



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

August 23, 2011

APPLICANT: Energy Northwest

FACILITY: Columbia Generating Station

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON
AUGUST 17, 2011, BETWEEN THE U.S. NUCLEAR REGULATORY
COMMISSION AND ENERGY NORTHWEST, CONCERNING THE RESPONSE
TO THE REQUEST FOR ADDITIONAL INFORMATION PERTAINING TO THE
COLUMBIA GENERATING STATION, LICENSE RENEWAL APPLICATION
(TAC NO. ME3058)

The U.S. Nuclear Regulatory Commission and representatives of Energy Northwest (the applicant), held a telephone conference call on August 17, 2011, to discuss and clarify the response to the request for additional information (RAI) concerning the Columbia Generating Station, license renewal application.

Enclosure 1 provides a listing of the participants and Enclosure 2 contains the RAI discussed with the applicant, including a brief description on the status of the item.

The applicant had an opportunity to comment on this summary.

A handwritten signature in black ink, reading "Arthur Cunanan".

Arthur D. Cunanan, Project Manager
Projects Branch 1
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket No. 50-397

Enclosures:
As stated

cc w/encls: Listserv

TELEPHONE CONFERENCE CALL
COLUMBIA GENERATING STATION LICENSE RENEWAL APPLICATION
LIST OF PARTICIPANTS
August 17, 2011

PARTICIPANTS:

Arthur Cunanan
Allen Hiser
Abbas Mostala
Janet Worthington
Scott Wood
John Twomey
Steven Richter

AFFILIATIONS:

U.S. Nuclear Regulatory Commission (NRC)
NRC
Energy Northwest (EN)
EN
EN
EN
EN

TELEPHONE CONFERENCE CALL
COLUMBIA GENERATING STATION
LICENSE RENEWAL APPLICATIONS
AUGUST 17, 2011

The U.S. Nuclear Regulatory Commission (NRC or the staff) and representatives of Energy Northwest (the applicant), held telephone conference call on August 17, 2011, to discuss the following response to the request for additional information (RAI) concerning the Columbia Generating Station (Columbia) license renewal application (LRA).

Response to RAI B.2.10-2: Related to the core plate rim hold-down bolts

The following discussion was related to a follow-up telephone conference call held on August 11, 2011.

Discussion:

The applicant clarified what prompted Columbia to verify that core plate wedges were not installed. The applicant will include in its LRA supplement on the core plate rim hold-down bolts time limited aging analysis disposition, a statement that it had reviewed the boiling water reactor vessel internals project (BWRVIP) inspection guidance and ensured that all other inspection guidance from the BWRVIP reports have been captured.

The staff will not send an additional RAI.

ENCLOSURE 2

August 23, 2011

APPLICANT: Energy Northwest

FACILITY: Columbia Generating Station

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON
AUGUST 17, 2011, BETWEEN THE U.S. NUCLEAR REGULATORY
COMMISSION AND ENERGY NORTHWEST, CONCERNING THE RESPONSE
TO THE REQUEST FOR ADDITIONAL INFORMATION PERTAINING TO THE
COLUMBIA GENERATING STATION, LICENSE RENEWAL APPLICATION
(TAC NO. ME3058)

The U.S. Nuclear Regulatory Commission and representatives of Energy Northwest (the applicant), held a telephone conference call on August 17, 2011, to discuss and clarify the response to the request for additional information (RAI) concerning the Columbia Generating Station, license renewal application.

Enclosure 1 provides a listing of the participants and Enclosure 2 contains the RAI discussed with the applicant, including a brief description on the status of the item.

The applicant had an opportunity to comment on this summary.

/RA/

Arthur D. Cunanan, Project Manager
Projects Branch 1
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket No. 50-397

Enclosures:
As stated

cc w/encls: Listserv

DISTRIBUTION:
See next page

ADAMS Accession No.: ML11230B089

*concurrence via e-mail

OFFICE	LA: DLR/RPB1*	PM: DLR/RPB1	BC: DLR/RPB1	LA: DLR/RPB1	PM: DLR/RPB1
NAME	SFigueroa	ACunanan	DMorey	SFigueroa	ACunanan
DATE	08/19/2011	08/19/2011	08/19/2011	08/22/2011	08/23/2011

OFFICIAL RECORD COPY

Letter to Energy Northwest from Arthur D. Cunanan dated August 23, 2011

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON
AUGUST 17, 2011, BETWEEN THE U.S. NUCLEAR REGULATORY
COMMISSION AND ENERGY NORTHWEST, CONCERNING THE RESPONSE
TO THE REQUEST FOR ADDITIONAL INFORMATION PERTAINING TO THE
COLUMBIA GENERATING STATION, LICENSE RENEWAL APPLICATION
(TAC NO. ME3058)

DISTRIBUTION:

HARD COPY:

DLR R/F

E-MAIL:

PUBLIC

RidsNrrDlr Resource

RidsNrrDlrRpb1 Resource

RidsNrrDlrRpb2 Resource

RidsNrrDlrRarb Resource

RidsNrrDlrRapb Resource

RidsNrrDlrRasb Resource

RidsNrrDlrRerb Resource

RidsNrrDlrRpob Resource

DDoyle

MThadani

WWalker, RIV

RCohen, RIV

LSubin, OGC