

**From:** Sanders, Carleen  
**Sent:** Friday, August 19, 2011 10:57 PM  
**To:** 'william.d.bartron@dom.com'; 'william.e.brown@dom.com'  
**Subject:** Millstone 2: Request for Additional Information Regarding Temporary Non-Code Compliant Condition  
**Attachments:** Millstone 2 flange RAls.docx

Mr. William Bartron,

By letter dated August 19, 2011, Dominion Nuclear Connecticut, Inc. (DNC or the licensee) requested relief from certain Section XI requirements of the *American Society of Mechanical Engineers* (ASME) Boiler and Pressure Vessel Code (ASME Code) for Millstone Power Station, Unit No. 2 (MPS2). Relief Request RR-04-12 is based on the hardship of performing required ASME Code repair/replacement activities to a degraded piping flange in the 'A' train 10-inch service water (SW) supply line to the emergency diesel generator heat exchangers. To complete its review, the U.S. Nuclear Regulatory Commission (NRC) staff requests a response to the attached request for additional information.

If you have any questions please contact me at 301-415-1603.

Sincerely,

Carleen J. Sanders, Project Manager  
Plant Licensing Branch I-2  
Division of Operating Reactor Licensing  
Office of Reactor Regulation