

From: William Bartron [wbartron@cox.net]
Sent: Saturday, August 20, 2011 6:20 AM
To: Sanders, Carleen
Cc: William.D.Bartron@dom.com; Mohamed Elmaghrabi
Subject: Millstone Power Station Unit 2 (MPS2) Temporary Non-Code
Compliant Condition of the Class 3 SW System 10-Inch EDG Supply
Piping Flange Relief Request RAI Responses
Attachments: Response to MPS2 RR RAIs.doc

Carleen J. Sanders, Project Manager
Plant Licensing Branch I-2
Division of Operating Reactor Licensing
Office of Reactor Regulation

By letter dated August 19, 2011, Dominion Nuclear Connecticut, Inc. (DNC or the licensee) requested relief from certain Section XI requirements of the American Society of Mechanical Engineers (ASME) Boiler and Pressure Vessel Code (ASME Code) for Millstone Power Station, Unit No. 2 (MPS2). Relief Request RR-04-12 is based on the hardship of performing required ASME Code repair/replacement activities to a degraded piping flange in the 'A' train 10-inch service water (SW) supply line to the emergency diesel generator heat exchangers. To complete its review, on August 19, 2011, the U.S. Nuclear Regulatory Commission (NRC) staff requested a response to a request for additional information. The DNC response to the request for additional information is attached.

If you have any questions please contact me at 860-444-4301.

Sincerely,

William D. Bartron
Station Licensing Supervisor
Millstone Power Station
Dominion Nuclear Connecticut, Inc.