

REQUEST FOR ADDITIONAL INFORMATION 807-5967 REVISION 3

8/18/2011

US-APWR Design Certification

Mitsubishi Heavy Industries

Docket No. 52-021

SRP Section: 10.04.06 - Condensate Cleanup System

Application Section: 10.4.6

QUESTIONS for Component Integrity, Performance, and Testing Branch 1 (AP1000/EPR Projects)
(CIB1)

10.04.06-17

In response to RAI 630-5044, Question 10.04.06-16 you state that the COL applicant will provide secondary side water chemistry values and operator actions, or it will commit to the latest version of the EPRI "PWR Secondary Water Chemistry Guidelines".

Although the staff finds this resolution to be acceptable, you should include a new COL item in the DCD to identify this action to the COL applicant.