

REQUEST FOR ADDITIONAL INFORMATION 813-5935 REVISION 3

8/23/2011

US-APWR Design Certification

Mitsubishi Heavy Industries

Docket No. 52-021

SRP Section: 03.02.01 - Seismic Classification

Application Section: 3.2.1

QUESTIONS for Engineering Mechanics Branch 2 (ESBWR/ABWR Projects) (EMB2)

03.02.01-22

In RAI 2041 Question 03.02.01-14 and RAI 5382 Question 03.02.01-21, NRC staff identified examples of SSCs that did not appear to be seismically classified in Table 3.2-2. Although the RAI responses proposed a revision to include certain missing components, the responses have not addressed the request to review the entire scope of SSCs that are not site-specific and completeness in scope of Table 3.2-2. Two additional examples of SSCs that should be seismically classified are the vent stack and essential service water intake screens. Clarify if Table 3.2-2 has been reviewed for completeness of non-site-specific SSCs and include any additional SSCs and their classification. Also identify specific SSCs that are site-specific and are to be classified by the COL applicant.