

REQUEST FOR ADDITIONAL INFORMATION 816-5989 REVISION 0

8/24/2011

US-APWR Design Certification

Mitsubishi Heavy Industries

Docket No. 52-021

SRP Section: 16 - Technical Specifications

Application Section: TS Bases

QUESTIONS for Technical Specification Branch (CTSB)

16-304

Correct the following errors in the Technical Specifications (TS) Bases related to adoption of TSTF-425-A, Rev. 3, "Relocate Surveillance Frequencies to Licensee Control - RITSTF Initiative 5b":

1. Two places in the Bases where numerical values of Surveillance Requirement (SR) frequency are outside of the brackets (i.e., SR 3.4.16.1 and SR 3.5.1.6), and as a result, in the R-COLA, the SR discussion still contains these numerical values.
2. One place where the Surveillance Frequency Control Program (SFCP) is opted in the TS but no discussion is provided in the Bases (SR 3.7.15.1).
3. Six places in the Bases where the brackets cover the entire text of the SR discussion (i.e., SR 3.1.4.1, SR 3.1.6.2, SR 3.2.3.2, SR 3.4.1.1, SR 3.4.1.2, and SR 3.4.1.3), and as a result, in the R-COLA, the SR discussion contains only the statement "The Surveillance Frequency is based on operating experience, equipment reliability, and plant risk and is controlled under the Surveillance Frequency Control Program."