

September 8, 2011

Dr. Mohamad Al-Sheikhly,  
Professor and Director  
Radiation Facilities and Nuclear Reactor  
Chemical and Nuclear Engineering Building 090  
University of Maryland  
College Park, MD 20742

SUBJECT: UNIVERSITY OF MARYLAND, REQUEST FOR ADDITIONAL INFORMATION  
REGARDING THE LICENSE RENEWAL FOR THE MARYLAND UNIVERSITY  
TRAINING REACTOR (TAC NO. ME1592)

Dear Dr. Al-Sheikhly:

The U. S. Nuclear Regulatory Commission (NRC) is continuing the review of your application for renewal of Facility Operating License No. R-70, Docket No. 50-166 for the Maryland University Training Reactor dated May 12, 2000, as supplemented by letters dated June 7, August 4, September 17, and October 7, 2004; April 18, 2005, April 25 (two letters), August 28 (two letters), November 9, and December 18, 2006; May 27, August 27, September 22, and December 14, 2010; January 31, February 2, March 17, May 2, July 5, and July 29, 2011. During our review of enclosure 2 of your letter dated July 5, 2011, questions have arisen for which we require additional information and clarification. Please provide responses to the enclosed requests for additional information by October 12, 2011. If you are unable to respond within this timeframe, submit a written request for an extension that explains the reason for the extension request.

In accordance with Title 10 of the *Code of Federal Regulations* Section 50.30(b), your response must be executed in a signed original under oath or affirmation. Your response must be submitted in accordance with 10 CFR 50.4, "Written Communications." Information included in your response that is considered security, sensitive, or proprietary, that you seek to have withheld from the public, must be marked in accordance with 10 CFR 2.390, "Public inspections, exemptions, requests for withholding."

If you have any questions please contact Spyros A. Traiforos at 301-415-3965 or by electronic mail at [Spyros.Traiforos@nrc.gov](mailto:Spyros.Traiforos@nrc.gov) or me at 301-415-2784 or by electronic mail at [William.Kennedy@nrc.gov](mailto:William.Kennedy@nrc.gov).

Sincerely,

/RA/

William B. Kennedy, Project Manager  
Research and Test Reactors Licensing Branch  
Division of Policy and Rulemaking  
Office of Nuclear Reactor Regulation

Docket No. 50-166  
License No. R-70

cc: See next page

University of Maryland

Docket No. 50-166

cc:

Director, Dept. of Natural Resources  
Power Plant Siting Program  
Energy & Coastal Zone Administration  
Tawes State Office Building  
Annapolis, MD 21401

Mr. Roland G. Fletcher, Program Manager IV  
Radiological Health Program  
Maryland Department of Environment  
1800 Washington Blvd., Suite 750  
Baltimore, MD 21230

Mr. Vincent G. Adams  
Facility Coordinator  
Chemical and Nuclear Engineering Building 090  
University of Maryland  
College Park, MD 20742

Tom O'Brien  
Radiation Safety Officer  
Department of Environmental Safety  
3115 Chesapeake Building 338  
University of Maryland  
College Park, MD 20742

Test, Research, and Training  
Reactor Newsletter  
University of Florida  
202 Nuclear Sciences Center  
Gainesville, FL 32611

**OFFICE OF NUCLEAR REACTOR REGULATION**  
**REQUEST FOR ADDITIONAL INFORMATION**  
**REGARDING LICENSE RENEWAL FOR**  
**THE MARYLAND UNIVERSITY TRAINING REACTOR**  
**LICENSE NO. R-70; DOCKET NO. 50-166**

The following requests for additional information (RAIs) relate to the dose calculations submitted as Enclosure 2 to the University of Maryland (UMD) letter dated July 5, 2011. The Enclosure addressed RAIs 8, 10, and 12 sent to you by letter dated January 31, 2011. The dose calculations in Enclosure 2 addressed the occupational dose to workers, the dose to a member of the public in the Nuclear and Chemical Engineering Building next to the Maryland University Training Reactor (MUTR), and the dose at the nearest residence during a maximum hypothetical accident (MHA) and normal operations. In the calculations, UMD considered two operational modes of the ventilation system, namely ventilation "on" and ventilation "off". The purpose of these calculations was to demonstrate that the occupational doses to workers and doses to the members of the public would not exceed the limits of Title 10 of the *Code of Federal Regulations* (10 CFR) Part 20, "Standards for Protection Against Radiation."

**Maximum Hypothetical Accident:**

NUREG-1537, Part 1, "Guidelines for Preparing and Reviewing Applications for the Licensing of Non-Power Reactors; Format and Content," provides guidance for analyzing accident consequences including radiation dose limits generally found acceptable by the NRC. NUREG-1537, Part 1, Section 13.2, suggests a step-by-step process for determining the consequences of accidents. The following four questions address your analysis of the consequences of the MHA.

1. NUREG-1537, Part 1, Section 13.2 states that the radiological consequences should include external and internal exposures. From the review of your responses it was not clear whether both the external and internal contributions to the dose were included. Please discuss whether the dose analyses include contributions from external (submersion or shine) and internal (inhalation) exposures from radioactive material released from the MHA at each of the following locations addressed in your analyses:
  - a) Reactor building (occupational dose)
  - b) Chemical and Nuclear Engineering Building (the area housing classrooms, offices and nuclear engineering laboratories) at the reactor bay door (public dose)
  - c) Nearest residence (public dose)

If the analyses don't include both external and internal exposures, explain why the analyses exclude the dose contributions from external or internal exposures, or revise the analyses to include both exposures.

2. Please clarify whether the dose conversion factors used in your analyses are as conservative as the dose conversion factors in 10 CFR Part 20, Appendix B, "Annual limits on intake (ALIs) and derived air concentrations (DACs) of radionuclides for occupational exposure; effluent concentrations; concentrations for release to sewerage."
3. Please clarify whether the Table at the bottom of page 13 of Enclosure 2 is the internal dose due to inhalation. Also provide the isotopes included in this Table.
4. NUREG 1537, Part 1, Section 13.2 states that exposure conditions used in determining the consequences of the MHA should account for the most exposed member of the public in the unrestricted environment until the accident conditions are terminated or the person is moved. Enclosure 2 provides dose rates to a member of the public at the reactor door and the total dose to a member of the public at the nearest residence. However it is unclear why either of these locations corresponds to the location of the most exposed member of the public. Please provide an analysis of the total dose to the most exposed member of the public in the unrestricted area. Include justifications for all assumptions regarding the duration of the exposure and an explanation of why the analysis represents the most exposed member of the public.

#### Normal Operation - Ar-41 releases

5. As discussed in our previous communications, you plan to conduct a series of measurements to determine the Ar-41 release in the reactor bay during normal operation and use the data to revise the calculations of doses due to Ar-41 releases provided on page 14 of Enclosure 2. Please use this data to re-evaluate all dose calculations due to Ar-41 release at all selected locations. As we discussed, please provide the revised dose calculations by October 21, 2011.

September 8, 2011

Dr. Mohamad Al-Sheikhly,  
Professor and Director  
Radiation Facilities and Nuclear Reactor  
Chemical and Nuclear Engineering Building 090  
University of Maryland  
College Park, MD 20742

SUBJECT: UNIVERSITY OF MARYLAND, REQUEST FOR ADDITIONAL INFORMATION  
REGARDING THE LICENSE RENEWAL FOR THE MARYLAND UNIVERSITY TRAINING  
REACTOR (TAC NO. ME1592)

Dear Dr. Al-Sheikhly:

The U. S. Nuclear Regulatory Commission (NRC) is continuing the review of your application for renewal of Facility Operating License No. R-70, Docket No. 50-166 for the Maryland University Training Reactor dated May 12, 2000, as supplemented by letters dated June 7, August 4, September 17, and October 7, 2004; April 18, 2005, April 25 (two letters), August 28 (two letters), November 9, and December 18, 2006; May 27, August 27, September 22, and December 14, 2010; January 31, February 2, March 17, May 2, July 5, and July 29, 2011. During our review of enclosure 2 of your letter dated July 5, 2011, questions have arisen for which we require additional information and clarification. Please provide responses to the enclosed requests for additional information by October 12, 2011. If you are unable to respond within this timeframe, submit a written request for an extension that explains the reason for the extension request.

In accordance with Title 10 of the Code of Federal Regulations Section 50.30(b), your response must be executed in a signed original under oath or affirmation. Your response must be submitted in accordance with 10 CFR 50.4, "Written Communications." Information included in your response that is considered security, sensitive, or proprietary, that you seek to have withheld from the public, must be marked in accordance with 10 CFR 2.390, "Public inspections, exemptions, requests for withholding."

If you have any questions please contact Spyros A. Traiforos at 301-415-3965 or by electronic mail at Spyros.Traiforos@nrc.gov or me at 301-415-2784 or by electronic mail at William.Kennedy@nrc.gov.

Sincerely,

/RA/

William B. Kennedy, Project Manager  
Research and Test Reactors Licensing Branch  
Division of Policy and Rulemaking  
Office of Nuclear Reactor Regulation

Docket No. 50-166  
License No. R-70  
cc: See next page

DISTRIBUTION:

PUBLIC	RidsNrrDprPrta	RidsNrrDpr	PRLB r/f
WKennedy, NRR	STraiforos, NRR	GLappert, NRR	AAdams, NRR
LTran, NRR			

ADAMS Accession No: ML112380621

NRR-088

OFFICE	PRLB: PM	PRLB : PM	PRPB: LA	PRLB: BC	PRLB : PM
NAME	STraiforos	WKennedy	GLappert	JQuichocho	WKennedy
DATE	8/29/11	9/8/11	9/8/11	9/8/11	9/8/11

OFFICIAL RECORD COPY