

ArevaEPRDCPEm Resource

From: Tesfaye, Getachew
Sent: Tuesday, August 30, 2011 3:38 PM
To: 'usepr@areva.com'
Cc: Scarbrough, Thomas; Terao, David; Jaffe, David; Colaccino, Joseph; ArevaEPRDCPEm Resource
Subject: U.S. EPR Design Certification Application RAI No. 501 (5934), FSAR Ch. 14
Attachments: RAI_501_CIB1_5934.doc

Attached please find the subject requests for additional information (RAI). A draft of the RAI was provided to you on July 21, 2011, and on August 30, 2011, you informed us that the RAI is clear and no further clarification is needed. As a result, no change is made to the draft RAI. The schedule we have established for review of your application assumes technically correct and complete responses within 30 days of receipt of RAIs. For any RAIs that cannot be answered within 30 days, it is expected that a date for receipt of this information will be provided to the staff within the 30 day period so that the staff can assess how this information will impact the published schedule.

Thanks,
Getachew Tesfaye
Sr. Project Manager
NRO/DNRL/NARP
(301) 415-3361

Hearing Identifier: AREVA_EPR_DC_RAIs
Email Number: 3369

Mail Envelope Properties (0A64B42AAA8FD4418CE1EB5240A6FED1471D38F723)

Subject: U.S. EPR Design Certification Application RAI No. 501 (5934), FSAR Ch. 14
Sent Date: 8/30/2011 3:38:23 PM
Received Date: 8/30/2011 3:38:24 PM
From: Tesfaye, Getachew

Created By: Getachew.Tesfaye@nrc.gov

Recipients:

"Scarbrough, Thomas" <Thomas.Scarbrough@nrc.gov>
Tracking Status: None
"Terao, David" <David.Terao@nrc.gov>
Tracking Status: None
"Jaffe, David" <David.Jaffe@nrc.gov>
Tracking Status: None
"Colaccino, Joseph" <Joseph.Colaccino@nrc.gov>
Tracking Status: None
"ArevaEPRDCPEm Resource" <ArevaEPRDCPEm.Resource@nrc.gov>
Tracking Status: None
"usepr@areva.com" <usepr@areva.com>
Tracking Status: None

Post Office: HQCLSTR02.nrc.gov

Files	Size	Date & Time
MESSAGE	797	8/30/2011 3:38:24 PM
RAI_501_CIB1_5934.doc	32250	

Options

Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received:

Request for Additional Information No. 501(5934), Revision 0

8/30/2011

U. S. EPR Standard Design Certification

AREVA NP Inc.

Docket No. 52-020

SRP Section: 14.03.03 - Piping Systems and Components - Inspections, Tests, Analyses, and
Acceptance Criteria

Application Section: 14.3.3

QUESTIONS for Component Integrity, Performance, and Testing Branch 1 (AP1000/EPR Projects)
(CIB1)

14.03.03-53

The ITAAC for the environmental qualification (EQ) of U.S. EPR components listed in Tier 1 of the U.S. EPR FSAR do not appear to be consistent with the EQ requirements specified in Tier 2 of the U.S. EPR FSAR. For example, the Commitment Wording for ITAAC 6.1 in Table 2.2.3-3, "Safety Injection System and Residual Heat Removal System ITAAC," in U.S. EPR FSAR Tier 1 states that components in Table 2.2.3-2, that are designated as harsh environment, will perform the function listed in Table 2.2.3-1 in the environments that exist during and following design basis events. To be consistent with the EQ requirements in Section 3.11, "Environmental Qualification of Mechanical and Electrical Equipment," of U.S. EPR FSAR Tier 2, the Commitment Wording for ITAAC 6.1 of Table 2.2.3-3 in U.S. EPR FSAR Tier 1 should be revised to read as follows: "Components in Table 2.2.3-2 that are designated as harsh environment will be capable of performing design safety functions listed in Table 2.2.3-1 under normal environmental conditions, containment test conditions, anticipated operational occurrences, and accident and post-accident environmental conditions." Similarly, item a in the Inspections, Tests, Analyses column of ITAAC 6.1 should be revised to read as follows: "Type tests or type tests and analysis are performed to demonstrate the ability of the components listed as harsh environment in Table 2.2.3-2 to perform the function listed in Table 2.2.3-1 under normal environmental conditions, containment test conditions, anticipated operational occurrences, and accident and post-accident environmental conditions." Further, item a in the Acceptance Criteria column of ITAAC 6.1 should be revised to read as follows: "Environmental Qualification Data Packages (EQDPs) exist and conclude that the components listed as harsh environment in Table 2.2.3-2 can perform the function listed in Table 2.2.3-1 under normal environmental conditions, containment test conditions, anticipated operational occurrences, and accident and post-accident environmental conditions, including the time required to perform the listed function." The EQ ITAAC listed in U.S. EPR FSAR Tier 1 for other U.S. EPR systems should also be revised to be consistent with the EQ requirements in U.S. EPR FSAR Tier 2, Section 3.11, similar to the proposed language for ITAAC 6.1 in U.S. EPR FSAR Tier 1, Table 2.2.3-3.