



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

September 8, 2011

APPLICANT: Energy Northwest

FACILITY: Columbia Generating Station

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON  
AUGUST 22, 2011, BETWEEN THE U.S. NUCLEAR REGULATORY  
COMMISSION AND ENERGY NORTHWEST, CONCERNING TOPICS  
PERTAINING TO THE COLUMBIA GENERATING STATION, LICENSE  
RENEWAL APPLICATION (TAC NO. ME3058)

The U.S. Nuclear Regulatory Commission and representatives of Energy Northwest (the applicant), held a telephone conference call on August 22, 2011, to discuss and clarify topics concerning the Columbia Generating Station, license renewal application.

Enclosure 1 provides a listing of the participants and Enclosure 2 contains a listing of the request for additional information discussed with the applicant, including a brief description on the status of the item.

The applicant had an opportunity to comment on this summary.

A handwritten signature in black ink, reading "Arthur Cunanan".

Arthur D. Cunanan, Project Manager  
Projects Branch 1  
Division of License Renewal  
Office of Nuclear Reactor Regulation

Docket No. 50-397

Enclosures:  
As stated

cc w/encls: Listserv

TELEPHONE CONFERENCE CALL  
COLUMBIA GENERATING STATION LICENSE RENEWAL APPLICATION  
LIST OF PARTICIPANTS  
August 22, 2011

**PARTICIPANTS:**

Arthur Cunanan  
Allen Hiser  
On Yee  
Ching Ng  
Abbas Mostala  
Steve Gosslin  
Jack Cole

**AFFILIATIONS:**

U.S. Nuclear Regulatory Commission (NRC)  
NRC  
NRC  
NRC  
Energy Northwest (EN)  
EN  
EN

TELEPHONE CONFERENCE CALL  
COLUMBIA GENERATING STATION  
LICENSE RENEWAL APPLICATIONS  
AUGUST 22, 2011

The U.S. Nuclear Regulatory Commission (NRC or the staff) and representatives of Energy Northwest (the applicant), held telephone conference calls on August 22, 2011, to discuss the topics concerning the Columbia Generating Station license renewal application (LRA).

Fatigue Analysis of Polar Crane

Discussion:

The original LRA submitted on January 19, 2010, stated the fatigue analysis of the polar crane does not meet the definition of a time-limited aging analysis (TLAA).

The staff discussed the fatigue analysis of the polar crane does meet the definition of a TLAA.

The applicant understands the staff's concern and will provide an LRA supplement to include an analysis of the polar crane as a TLAA and an aging management review line item from the polar crane.

The staff will not send a request for additional information (RAI).

Boiling Water Reactor Stress Corrosion Cracking Program

Discussion:

The applicant discussed performing ultrasonic testing of the subject flaw, discussed in the LRA, during refueling outage 20 in 2011. The results showed that there was no growth of the subject flaw.

The applicant also discussed that informing the NRC of the subject flaw is a requirement, but informing the NRC of inspection frequency changes to the subject flaw is not a requirement. The staff agrees with the applicant's statement. The subject flaw was reported to the NRC in 1991.

The staff will not send an RAI.

September 8, 2011

APPLICANT: Energy Northwest

FACILITY: Columbia Generating Station

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON  
AUGUST 22, 2011, BETWEEN THE U.S. NUCLEAR REGULATORY  
COMMISSION AND ENERGY NORTHWEST, CONCERNING TOPICS  
PERTAINING TO THE COLUMBIA GENERATING STATION, LICENSE  
RENEWAL APPLICATION (TAC NO. ME3058)

The U.S. Nuclear Regulatory Commission and representatives of Energy Northwest (the applicant), held a telephone conference call on August 22, 2011, to discuss and clarify topics concerning the Columbia Generating Station, license renewal application.

Enclosure 1 provides a listing of the participants and Enclosure 2 contains a listing of the request for additional information discussed with the applicant, including a brief description on the status of the item.

The applicant had an opportunity to comment on this summary.

**/RA/**

Arthur D. Cunanan, Project Manager  
Projects Branch 1  
Division of License Renewal  
Office of Nuclear Reactor Regulation

Docket No. 50-397

Enclosures:  
As stated

cc w/encls: Listserv

DISTRIBUTION:  
See next page

**ADAMS Accession No.: ML11250A015**

\*concurrence via e-mail

<b>OFFICE</b>	LA: DLR/RPB1*	PM: DLR/RPB1	BC: DLR/RPB1	LA: DLR/RPB1	PM: DLR/RPB1
<b>NAME</b>	SFigueroa	ACunanan	DMorey	SFigueroa	ACunanan
<b>DATE</b>	09/7/2011	09/07/2011	09/08/2011	09/08/2011	09/08/2011

**OFFICIAL RECORD COPY**

Letter to Energy Northwest from A. Cunanan dated September 8, 2011

**SUBJECT:** SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON  
AUGUST 22, 2011, BETWEEN THE U.S. NUCLEAR REGULATORY  
COMMISSION AND ENERGY NORTHWEST, CONCERNING TOPICS  
PERTAINING TO THE COLUMBIA GENERATING STATION, LICENSE  
RENEWAL APPLICATION (TAC NO. ME3058)

**DISTRIBUTION:**

**HARD COPY:**

DLR R/F

**E-MAIL:**

PUBLIC

RidsNrrDir Resource

RidsNrrDirRpb1 Resource

RidsNrrDirRpb2 Resource

RidsNrrDirRarb Resource

RidsNrrDirRapb Resource

RidsNrrDirRasb Resource

RidsNrrDirRerb Resource

RidsNrrDirRpob Resource

-----  
DDoyle

ACunanan

MThadani

WWalker, RIV

RCohen, RIV

LSubin, OGC

-----  
BSingal