



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

September 23, 2011

APPLICANT: Energy Northwest

FACILITY: Columbia Generating Station

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON  
SEPTEMBER 12, 2011, BETWEEN THE U.S. NUCLEAR REGULATORY  
COMMISSION AND ENERGY NORTHWEST, CONCERNING THE DRAFT  
REQUEST FOR ADDITIONAL INFORMATION PERTAINING TO THE  
COLUMBIA GENERATING STATION, LICENSE RENEWAL APPLICATION  
(TAC NO. ME3058)

The U.S. Nuclear Regulatory Commission and representatives of Energy Northwest (the applicant), held a telephone conference call on September 12, 2011, to discuss and clarify the draft request for additional information (RAI) concerning the Columbia Generating Station, license renewal application.

Enclosure 1 provides a listing of the participants and Enclosure 2 contains a listing of the RAI discussed with the applicant, including a brief description on the status of the item.

The applicant had an opportunity to comment on this summary.

A handwritten signature in black ink, reading "Arthur Cunanan".

Arthur D. Cunanan, Project Manager  
Projects Branch 1  
Division of License Renewal  
Office of Nuclear Reactor Regulation

Docket No. 50-397

Enclosures:  
As stated

cc w/encls: Listserv

TELEPHONE CONFERENCE CALL  
COLUMBIA GENERATING STATION LICENSE RENEWAL APPLICATION  
LIST OF PARTICIPANTS  
September 12, 2011

**PARTICIPANTS:**

Arthur Cunanan  
Chris Sydnor  
Abbas Mostala  
Scott Wood  
John Sisk  
Lori Tilly  
George Depta

**AFFILIATIONS:**

U.S. Nuclear Regulatory Commission (NRC)  
NRC  
Energy Northwest (EN)  
EN  
EN  
General Electric (GE)  
GE

TELEPHONE CONFERENCE CALL  
COLUMBIA GENERATING STATION  
LICENSE RENEWAL APPLICATIONS  
SEPTEMBER 12, 2011

The U.S. Nuclear Regulatory Commission (NRC or the staff) and representatives of Energy Northwest (the applicant), held telephone conference calls on September 12, 2011, to discuss the following draft request for additional information (RAI) concerning the Columbia Generating Station (Columbia) license renewal application (LRA).

Draft RAI 4.2-7: Related to the upper shelf energy of the N12 nozzle forging

Discussion:

The staff discussed the need for the applicant to provide a technical basis for initial upper shelf energy (USE) values of 62 ft-lb and copper content of 0.27 percent for SA-508 Class 1 forgings material, which can be verified by the staff, in order for the applicant to demonstrate that the USE value for the N12 nozzle forgings will not pass below 50 ft-lbs prior to the period of extended operation.

The applicant understands the staff's concern and will submit the SA-508 Class 1 raw data and calculations to the NRC so that the staff can verify the results. Some of the information is proprietary, so the applicant will submit an affidavit to redact proprietary information from being viewed by the public. A non-proprietary version of the document will be available to the public.

The staff will send an RAI.

September 23, 2011

APPLICANT: Energy Northwest

FACILITY: Columbia Generating Station

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON  
SEPTEMBER 12, 2011, BETWEEN THE U.S. NUCLEAR REGULATORY  
COMMISSION AND ENERGY NORTHWEST, CONCERNING THE DRAFT  
REQUEST FOR ADDITIONAL INFORMATION PERTAINING TO THE  
COLUMBIA GENERATING STATION, LICENSE RENEWAL APPLICATION  
(TAC NO. ME3058)

The U.S. Nuclear Regulatory Commission and representatives of Energy Northwest (the applicant), held a telephone conference call on September 12, 2011, to discuss and clarify the draft request for additional information (RAI) concerning the Columbia Generating Station, license renewal application.

Enclosure 1 provides a listing of the participants and Enclosure 2 contains a listing of the RAI discussed with the applicant, including a brief description on the status of the item.

The applicant had an opportunity to comment on this summary.

*/RA/*

Arthur D. Cunanan, Project Manager  
Projects Branch 1  
Division of License Renewal  
Office of Nuclear Reactor Regulation

Docket No. 50-397

Enclosures:  
As stated

cc w/encls: Listserv

DISTRIBUTION:  
See next page

**ADAMS Accession No.: ML11256A300**

\*concurrence via e-mail

<b>OFFICE</b>	LA: DLR/RPB1*	PM: DLR/RPB1	BC: DLR/RPB1	LA: DLR/RPB1	PM: DLR/RPB1
<b>NAME</b>	SFigueroa	ACunanan	DMorey	SFigueroa	ACunanan
<b>DATE</b>	09/14/2011	09/16/2011	09/21/2011	09/22/2011	09/23/2011

**OFFICIAL RECORD COPY**

Letter to Energy Northwest from Arthur D. Cunanan dated September 23, 2011

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON  
SEPTEMBER 12, 2011, BETWEEN THE U.S. NUCLEAR REGULATORY  
COMMISSION AND ENERGY NORTHWEST, CONCERNING THE DRAFT  
REQUEST FOR ADDITIONAL INFORMATION PERTAINING TO THE  
COLUMBIA GENERATING STATION, LICENSE RENEWAL APPLICATION  
(TAC NO. ME3058)

DISTRIBUTION:

**E-MAIL:**

**PUBLIC**

RidsNrrDlr Resource

RidsNrrDlrRpb1 Resource

RidsNrrDlrRpb2 Resource

RidsNrrDlrRarb Resource

RidsNrrDlrRapb Resource

RidsNrrDlrRasb Resource

RidsNrrDlrRerb Resource

RidsNrrDlrRpob Resource

-----

DDoyle

MThadani

WWalker, RIV

RCohen, RIV

LSubin, OGC