

A002

REGULATORY INFORMATION DISTRIBUTION SYSTEM

DOCKET NBR: 50-263 MONTICELLO
RECIPIENT: KEPPLER, J.G.
ORIGINATOR: ELIASON, L.R.
COMPANY NAME: N STATES PWR
SUBJECT:

DOC DATE: 781023
ACCESSION NBR: 7810300145
COPIES RECEIVED:
LTR 1 ENCL 0
SIZE: 1

On 781020 local leak rate testing of High Pressure Coolant Injection Sys exhaust isolation valve exceeded acceptable criteria. On 781021-22 reactor core isolation & reactor water cleanup sys exceeded criteria. Cause is being investigated.

DISTRIBUTION CODE: A002
DISTRIBUTION TITLE:
INCIDENT REPORTS

NOTARIZED _____

NAME	ENCL?
BR CHIEF	W/4 ENCL
REG FILE	W/ENCL
NRC PDR	W/ENCL
I & E	W/2 ENCL
MIPC	W/3 ENCL
I & C SYSTEMS BR	W/ENCL
NOVAK/CHECK	W/ENCL
EEB	W/ENCL
AD FOR ENG	W/ENCL
PLANT SYSTEMS BR	W/ENCL
HANAUER	W/ENCL
AD FOR PLANT SYSTEMS	W/ENCL
AD FOR SYS & PROJ	W/ENCL
REACTOR SAFETY BR	W/ENCL
ENGINEERING BR	W/ENCL
KREGER/J. COLLINS	W/ENCL
POWER SYS BR	W/ENCL
E. Jordan	W/ENCL
LPDR	W/ENCL
NSIC	W/ENCL
ACRS	W/16 ENCL

FOR ACTION

ORB#3 BC

TOTAL NUMBER OF COPIES REQUIRED:
LTR
ENCL

42
42

NOV 22 1978

NOTES:

A004
T

NSP

Harpster

NORTHERN STATES POWER COMPANY

Monticello Nuclear Generating Plant
Monticello, NY 55362

October 23, 1978

Mr. J. G. Keppler, Director
Region III
Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, IL 60137

Dear Mr. Keppler,

MONTICELLO NUCLEAR GENERATING PLANT
Docket No. 50-263 License No. DPR-22

On October 20, 1978, local leak rate testing of the High Pressure Coolant Injection System exhaust isolation valve, HPCI-9, indicated that the leakage exceeded the acceptance criteria for individual isolation valves as defined by Technical Specification 4.7.A.2.f.


On October 21, 1978, local leak rate testing of the Reactor Core Isolation Cooling System exhaust isolation valve, RCIC-9, indicated that the leakage exceeded the acceptance criteria for individual isolation valves as defined by Technical Specification 4.7.A.2.f.

On October 22, 1978, local leak rate testing of the Reactor Water Cleanup System isolation valves, MD 2397 and MD 2398, indicated that the leakage through that valve pair exceeded the acceptance criteria for individual isolation valves as defined by Technical Specification 4.7.A.2.f. These valves are tested as a unit. Therefore, individual valve leakages are not measured.

The cause of the high leakage rates is being investigated.

With the determination of the leakage rate for the reactor water cleanup system isolation valves, the total "as found" leakage for all testable penetrations and isolation valves, except the main steam isolation valves, exceeded the acceptance criteria defined in Technical Specification 4.7.A.2.f.

Yours very truly,


L. R. Eliason
Plant Manager

LRE/sdd

REGULATORY DOCKET FILE COPY

cc: Director, Office of Management Information
& Program Control
File

Copy sent by telecopy to Keppler.

7811210 145

Rec. 10/2

11
1007
9/10