NRC FORM 366
(7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | M N M N P 1 (2) | 0 0 - 0 0 0 0 0 - 0 0 (3) | 4 1 1 1 1 (4) | (5)

7 8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58

CON'T

0 1 | REPORT SOURCE L (6) | 0 5 0 0 0 2 6 3 (7) | 1 0 2 0 7 8 (8) | 1 1 2 2 7 8 (9)

7 8 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | DURING LOCAL LEAK RATE TESTING, HPCI-9, TURBINE EXHAUST LINE CHECK VALVE WAS FOUND

0 3 | LEAKING IN EXCESS OF TECHNICAL SPECIFICATION ACCEPTANCE CRITERIA (T.S. 4.7.A.2.f)

0 4 | THE AS FOUND LEAKAGE WAS 54.6 SCFH. FOUR PREVIOUS REPORTABLE EVENTS.

0 5 | (AO 74-05, AO 75-01, AO 75-17, M-RO-77-024)

0 6 |

0 7 |

0 8 | 7 8 9 80

0 9 | SYSTEM CODE S D (11) | CAUSE CODE E (12) | CAUSE SUBCODE B (13) | COMPONENT CODE V A L V E X (14) | COMP. SUBCODE C (15) | VALVE SUBCODE A (16)

7 8 9 10 11 12 13 18 19 20

(17) LER/RO REPORT NUMBER: EVENT YEAR 7 8 (21 22) | — (23) | SEQUENTIAL REPORT NO. 0 2 4 (24 26) | / (27) | OCCURRENCE CODE 0 1 (28 29) | REPORT TYPE T (30) | — (31) | REVISION NO. 0 (32)

ACTION TAKEN B (18) | FUTURE ACTION X (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS 0 0 0 0 (22) | ATTACHMENT SUBMITTED N (23) | NPRD-4 FORM SUB. Y (24) | PRIME COMP. SUPPLIER A (25) | COMPONENT MANUFACTURER A 3 9 5 (26)

33 34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | ANCHOR VALVE CO. 16" - 150 LB. SWING CHECK VALVE. FAILED TEST DUE TO ACCUMULATED DIRT

1 1 | ON SEATING SURFACES. SEATS CLEANED AND LAPPED. RETESTED SATISFACTORILY. PLAN

1 2 | TO INSTALL A DIFFERENT TYPE PRIMARY CONTAINMENT ISOLATION VALVE IN EXHAUST LINE.

1 3 |

1 4 | 7 8 9 80

1 5 | FACILITY STATUS H (28) | % POWER 0 0 0 (29) | OTHER STATUS (30) NA | METHOD OF DISCOVERY B (31) | DISCOVERY DESCRIPTION (32) LOCAL LEAK RATE TEST

7 8 9 10 12 13 44 45 46 80

1 6 | ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) NA | LOCATION OF RELEASE (36) NA

7 8 9 10 11 44 45 80

1 7 | PERSONNEL EXPOSURES NUMBER 0 0 0 (37) | TYPE Z (38) | DESCRIPTION (39) NA

7 8 9 11 12 13 80

1 8 | PERSONNEL INJURIES NUMBER 0 0 0 (40) | DESCRIPTION (41) NA

7 8 9 11 12 80

1 9 | LOSS OF OR DAMAGE TO FACILITY TYPE Z (42) | DESCRIPTION (43) NA

7 8 9 10 80

2 0 | PUBLICITY ISSUED N (44) | DESCRIPTION (45) NA | NRC USE ONLY

7 8 9 10 68 69 80

7811280249

NAME OF PREPARER D. E. PEDERSEN PHONE: 612/295-5151

GPO 917-926