



# NSP REGULATORY DOCKET FILE COPY

NORTHERN STATES POWER COMPANY

MINNEAPOLIS, MINNESOTA 55401

October 25, 1977



Mr. James G. Keppler  
Director - Region III  
Office of Inspection and Enforcement  
United States Nuclear Regulatory Commission  
799 Roosevelt Road  
Glen Ellyn, Illinois 60137

Dear Mr. Keppler:

Monticello Nuclear Generating Plant  
Docket No. 50-263 License No. DPR-22

The following is submitted in reply to IE Bulletin 77-02:

A survey has been performed to determine whether relays of the type and vintage described in the bulletin are used in safety-related applications at Monticello.

Safety-related systems parts lists were reviewed and equipment cabinets inspected -- the results of which indicate that no such relays are in use at Monticello. Furthermore, no relays of this type are planned for use at this time.

Yours very truly,

L. J. Wachter  
Vice President - Power Production  
and System Operation

cc: Mr. Victor Stello  
Mr. G. Charnoff  
Minnesota Pollution Control Agency  
Attention: Mr. J. W. Ferman

773040033

RECEIVED DOCUMENT  
PROCESSING UNIT

1977 OCT 31 AM 9 37

10/31/77  
10:10  
10/31/77

10/31/77 10:10