

W**

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)
DISTRIBUTION FOR INCOMING MATERIAL

50-263

REC: KEPPLER J G
NRC

ORG: MAYER L O
N STATES PWR

DOCDATE: 01/19/78
DATE RCVD: 01/24/78

DOCTYPE: LETTER NOTARIZED: NO
SUBJECT:

COPIES RECEIVED
LTR 0 ENCL 1

LICENSEE EVENT REPT (RO 50-263/78-001) ON 01/05/78 CONCERNING ONE OF THE TWO
SHIPPING CASKS USED TO TRANSPORT IRRADIATED COMPONENTS WAS PROVIDED WITH 1
INCH DIAMETER LID BOLTS RATHER THAN THE 1 1/4 INCH SIZE AS REQUIRED.

PLANT NAME: MONTICELLO

REVIEWER INITIAL: XJM
DISTRIBUTOR INITIAL:

***** DISTRIBUTION OF THIS MATERIAL IS AS FOLLOWS *****

INCIDENT REPORTS
(DISTRIBUTION CODE A002)

FOR ACTION: ~~BRANCH CHIEF DAVIS~~**W/4 ENCL

INTERNAL: REG FILE**W/ENCL
I & E**W/2 ENCL
SCHROEDER/IPPOLITO**W/ENCL
NOVAK/CHECK**W/ENCL
KNIGHT**W/ENCL
HANAUER**W/ENCL
EISENHUT**W/ENCL
SHAO**W/ENCL
KREGER/J. COLLINS**W/ENCL
L. CROCKER**W/ENCL

NRC PDR**W/ENCL
MIPC**W/3 ENCL
HOUSTON**W/ENCL
GRIMES**W/ENCL
BUTLER**W/ENCL
TEDESCO**W/ENCL
BAER**W/ENCL
VOLLMER/BUNCH**W/ENCL
ROSA**W/ENCL

EXTERNAL: LPDR'S
MINNEAPOLIS, MN**W/ENCL
TIC**W/ENCL
NSIC**W/ENCL
ACRS CAT B**W/16 ENCL

DISTRIBUTION: LTR 45 ENCL 45
SIZE: 1P+1P

CONTROL NBR: 780250005

***** THE END *****

NSP

REGULATORY DOCKET FILE COPY

NORTHERN STATES POWER COMPANY

MINNEAPOLIS, MINNESOTA 55401



January 19, 1978

Mr J G Keppler, Director, Region III
Office of Inspection & Enforcement
U S Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, IL 60137

Dear Mr Keppler:

MONTICELLO NUCLEAR GENERATING PLANT
Docket No. 263 License No. DPR-22

Nonconforming Bolts in Radwaste Shipping Cask

The Licensee Event Report for this occurrence is reproduced on the back of this letter. Enclosed are three copies.

This event is reported in compliance with Technical Specification 6.7.B.1.i, components that require corrective measures to prevent operation in a manner less conservative than assumed in the accident analysis.

Yours very truly,

L O Mayer, PE
Manager of Nuclear Support Services

LOM/MHV/ak

cc: Director, IE, USNRC (40)
Director, MIPC, USNRC (3)
MPCA: Attn: J W Ferman

780250005

A002/5
0/1
HEAD TO
HEAD

CONTROL BLOCK: _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

917-926