

MEMO ROUTE SLIP		See me about this.	For concurrence.	For action.
Form AEC-93 (Rev. May 14, 1947) AECM 0240		Note and return.	For signature.	For information.
TO (Name and unit) RO Chief, FS&EB RO:HQ (4) Licensing (4) DR Central Files Region I	INITIALS	REMARKS Northern States Power Company Monticello 50-263		
	DATE			
TO (Name and unit) Region II PDR Local PDR NSIC DTIE	INITIALS	REMARKS		
	DATE			
TO (Name and unit) OGC, Beth, P-506A A. Roisman F. Rizzo, RO:HQ	INITIALS	REMARKS		
	DATE			
FROM (Name and unit) G. Fiorelli RO:III	REMARKS Attached is a copy of licensee's reply dated July 11, 1974, to RO Bulletin 74-6.			
PHONE NO.	DATE 7-23-74			

USE OTHER SIDE FOR ADDITIONAL REMARKS

GPO : 1971 O - 445-469

Ry



N O R T H E R N   S T A T E S   P O W E R   C O M P A N Y

Minneapolis, Minnesota 55401

July 11, 1974

Mr. J. G. Keppler, Regional Director  
Directorate of Regulatory Operations  
Region III  
United States Atomic Energy Commission  
799 Roosevelt Road  
Glen Ellyn, Illinois 61073

Dear Mr. Keppler:

MONTICELLO NUCLEAR GENERATING PLANT  
Docket No. 50-263 License No. DPR-22

In accordance with DRO bulletin No. 74-6, this report is submitted to inform you that Westinghouse Type W-2 control switches are not used in Safety Systems at the Monticello Nuclear Generating Plant.

Yours very truly,

A handwritten signature in cursive script, appearing to read "L. J. Wachter".

L. J. Wachter  
Vice Pres.-Power Prod.  
& System Operations

LJW/mm

cc: J F O'Leary, Directorate of Licensing  
G Charnoff  
Minnesota Pollution Control Agency  
Attn: E A Pryzina  
File

JUL 22 1974