

MEMO ROUTE SLIP

Form AEC-93 (Rev. May 14, 1947) AECM 0240

See me about this.

For concurrence.

For action.

Note and return.

For signature.

For information.

TO (Name and unit)		INITIALS	REMARKS
J. Henderson, RO:HQ			Subject: Northern States Power Company
J. Keppler, RO:HQ			Monticello - Docket No. 50-263
RO:HQ (4)		DATE	
Licensing (4)			
DB Central Files			
TO (Name and unit)		INITIALS	REMARKS
Local PDR			
PDR			
NSIC		DATE	
DTIE			
OGC Beth. P-506A			
TO (Name and unit)		INITIALS	REMARKS
Regional Offices			
		DATE	
FROM (Name and unit)		REMARKS	
W. E. Vetter		Attached is a copy of licensee's adequate reply dated	
RO:III		January 19, 1973, to Bulletin No. 72-3.	
PHONE NO.	DATE		
	2-12-73		

USE OTHER SIDE FOR ADDITIONAL REMARKS

GPO : 1971 O - 445-469



NORTHERN STATES POWER COMPANY

MINNEAPOLIS, MINNESOTA 55401

January 19, 1973

Mr Boyce H Grier
Regional Director
Directorate of Regulatory Operations
Region III, 799 Roosevelt Road
Glen Ellyn, Illinois 60137

Dear Mr Grier:

MONTICELLO NUCLEAR GENERATING PLANT
Docket No. 50-263 License No. DPR-22

Response to Regulatory Operations Bulletin No. 72-3
"Limitorque Valve Operator Failures"

As requested in Directorate of Regulatory Operations Bulletin No. 72-3, transmitted by your letter of December 6, 1972 to Mr Leo J Wachter, it has been determined that no valve operators of the make, model and vintage described in the Bulletin are installed or scheduled to be installed at the Monticello Nuclear Generating Plant.

We have found that there are no limitorque valve operators of unit size SMB-000 installed at Monticello. There are ten unit size SMB-00 operators presently installed as indicated on the attached list. These were all shipped prior to the time of manufacture of the specific production group identified in Bulletin 72-3.

Yours very truly,

A handwritten signature in cursive script, appearing to read "L J Wachter".

L J Wachter, Vice President
Power Production & System Operation

LJW/ma

Attachment

JAN 26 1973

Handwritten initials, possibly "RW", in the bottom right corner of the page.

MONTICELLO NUCLEAR GENERATING PLANT

Valve Number	Limitorque Operator Number	System	Shipping Date
MD 2026	SMB-00	RHR	11/22/68
MD 2027		RHR	11/22/68
MD 2028		RCIC	12/17/68
MD 2106		RCIC	11/17/68
MD 2107		RCIC	11/17/68
MD 2398		Reactor Water Cleanup	12/17/68
MD 2400		Reactor Water Cleanup	11/22/68
MD 2401		Reactor Water Cleanup	11/22/68
MD 2404		Reactor Water Cleanup	12/17/68
MD 2405		Reactor Water Cleanup	12/17/68