

AEC DISTRIBUTION FOR PART 50 DOCKET MATERIAL
(TEMPORARY FORM)

CONTROL NO: **3890**

FILE: **A/O**

FROM: Northern States Power Company Monticello, Minnesota 55362 C. E. Larson			DATE OF DOC 5-1-74	DATE REC'D 5-2-74	LTR	MEMO	RPT	OTHER Facsimile
TO: J. G. Keppler			ORIG NONE	CC	OTHER	SENT AEC PDR X SENT LOCAL PDR X		
CLASS	UNCLASS XXX	PROP INFO	INPUT	NO CYS REC'D 1		DOCKET NO: 50-263		

DESCRIPTION:
Facsimile reporting abnormal occurrence on
4-30-74, regarding excessive leakage through
valve HPCI-9.....

ENCLOSURES:

DO NOT REMOVE

PLANT NAME: Monticello

FOR ACTION/INFORMATION **5-2-74 GC**

BUTLER(L)	SCHWENCER(L)	<input checked="" type="checkbox"/> ZIEMANN(L)	REGAN(E)
W/ Copies	W/ Copies	W/ 7Copies	W/ Copies
CLARK(L)	STOLZ(L)	DICKER(E)	
W/ Copies	W/ Copies	W/ Copies	W/ Copies
PARR(L)	VASSALLO(L)	KNIGHTON(E)	
W/ Copies	W/ Copies	W/ Copies	W/ Copies
KNIEL(L)	PURPLE (L)	YOUNGBLOOD(E)	
W/ Copies	W/ Copies	W/ Copies	W/ Copies

INTERNAL DISTRIBUTION

<input checked="" type="checkbox"/> <u>REG FILE</u>	<input checked="" type="checkbox"/> <u>TECH REVIEW</u>	DENTON	<u>LIC ASST</u>	<u>A/T IND</u>
<input checked="" type="checkbox"/> AEC PDR	<input checked="" type="checkbox"/> HENDRIE	GRIMES		BRAITMAN
<input checked="" type="checkbox"/> GGC, ROOM P-506A	<input checked="" type="checkbox"/> SCHROEDER	GAMMILL	<input checked="" type="checkbox"/> DIGGS (L)	SALTZMAN
<input checked="" type="checkbox"/> MUNTZING/STAFF	<input checked="" type="checkbox"/> MACCARY	KASTNER	GEARIN (L)	B. HURT
<input checked="" type="checkbox"/> CASE	<input checked="" type="checkbox"/> KNIGHT	BALLARD	GOULBOURNE (L)	<u>PLANS</u>
GIAMBUSO	<input checked="" type="checkbox"/> PAWLICKI	SPANGLER	LEE (L)	MCDONALD
BOYD	<input checked="" type="checkbox"/> SHAO		MAIGRET (L)	DUBE w/Input
MOORE (L)(EWR)	<input checked="" type="checkbox"/> STELLO	<u>ENVIRO</u>	REED (E)	<u>INFO</u>
DEYOUNG(L)(PWR)	<input checked="" type="checkbox"/> HOUSTON	MULLER	SERVICE (L)	C. MILES
SKOVHOLT (L)	<input checked="" type="checkbox"/> NOVAK	DICKER	SHEPPARD (L)	<input checked="" type="checkbox"/> B. KING (E/W-358)
<input checked="" type="checkbox"/> COLLIER(L)	<input checked="" type="checkbox"/> ROSS	KNIGHTON	SLATER (E)	<input checked="" type="checkbox"/> KLECKER
P. COLLINS	<input checked="" type="checkbox"/> IPPOLITO	YOUNGBLOOD	SMITH (L)	<input checked="" type="checkbox"/> EISENHUT
DENISE	<input checked="" type="checkbox"/> TEDESCO	REGAN	TEETS (L)	
<input checked="" type="checkbox"/> REG OPR	<input checked="" type="checkbox"/> LONG	PROJECT LDR	WADE (E)	
<input checked="" type="checkbox"/> FILE & REGION(3)	<input checked="" type="checkbox"/> LAINAS		WILLIAMS (E)	
<input checked="" type="checkbox"/> MORRIS	<input checked="" type="checkbox"/> BENAROYA	<u>HARLESS</u>	WILSON (L)	
<input checked="" type="checkbox"/> STEELE	<input checked="" type="checkbox"/> VOLLMER			

EXTERNAL DISTRIBUTION

<input checked="" type="checkbox"/> 1 - LOCAL PDR <u>Minneapolis, Minn.</u>	(1)(2)(10)-NATIONAL LAB'S	1-PDR-SAN/LA/NY
<input checked="" type="checkbox"/> 1 - TIC (ABERNATHY)	1-ASLBP(E/W Bldg, Rm 529)	1-GERALD LELLOUCHE
<input checked="" type="checkbox"/> 1 - NSIC(BUCHANAN)	1-W. PENNINGTON, Rm E-201 GT	BROOKHAVEN NAT. LAB
1 - ASLB	1-CONSULTANT'S	1-ACMED(Ruth Gussman)
1 - P. R. DAVIS (AEROJET NUCLEAR)	NEWMARK/BLUME/AGBABIAN	RM-B-127, GT.
<input checked="" type="checkbox"/> 16 - CYS ACRS XXXXXXXX SENT TO LIC. ASST.	1-GERALD ULRIKSON...ORNL	1-RD..MULLER..F-309 GT
5-2-74 Diggs	1-B & M SWINEBROAD, Rm E-201 GT	

NORTHERN STATES POWER COMPANY

Monticello, Minnesota 55362

May 1, 1974

Mr. J. G. Keppler, Regional Director
Directorate of Regulatory Operations
Region III
799 Roosevelt Road
Glen Ellyn, Illinois 61073



Dear Mr. Keppler:

MONTICELLO NUCLEAR GENERATING PLANT
Docket No. 50-263 License No. DPR-22

Excessive Leakage Through HPCI-9

On April 30, 1974, the outboard isolation valve on the HPCI turbine exhaust, HPCI-9, which is a swing check, was found to have leakage of approximately 65.6 SCFH which is in excess of that allowed by the Technical Specifications.

An investigation into the cause of the excess leakage is being conducted.

Yours very truly,

C. E. Larson
C. E. Larson
Plant Manager

CEL/nmm

cc: J P O'Leary, Directorate of Licensing
G Charnoff
Minnesota Pollution Control Agency
Attn: E A Pryzina
File

Copies sent by telecopier to Keppler and O'Leary

