

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 7906280136 DOC. DATE: 79/06/20 NOTARIZED: NO DOCKET #
 FACIL: 50-263 Monticello Nuclear Generating Plant, Northern States 05000263
 AUTH. NAME AUTHOR AFFILIATION
 HALL, R.E. Brookhaven National Laboratory
 RECIP. NAME RECIPIENT AFFILIATION
 FERGUSON, R.L. Plant Systems Branch

SUBJECT: Discusses exception to safety evaluation. Submits review of fire protection plan.

DISTRIBUTION CODE: A006S COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 3
 TITLE: FIRE PROTECTION INFORMATION (AFTER ISSUANCE OF OP. LIC.)


NOTES: _____

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
ACTION:	05 BC <u>ORB #3</u>	4 4		
INTERNAL:	<u>01 REG FILE</u>	1 1	02 NRC PDR	1 1
	09 I&E	2 2	11 TA/EDO	1 1
	12 AUXIL SYS BR	2 2	14 PLANT SYS BR	5 5
	19 WAMBACH	1 1	20 MURANAKA, R	1 1
	21 AD SYS/PROJ	1 1	OELD	1 0
EXTERNAL:	03 LPDR	1 1	04 NSIC	1 1
	22 ACKS	16 16		

JUL 2 1979

TRC
25/10

TOTAL NUMBER OF COPIES REQUIRED: LTTR 38 ENCL 37



BROOKHAVEN NATIONAL LABORATORY
ASSOCIATED UNIVERSITIES, INC.

Upton, New York 11973

(516) 345- 2362

Department of Nuclear Energy

June 20, 1979

Division of Operating Reactors
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

JUL 2 1979

Attention: Mr. Robert L. Ferguson
Plant Systems Branch

Dear Bob:

Subject: Fire Protection in Operating Nuclear Power Stations
Monticello Safety Evaluation Report Review

The Safety Evaluation Report, as developed jointly by the NRC staff and Brookhaven National Laboratory, (BNL), adequately reflects the concerns and recommendations of the consultants. Throughout the reevaluation of Monticello there has been general agreement between the NRC staff and the BNL consultants. Based on present data, the proposed fire protection, as set forth in the SER, will give reasonable assurance that the health and safety of the public is not endangered. The following exception represents a differing engineering point of view that should be evaluated by the NRC staff.

Valve Supervision

Electrical valve supervision should be provided on all valves controlling fire water systems and sectionalizing valves. The present proposal of administrative controls or locks is unacceptable. See letter dated July 13, 1977 to Mr. R.L. Ferguson from Mr. R.E. Hall.

The preceding statements are based on a detailed reevaluation of the fire protection program as implemented by the Northern States Power Company at the Monticello Nuclear Power Station. The analysis covered a review of the fire prevention, detection and suppression capabilities of the plant as interfaced with the nuclear systems requirements. This was accomplished by utilizing a review team concept with members from Brookhaven National Laboratory (BNL) and the Nuclear Regulatory Commission Division of Operating Reactors staff.

The fire protection evaluation for the Monticello Plant is based on an analysis of documents submitted by the Northern States Power Company to the Nuclear Regulatory Commission and a site visit. The site visit was conducted by Mr. E. Sylvester, V. Panciera, and C. Heit of the NRC; Mr. Ingemar Asp of Gage-Babcock & Associates, Inc. under contract to Brookhaven National Laboratory;

7906280136 Aug 5 1/1 F

R.L. Ferguson

-2-


June 20, 1979

and Mr. J. Townley, consultant to BNL. Mr. Townley was under contract to BNL to review the manual fire fighting capabilities of the station along with administrative controls.

The Monticello review has been conducted under the direction of Mr. E.A. MacDougall and myself of Reactor Engineering Analysis Group at BNL.

We have reviewed the analyses submitted by the licensee and have visited the facility to examine the relationship of safety-related components, systems and structures with both combustibles and the associated fire detection and suppression systems. Our review has been limited to the aspects of fire protection related to the protection of the public from the standpoint of radiological health and safety. We have not considered aspects of fire protection associated with life safety of onsite personnel and with property protection, unless they impact the health and safety of the public due to the release of radioactive material. The proposed modifications represent a significant increase in the level of protection against serious fire associated hazards.

Sincerely yours,

A handwritten signature in black ink, appearing to read "Robert E. Hall". The signature is fluid and cursive, with the first name "Robert" and last name "Hall" clearly distinguishable.

Robert E. Hall, Group Leader
Reactor Engineering Analysis

REH:EAM:sd

DISTRIBUTION

M. Antonetti	1
I. Asp	1
V. Benaroya	1
E. Blackwood	1
W. Butler	1
R. Cerbone	1
D. Eisenhut	1
R. Feit	1
R. Ferguson	5
R. Hall	1
S. Hanauer	1
E. Imbro	1
W. Kato	1
J. Klevan	1
G. Lainas	1
C. Long	1
E. MacDougall	1
J. Riopelle	1
V. Stello	1
T. Telford	1
H. Todosow	2
J. Townley	1
NRC - Division of Technical Information and Control	2