

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8011130411 DOC. DATE: 80/11/06 NOTARIZED: NO DOCKET #
 FACIL: 50-263 Monticello Nuclear Generating Plant, Northern States 05000263
 AUTH. NAME AUTHOR AFFILIATION
 MAYER, L.O. Northern States Power Co.
 RECIP. NAME RECIPIENT AFFILIATION
 Office of Nuclear Reactor Regulation, Director

SUBJECT: Responds to Eisenhower 801001 request to submit specific information re equipment environment qualification tests to be conducted within two years. No specific plans to conduct unique tests exist at this time.

DISTRIBUTION CODE: A001S COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 1
 TITLE: General Distribution for after Issuance of Operating License

NOTES:

	RECIPIENT ID CODE/NAME		COPIES		RECIPIENT ID CODE/NAME		COPIES	
			LTTR	ENCL			LTTR	ENCL
ACTION:	IPPOLITO, T.	04	13	13				
INTERNAL:	D/DIR, HUM	FAC08	1		I&E	06	2	
	NRC PDR	02	1		OELD	11	1	
	OR ASSESS BR	10	1		REG FILE	01	1	
EXTERNAL:	ACRS	09	16	16	LPDR	03	1	
	NSIC	05	1	1				

NOV 17 1980

TOTAL NUMBER OF COPIES REQUIRED: LTTR 38 ENCL 0

NSP

RECEIVED DISTRIBUTION
SERVICES UNIT

NORTHERN STATES POWER COMPANY

1980 NOV 13 AM 9 00

MINNEAPOLIS, MINNESOTA 55401

US NRC
DISTRIBUTION SERVICES
November 6, 1980

Director of Nuclear Reactor Regulation
U S Nuclear Regulatory Commission
Washington, DC 20555

MONTICELLO NUCLEAR GENERATING PLANT
Docket No. 50-263 License No. DPR-22

Schedule for Environmental Qualification Tests

In a letter dated October 1, 1980 from D G Eisenhut, Director, Division of Licensing, USNRC, we were requested to submit specific information related to equipment environmental qualification tests to be conducted within the next two years.

The purpose of this letter is to inform you that we have no specific plans at this time to conduct unique qualification tests for equipment installed at the Monticello plant. It is our intention to replace inadequately qualified equipment with new equipment qualified by the vendor or rely on tests being planned by other organizations.

Please contact us if you have any questions related to this matter.

L. O. Mayer

L O Mayer, PE
Manager of Nuclear Support Services

LOM/DMM/jh

cc J G Keppler
G Charnoff
NRC Resident Inspector

*Acc'd
S/p*

8011130

411

P