

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:8810140207 DOC.DATE: 88/10/07 NOTARIZED: NO DOCKET #
 FACIL:50-263 Monticello Nuclear Generating Plant, Northern States 05000263
 AUTH.NAME AUTHOR AFFILIATION
 MUSOLF,D. Northern States Power Co.
 RECIP.NAME RECIPIENT AFFILIATION
 Office of Nuclear Reactor Regulation, Director (Post 870411)

SUBJECT: Responds to confirmatory action ltr re effect of dc power supply failure on ECCS performance.

DISTRIBUTION CODE: A001D COPIES RECEIVED:LTR 1 ENCL 0 SIZE: 1
 TITLE: OR Submittal: General Distribution

NOTES:

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME		LTTR	ENCL		ID CODE/NAME		LTTR	ENCL
	PD3-1 LA		1	0		PD3-1 PD		5	5
	STEFANO,J		1	1					
INTERNAL:	ARM/DAF/LFMB		1	0		NRR/DEST/ADS 7E		1	1
	NRR/DEST/CEB 8H		1	1		NRR/DEST/ESB 8D		1	1
	NRR/DEST/MTB 9H		1	1		NRR/DEST/RSB 8E		1	1
	NRR/DOEA/TSB 11		1	1		NRR/PMAS/ILRB12		1	1
	NUDOCS-ABSTRACT		1	1		OGC/HDS1		1	0
	<u>REG FILE</u> 01		1	1		RES/DSIR/EIB		1	1
EXTERNAL:	LPDR		1	1		NRC PDR		1	1
	NSIC		1	1					

TOTAL NUMBER OF COPIES REQUIRED: LTTR 22 ENCL 19

M/A 4

R
I
D
S
/
A
D
D
S

R
I
D
S
/
A
D
D
S



October 7, 1988



Northern States Power Company

414 Nicollet Mall
Minneapolis, Minnesota 55401-1927
Telephone (612) 330-5500

Director of Nuclear Reactor Regulation
U S Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

MONTICELLO NUCLEAR GENERATING PLANT
Docket No. ~~NER~~-263 License No. DPR-22

Response to Confirmatory Action Letter
Effect of a DC Power Supply Failure on ECCS Performance


- References (1): Letter dated October 4, 1988 from A Bert Davis (NRC) to C E Larson (NSP), Confirmatory Action Letter
- (2): Letter dated October 4, 1988 from David Musolf (NSP) to Director of NRR, "Effect of a DC Supply Failure on ECCS Performance"

On October 4, 1988 we received a Confirmatory Action Letter related to the effect of a DC Power Supply Failure on ECCS Performance (Reference 1). Northern States Power Company will comply with all of the actions described in the October 4, 1988 Confirmatory Action Letter.

Operator training described in item (1) of the Confirmatory Action Letter will be conducted in two ways. The operators will read the new procedure and a "hands on" training session will be conducted on manually operating the deenergized breakers. This training will be completed by November 1, 1988. Other corrective actions are described in Reference 2.

Information required by item (3) to be submitted to the Office of NRR and the NRC Region III office was provided in our letter dated October 4, 1988 (Reference 2).

Please contact us if you have any questions related to our resolution of this matter.


David Musolf
Manager Nuclear Support Services

c: Regional Administrator-III, NRC
NRR Project Manager, NRC
Sr Resident Inspector, NRC
G Charnoff

8810140207 881007
PDR ADCK 05000263
P FDC

1001
1/2