

NRC DISTRIBUTION FOR POINT 50 DOCKET MATERIAL

50-263

FILE NUMBER

TO:

Mr. Victor Stello

FROM:

Northern States Power Company
Minneapolis, Minnesota
L. O. Mayer

DATE OF DOCUMENT

5/5/77

DATE RECEIVED

5/7/77

☒ LETTER☒ NOTORIZED

PROP

INPUT FORM

NUMBER OF COPIES RECEIVED

☒ ORIGINAL☒ UNCLASSIFIED☐ COPY

3 SIGNED

DESCRIPTION

Ltr. trans the following:

DO NOT REMOVE

(1-P)

ENCLOSURE

Amdt. to OL/change to Appendix A tech
specs...notorized 5/5/77...concerns minimum
qualifications for Radiation Protection
seppervisor....

(4-P)

PLANT NAME:

Monticello

ACKNOWLEDGED

RJL

(40 cys encl rec'd)

SAFETY

FOR ACTION/INFORMATION

ENVIRO

ASSIGNED AD:		ASSIGNED AD:
BRANCH CHIEF:	Ziemann (5)	BRANCH CHIEF:
PROJECT MANAGER:	Snider	PROJECT MANAGER:
LIC. ASST. :	Diggs	LIC. ASST. :

INTERNAL DISTRIBUTION

REG FILE	SYSTEMS SAFETY	PLANT SYSTEMS	SITE SAFETY &
NRC PDR	HEINEMAN	TEDESCO	ENVIRO ANALYSIS
I & E (2)	SCHROEDER	BENAROYA	DENTON & HULLER
OELD		LAINAS	
GOSSICK & STAFF	ENGINEERING	IPPOLITO	ENVIRO TECH.
MIPC	MACARRY	KIRKWOOD	ERNST
CASE	BOSNAK		BALLARD
HANAUER	SINWEL	OPERATING REACTORS	SPANGLER
HARLESS	PAWLICKI	STELLO	
			SITE TECH.
PROJECT MANAGEMENT	REACTOR SAFETY	OPERATING TECH.	GAMMILL
BOYD	ROSS	EISENHUT	STAPP
P. COLLINS	NOVAK	SHAO	HULMAN
HOUSTON	ROSZTOCZY	BAER	
PETERSON	CHECK	BUTLER	SITE ANALYSIS
MELTZ		GRIMES	VOLLMER
HELTENES	AT & I		BUNCH
SKOVHOLT	SALTZMAN		J. COLLINS
	RUTBERG		KREGER

EXTERNAL DISTRIBUTION

IPDR: Minneapolis Mn	NAT. LAB.	BROOKHAVEN NAT. LAB.	CONTROL NUMBER
TIC:	REG. V. IE	ULRIKSON (ORNL)	
NSIC:	IA PDR		
ASLB:	CONSULTANTS:		
ACRS/6 CYS HOLDING/SENT	As CAT B		

771290226




NORTHERN STATES POWER COMPANY

MINNEAPOLIS, MINNESOTA 55401

May 5, 1977

Regulatory Docket File



Mr Victor Stello, Director
Division of Operating Reactors
U S Nuclear Regulatory Commission
Washington, DC 20555

Dear Mr Stello:

MONTICELLO NUCLEAR GENERATING PLANT
Docket No. 50-263 License No. DPR-22

License Amendment Request Dated May 5, 1977

Attached are three signed originals and 37 conformed copies of a request for a change of Technical Specifications, Appendix A of Operating License DPR-22. This License Amendment Request has been reviewed by the Monticello Operations and Safety Audit Committees and contains no unreviewed safety questions.

This is in response to the March 15, 1977 NRC letter from D L Ziemann which requested that we propose a Technical Specification stating the minimum qualifications for the Radiation Protection supervisor.

Yours very truly,

L O Mayer, PE
Manager of Nuclear Support Services

LOM/ak

cc: J G Keppler
G Charnoff
MPCA
Attn: J W Ferman
MECCA
Attn: H J Vogel
S J Gadler

Attachments

UNITED STATES NUCLEAR REGULATORY COMMISSION

NORTHERN STATES POWER COMPANY

MONTICELLO NUCLEAR GENERATING PLANT

Docket No. 50-263

REQUEST FOR AMENDMENT TO
OPERATING LICENSE NO. DPR-22

(License Amendment Request Dated May 5, 1977)

Northern States Power Company, a Minnesota corporation, requests authorization for changes to the Technical Specifications as shown on the attachments labeled Exhibit A and Exhibit B. Exhibit A describes the proposed changes along with reasons for the change. Exhibit B is a set of Technical Specification pages incorporating the proposed changes.

This request contains no restricted or other defense information.

NORTHERN STATES POWER COMPANY

By

L. J. Wachter

L J Wachter

Vice President, Power Production &
System Operation

On this 5th day of May, 1977, before me a notary public in and for said County, personally appeared L J Wachter, Vice President, Power Production & System Operation, and first being duly sworn acknowledged that he is authorized to execute this document in behalf of Northern States Power Company, that he knows the contents thereof and that to the best of his knowledge, information and belief, the statements made in it are true and that it is not interposed for delay.

Denise E. Halvorson




EXHIBIT A

MONTICELLO NUCLEAR GENERATING PLANT
DOCKET NO. 50-263

LICENSE AMENDMENT REQUEST DATED MAY 5, 1977

PROPOSED CHANGES TO THE TECHNICAL SPECIFICATIONS
APPENDIX A OF OPERATING
LICENSE DPR-22

Pursuant to 10CFR50.59, the holders of the above mentioned license hereby propose the following change to Appendix A Technical Specifications:

Proposed Change

On Page 192, TS 6.1.D, between the existing first and second sentences, insert the following: "The Radiation Protection supervisor shall meet the minimum qualifications in Regulatory Guide 1.8, September, 1975." Please note the other change to Page 192, contained in Exhibit B attached, that was submitted to the NRC on January 31, 1977 and is still undergoing review.

Reason for Change

This is in response to the March 15, 1977 NRC letter from D L Ziemann which requested that we propose a Technical Specification stating the minimum qualifications for the Radiation Protection supervisor.

Safety Evaluation

The minimum qualifications stated in Regulatory Guide 1.8, September, 1975, exceed those required by ANSI N18.1-1971, the latter being referenced in the current technical specification.

EXHIBIT B

DPR-22 LICENSE AMENDMENT REQUEST DATED MAY 5, 1977

This exhibit consists of a page containing the proposed change to the Appendix A Technical Specifications:

6.0 ADMINISTRATIVE CONTROLS

6.1 Organization

- A. The Plant Manager has the overall full-time onsite responsibility for safe operation of the facility. During periods when the Plant Manager is unavailable, he may delegate this responsibility to other qualified supervisory personnel.
- B. The Northern States Power corporate organizational structure relating to the operation of this plant is shown in Figure 6.1.1.
- C. The minimum functional organization for operation of the plant shall be as shown in Figure 6.1.2 and:
 - 1. Each on duty shift shall be composed of at least the minimum shift crew composition shown in Table 6.1.1.
 - 2. At least one licensed operator shall be in the control room when fuel is in the reactor.
 - 3. At least two licensed operators shall be present in the control room during cold startup, scheduled reactor shutdown, and during recovery from reactor trips.
 - 4. An individual qualified in radiation protection procedures shall be on site when fuel is in the reactor.
 - 5. All alterations of the reactor core shall be directly supervised by a licensed Senior Reactor Operator or Senior Reactor Operator Limited to Fuel Handling who has no other concurrent responsibilities during this operation.
 - 6. A fire brigade consisting of three members shall be maintained on site during the day shift, during refueling outages, and at all other times when site activities such as welding and burning present a significant fire hazard. This fire brigade is in addition to the minimum shift crew composition specified in Table 6.1.1 and notes thereto. At all other times three members of the normal shift organization may constitute the fire brigade.
- D. Minimum qualifications, training, replacement training and retraining of plant personnel shall be in accordance with that stated in the "Standard for Selection and Training of Personnel for Nuclear Power Plants" ANSI N18.1-1971. The Radiation Protection supervisor shall meet the minimum qualifications in Regulatory Guide 1.8, September, 1975. The minimum frequency of the retraining program shall be every two years. The training program shall be under the direction of a designated member of the plant staff.