

Docket No. 50-263

NOV 04 1975

Northern States Power Company
ATTN: Mr. L. O. Mayer
Director of Nuclear Support
Services
414 Nicollet Mall
Minneapolis, Minnesota 55401

Gentlemen:

RE: MONTICELLO NUCLEAR GENERATING PLANT

Based on our review of the information submitted on your docket regarding the Mark I containment reevaluation program (up to and including the Mark I Containment Status Report dated July 31, 1975, submitted by the General Electric Company), we have identified additional information that is required to continue our review. The information required is listed in the enclosure and pertains to the functional operability of piping and components when subjected to (1) pool swell loads associated with a loss of coolant accident, and (2) loads from operation of the primary system pressure relief valves. The items listed in the enclosure should be addressed during the Long Term Program proposed by the Mark I Owners Group.

We anticipate that further information will be required based on our review of the Short Term Program report.

Please contact us if you desire clarification of the information required.

This request for generic information was approved by GAO under a blanket clearance number E-180225 (FC072); this clearance expires July 31, 1977.

Sincerely,
Original Signed by:
Dennis L. Ziemann

Dennis L. Ziemann, Chief
Operating Reactors Branch #2
Division of Reactor Licensing

Enclosure:
Request for Additional
Information

OFFICE >	RL:ORB #2	RL:ORB #2				
SURNAME >	BCBuckley:ah	DLZiemann				
DATE >	10/30/75	10/4/75				

cc w/enclosure:

Arthur Renquist, Esquire
Vice President - Law
Northern States Power Company
414 Nicollet Mall
Minneapolis, Minnesota 55401

Gerald Charnoff
Shaw, Pittman, Potts &
Trowbridge
910 - 17th Street, N. W.
Washington, D. C. 20006

Howard J. Vogel, Esquire
Legal Counsel
2750 Dean Parkway
Minneapolis, Minnesota 55416

Steve Gadler
2120 Carter Avenue
St. Paul, Minnesota 55108

Mr. Daniel L. Ficker
Assistant City Attorney
638 City Hall
St. Paul, Minnesota 55102

Mr. Kenneth Dzigan
Environmental Planning
Consultant
St. Paul City Planning
421 Wabasha Street
St. Paul, Minnesota 55102

Sandra S. Gardebring
Special Assistant Attorney General
Counsel for Minnesota Pollution
Control Agency
1935 W. County Road B2
Roseville, Minnesota 55113

Anthony Z. Roisman, Esquire
Berlin, Roisman and Kessler
1712 N Street, N. W.
Washington, D. C. 20036

The Environmental Conservation
Library
Minneapolis Public Library
300 Nicollet Mall
Minneapolis, Minnesota 55401

ENCLOSURE

REQUEST FOR ADDITIONAL INFORMATION

1. Provide a list of piping and mechanical components which could be subjected to suppression pool hydrodynamic loadings or loadings from operation of the primary system pressure relief valves, including detailed drawings and functional description of such piping and components.
2. Provide a description of methods and procedures used to define the pool dynamic loads and relief valve actuation loads acting on the listed piping and components.
3. Provide a description of methods and procedures, either by analysis or by testing, being used to ensure design adequacy of the listed piping and components under pool dynamic loads or relief valve actuation loads.
4. Provide a description regarding how the pool dynamic loads or valve actuation loads being concurrently considered and combined with other operation or accident loads acting on the listed piping and components.
5. Identify design limits used for the listed piping and components under pool dynamic or relief valve actuation loads. If analysis or testing has been done, a summary of analysis or testing results and their comparison with design limits should be provided. If analysis or testing has not yet been done, a description of the future program to perform such testing or analysis should be provided.