

**COMBUSTION ENGINEERING, INC.**  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

CHARGE NO. \_\_\_\_\_

NUMBER 5-212-P

A 246

SHEET 74 OF 90DATE 4-22-68 BY CRITCHCHECK DATE 4-22-68 BY HANNA

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF OUTLET NOZZLE - VESSEL SUPPORT

5. DETAILED ANALYSIS:1. STRESSES:2. PEAK STRESSES:

LOCATION 9A

TRANSVERSE	TENSILE STRESS		TORSIONAL STRESS		THERMAL AND AIR REACTION STRESS		SEISMIC AND REACTION STRESS		DYNAMIC STRESS		STATIC WEIGHT STRESS	
	OT	OP	OT	OP	OT	OP	OT	OP	OT	OP	OT	OP
400 MC	-3.18	49.24	-1.88	-13.44	-15.77	-4.64	-1.48	-0.05	-2.56	-1.32	-0.43	0
425	-3.51	54.42	-2.08	-12.59	-15.91	-4.93	-1.57					
435	-3.64	56.46	-2.16	-12.63	-15.96	-5.04	-1.61					
447	-3.90	58.92	-2.25	-14.19	-16.37	-5.18	-1.65					
500	-3.90	58.92	-2.25	-6.50	-7.84	-5.18	-1.65					
400	-3.18	49.24	-1.88	-13.44	-15.44	-4.64	-1.48		2.56	1.32	0.43	
425	-3.51	54.42	-2.08	-13.58	-15.91	-4.93	-1.57					
435	-3.64	56.46	-2.16	-13.62	-15.96	-5.04	-1.61					
447	-3.90	58.92	-2.25	-14.14	-16.36	-5.18	-1.65					
500	-3.90	58.92	-2.25	-6.50	-7.84	-5.18	-1.65					
NO ZERO STRESS	-3.80	58.92	-2.25	0.17	-0.08	-5.18	-1.65		0	0	0	
400 MC	-0.53	8.25	-0.31	12.24	14.24	-0.54	-0.17	-0.01	-2.56	-1.32	-0.43	
425				12.10	14.15	-0.26	-0.08	0				
435				12.04	14.09	-0.14	-0.04					
447				12.39	14.34	0	0					
500				5.57	6.64	0	0					
400				12.24	14.24	-0.54	-0.17	-0.01	2.56	1.32	0.43	
425				12.10	14.15	-0.26	-0.08	0				
435				12.04	14.09	-0.14	-0.04					
447				12.39	14.34	0	0					
500				5.57	6.64	0	0					

a. Interior

b. Location

## COMBUSTION ENGINEERING, INC.

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

CHARGE NO. \_\_\_\_\_

NUMBER 5-212-P

A247

SHEET 75 OF 80

DATE 4-22-68 BY CHERRYDESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
DE OUTLET NOZZLE - VESSEL SUPPORTSCHECK DATE 4-22-68 BY HEUER5. DETAILED ANALYSIS:C. STRESSES:2. PEAK STRESSES:

LOCATION 9A

TIME/UNIT	PRESSURE STRESS		THERMAL STRESS		THERMAL AND REACTION STRESS		STATIC REACTION STRESS		STATIC MEMBER STRESS	
	$\sigma_x$	$\sigma_y$	$\sigma_x$	$\sigma_y$	$\sigma_x$	$\sigma_y$	$\sigma_x$	$\sigma_y$	$\sigma_x$	$\sigma_y$
10 min	-2.50	58.92	-1.78	-0.49	-5.18	-1.65	0	0	1.62	0.55
15			-2.94	-0.66						
20			-4.25	-0.77						
25			-4.41	-0.36						
30			-4.06	0.21						
Full Load			-4.88	4.51						
10 min			1.57	6.19						
15			2.68	6.24						
20			3.59	6.16						
25			4.03	5.86						
30			3.52	5.08						
100 sec	-3.62	56.04	-3.22	1.26						
225	-3.84	59.58	-4.15	-1.68						
40 sec	-3.92	60.76	-2.32	-5.07						
100	-3.82	59.18	-2.26	-6.30						
240	-3.62	56.04	-2.14	-2.60						
3.5 min	-3.97	61.54	-2.35	-0.67						
11	-3.63	56.30	-2.15	4.26						
15.5	-3.80	58.92	-2.25	4.57						

## COMBUSTION ENGINEERING, INC.

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

CHARGE NO. \_\_\_\_\_

NUMBER 5-212-P

1248

SHEET 76 OF 80

DATE 4-22-68 BY COCKRELL

CHECK DATE 4-22-69 BY HENNER

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF OUTLET NOZZLE - VESSEL SUPPORTS5. DETAILED ANALYSIS:a. STRESSES:2. PEAK STRESSES

LOCATION 9A

TRANSIENT	PRESSURE STRESS		THERMAL STRESS		THERMAL IMPULSED AND RESONANT STRESS		SERVICING PUMP ACTION STRESS		STATIC AROUND STRESS	
	$\sigma_x$	$\sigma_y$	$\sigma_x$	$\sigma_y$	$\sigma_x$	$\sigma_y$	$\sigma_x$	$\sigma_y$	$\sigma_x$	$\sigma_y$
h 10 sec	-3.75	58.14	-2.22	-3.59	0.87	-5.18	-1.65	-0.05	0	0
90	-3.28	50.80	-1.94	1.94	6.41	-5.18	-1.65	-0.05	0	0
i 200 min	-5.28	81.84	-3.12	0	0	0	0	0	0	0
100	-2.11	32.73	-1.25	-13.32	-15.46	-3.48	-1.11	-0.03	0	0
j 55.60	-4.22	65.47	-2.50	0.11	-0.06	-3.48	-1.11	-0.03	0	0
30 hrs	-0.53	8.25	-0.31	13.51	14.27	0	0	0	0	0
k ~	-3.97	61.54	-2.35	-4.82	-0.36	-5.18	-1.65	-0.05	0	0
~	-3.63	56.30	-2.15	-0.51	-4.05					
l 12 sec	-3.90	58.92	-2.25	9.32	13.78					
18.5	-3.80	59.92	-2.25	-0.15	4.26					
m 12 sec	-4.65	72.02	-2.75	-10.05	-5.59					
26	-3.38	54.38	-2.00	-13.13	-8.67					
44	-2.49	38.63	-1.47	1.02	5.49					
n 35 sec	-0.51	7.86	-0.30	29.03	33.53					
54	-1.18	18.33	-0.70	53.46	57.95					

**COMBUSTION ENGINEERING, INC.**  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-218-P | A 249

SHEET 77 OF 80

CHARGE NO. \_\_\_\_\_

DATE 4-27-69 BY COCKRILL

DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF OUTLET NOZZLE - VESSEL SUPPORT

CHECK DATE 4-22-69 BY HEILNER

**5. DETAILED ANALYSIS:**

**A. STRESSES:**

**2. PEAK STRESSES:**

Location 9A

TENSILE	Fatigue Longitudinal Stress Intensity Factor			Fatigue and Corrosion Stress			Total Stress			Principal Stresses			Stress Intensity		
	$S_t$	$S_p$	$T_{10}$	$S_t$	$S_p$	$T_{10}$	$S_t$	$S_p$	$T_{10}$	$S_1$	$S_2$	$S_3$	$S_t$	$S_p$	$S_3$
400 HB	-0.38	-0.13	-0.20	-0.28	0.53		-22.86	31.67	-1.88	-0.68	21.68	-22.87	54.55	33.56	-20.99
435							-23.63	36.57	-2.08	-0.68	36.58	-23.64	60.21	38.65	-21.56
455							-23.92	38.52	-2.16	-0.68	38.53	-23.92	62.45	40.69	-21.77
447							-24.73	40.54	-2.25	-0.69	40.54	-24.73	65.28	42.79	-22.48
500							-17.08	49.06	-2.25	-0.69	49.07	-17.09	66.16	51.32	-14.84
400	0.38	0.13	0.20				-16.97	34.56	-1.88	0.59	34.57	-16.98	51.55	36.45	-15.10
435							-17.74	39.46	-2.08	0.59	39.47	-17.74	57.22	41.55	-15.67
455							-18.03	41.42	-2.16	0.58	41.42	-18.03	59.46	43.58	-15.88
447							-18.84	43.43	-2.25	0.58	43.44	-18.84	62.28	45.69	-16.59
500							-11.20	51.95	-2.25	0.58	51.96	-11.20	68.16	54.21	-9.95
No Load	0	0	0	0	0		-7.20	57.73	-2.25	-0.05	57.74	-7.20	64.93	59.99	-4.95
400 HB	-0.38	-0.13	-0.20	0.28	-0.53		10.11	20.94	-0.31	-0.64	20.98	10.08	10.90	21.29	10.39
435							10.27	20.89		-0.64	20.93	10.23	10.70	21.24	10.35
455							10.32	20.87		-0.64	20.91	10.28	10.63	21.22	10.59
447							10.81	21.16		-0.63	21.20	10.77	10.45	21.52	11.09
500							3.99	13.46		-0.63	13.50	3.95	9.56	13.82	4.26
400	0.38	0.13	0.20				16.00	23.83		0.63	23.88	15.95	7.93	24.19	16.26
435							16.15	23.79		0.63	23.84	16.10	7.74	24.15	16.41
455							16.20	23.76		0.63	23.81	16.15	7.66	24.13	16.46
447							16.49	24.05		0.63	24.11	16.44	7.47	24.42	16.95
500							9.87	16.35		0.63	16.41	9.81	4.60	16.73	10.12

b. Cool down

**COMBUSTION ENGINEERING, INC.**  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-212-0 | A250  
SHEET 78 OF 80  
DATE 4-22-68 BY CC/MSL  
CHECK DATE 9-22-69 BY HENDER

CHARGE NO. \_\_\_\_\_  
DESCRIPTION STRUCTURAL AND FATIGUE EVALUATION  
OF OUTLET NOZZLE - VESSEL SUPPORTS

5-Detailed Analysis:

1. STRESSES:

2- PEAK STRESSES:

Location 9A

TENSILE	EXTENDING LOADS			EXTENDING AND COMPRESSIVE STRESS			TOTAL STRESS			PRINCIPAL STRESS			STRESS INTENSITY		
	$\sigma_1$	$\sigma_2$	$\tau_{12}$	$\sigma_1$	$\sigma_2$	$\tau_{12}$	$\sigma_1$	$\sigma_2$	$\tau_{12}$	$\sigma_1$	$\sigma_2$	$\tau_{12}$	$\sigma_1$	$\sigma_2$	$\tau_{12}$
10 mm	0	0	0	-9.15	57.33	-2.25	-0.05	57.33	-9.15	-2.25	-2.25	66.47	59.58	-6.90	
15	0	0	0	-10.31	57.16			57.16	-10.31			67.47	59.41	-8.06	
20	0	0	0	-11.64	57.05			57.05	-11.64			68.66	59.30	-9.36	
25	0	0	0	-11.78	57.45			57.45	-11.78			69.23	59.70	-9.53	
30	0	0	0	-11.43	58.03			58.03	-11.43			69.46	60.28	-9.18	
Full Load	0	0	0	-9.25	62.33			62.33	-9.25			71.98	64.58	-7.00	
10 mm	0	0	0	-5.80	64.01			64.01	-5.80			69.80	66.26	-3.55	
15	0	0	0	-4.69	64.06			64.06	-4.69			68.75	66.31	-2.44	
20	0	0	0	-3.78	63.98			63.98	-3.78			67.75	66.23	-1.53	
25	0	0	0	-3.33	63.68			63.68	-3.33			67.01	65.93	-1.08	
30	0	0	0	-3.84	62.40			62.40	-3.84			66.74	65.15	-1.59	
10 mm	0	0	0	-10.40	56.19	-2.14		56.19	-10.40	-2.14	-2.14	66.59	58.33	-8.26	
15	0	0	0	-13.56	56.80	-2.27		56.80	-13.56	-2.27	-2.27	70.35	59.07	-11.28	
20	0	0	0	-17.03	54.58	-2.32		54.58	-17.03	-2.32	-2.32	71.61	56.90	-14.71	
25	0	0	0	-18.16	51.78	-2.26		51.78	-18.16	-2.26	-2.26	69.94	54.04	-15.90	
30	0	0	0	-14.26	52.34	-2.14		52.34	-14.26	-2.14	-2.14	68.59	54.48	-12.12	
35 mm	0	0	0	-12.66	59.77	-2.35		59.77	-12.66	-2.35	-2.35	72.43	62.12	-10.31	
9 11	0	0	0	-7.40	59.46	-2.15		59.46	-7.40	-2.15	-2.15	66.86	61.61	-5.25	
15.5	0	0	0	-7.27	62.38	-2.25		62.38	-7.27	-2.25	-2.25	69.65	64.63	-5.02	

**Submitted: December 27, 2011**

**COMBUSTION ENGINEERING, INC.**

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

**CHARGE NO**

NUMBER 5-212-P | A251

SHEET 79 OF 80

DATE 4-21-69 BY CHURCH

DESCRIPTION: STRUCTURAL AND FATIGUE EVALUATION  
OF OUTLET NOZZLE - VESSEL SUPPORTS

CHECK DATE 4-27-68 BY HEILNER

### 5. DETAILED ANALYSIS:

E. STRESSES:

## 2- PEAK STRESSES

[illegible]





COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-2M-P | A 253

SHEET 5 OF 10



CHARGE NO. \_\_\_\_\_

DATE 1-11-67 BY C. G. REIL

DESCRIPTION STRUCTURAL ANALYSIS OF INLET & OUTLET NOZZLES CHECK DATE 1-11-67 BY LOU BLE  
VESSEL SUPPORTS UNDER PIPE BREAK LOADS

5. DETAILED ANALYSIS:

a. SYSTEM GEOMETRY:





## COMBUSTION ENGINEERING, INC.

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

CHARGE NO. \_\_\_\_\_

NUMBER 5-24-P

A294


SHEET 6 OF 10DATE 1-11-69 BY Coccardi

CHECK DATE \_\_\_\_\_ BY \_\_\_\_\_

DESCRIPTION STRUCTURAL ANALYSIS OF INLET AND OUTLET  
NOZZLES - VESSEL SUPPORTS UNDER PIPE BREAK LOADS5. DETAILED ANALYSIS:5.1. LOADS ON NOZZLES:

IN THIS SECTION, ANALYSIS WILL BE PERFORMED FOR THE FOLLOWING SEVEN INDEPENDANT REACTOR COOLANT PIPE BREAK ACCIDENT CONDITIONS

CASE		$F_y$	$F_z$	$F_x$	$M_x$	$M_y$	$M_z$
OUTLET	1	1485	-	-	-	-	-
	2	955	-1140	-	-	-	10300
	3	260	380	-800	-	-97100	-37500
INLET	1	1337	-	-	-	-	-
	2	220	-	1473	-	61750	-
	3	-	-	-	-89000	-	-
	4	-	1437	-	-	-	-63700



THE PIPE BREAK LOADS WILL BE COMBINED WITH THE NORMAL OPERATING DEADWEIGHT, INTERNAL PRESSURE, AND THERMAL PIPE REACTIONS. THE THERMAL PIPE REACTIONS ON THE NOZZLE WITH THE PIPE BREAK ARE INSTANTANEOUS RELIEVED AND WILL NOT BE CONSIDERED IN THE EVALUATION OF THAT NOZZLE DURING THE PIPE BREAK ACCIDENT.

THE EFFECT OF THESE LOADS WILL BE EVALUATED FOR THE REINFORCED PORTION OF THE NOZZLE, THE NOZZLE TO SHELL JUNCTURE, AND THE VESSEL SUPPORTS.

FOR THE PIPE BREAK ACCIDENT CONDITIONS, THE RESULTING STRESSES WILL BE LIMITED TO 1.2 TIMES THE CODE ALLOWABLE STRESSES. EACH OF THE ABOVE CASES HAVE BEEN INVESTIGATED TO DETERMINE WHICH GAVE THE HIGHEST STRESSES AT THE LOCATIONS OF INTEREST.

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER S-211-P | A 255  
SHEET 7 OF 10  
DATE 4-11-69 BY LOCKER  
CHECK DATE \_\_\_\_\_ BY \_\_\_\_\_

CHARGE NO. \_\_\_\_\_  
DESCRIPTION STRUCTURAL ANALYSIS OF INLET AND OUTLET  
NOZZLES - VESSEL SUPPORTS UNDER PIPE BREAK LOADS

5- DETAILED ANALYSIS:

b- LOADS ON NOZZLES:

INLET NOZZLE

REINFORCED PORTION OF NOZZLE

THE LOCATIONS OF INTEREST ARE 7 & 8 (SEE SHEET 40 OF S-211-P).  
THE CASES WHICH GAVE THE HIGHEST STRESSES WERE CASE 4 FOR POINTS  
A & C AND CASE 2 FOR POINTS C & D. NOTE THAT THE HIGHEST  
STRESSES OCCURRED ON INLET NOZZLES 2 & 4 BECAUSE THE  
SUPPORT LOADS HELP TO RELIEVE THE STRESSES.

FOR CASE 4

$$\begin{array}{ll} \bar{F}_x = 0 & \bar{M}_x = 0 \\ \bar{F}_y = 1437 & \bar{M}_y = 0 \\ \bar{F}_z = 0 & \bar{M}_z = -107260 \end{array}$$

FOR CASE 2

$$\begin{array}{ll} \bar{F}_x = 0 & \bar{M}_x = 0 \\ \bar{F}_y = 0 & \bar{M}_y = 106401 \\ \bar{F}_z = 1473 & \bar{M}_z = 0 \end{array}$$

VESSEL WALL AT THE NOZZLE TO VESSEL SHELL JUNCTURE

THE LOCATIONS OF INTEREST ARE 9 & 10 (SEE SHEET 43 OF S-211-P).  
THE CASES WHICH GAVE THE HIGHEST STRESSES WERE CASE 4 FOR POINTS  
A & B AND CASE 2 FOR POINTS C & D. THE HIGHEST STRESSES OCCURRED  
ON INLET NOZZLES 2 & 4

FOR CASE 4

$$\begin{array}{ll} \bar{F}_x = 0 & \bar{M}_x = 0 \\ \bar{F}_y = 1437 & \bar{M}_y = 0 \\ \bar{F}_z = 0 & \bar{M}_z = -114984 \end{array}$$

FOR CASE 2

$$\begin{array}{ll} \bar{F}_x = 0 & \bar{M}_x = 0 \\ \bar{F}_y = 0 & \bar{M}_y = 113034 \\ \bar{F}_z = 1473 & \bar{M}_z = 0 \end{array}$$

SUPPORT PADS:

THE LOCATIONS OF INTEREST ARE THE SIDE AND BOTTOM OF THE  
PADS CASES 2 AND 4 GAVE THE HIGHEST FORCES

$$H_{MAX} = -1304^* \quad \text{FOR CASE 2}$$

$$V_{MAX} = 1642^* \quad \text{FOR CASE 4}$$

NOTE THAT THE VESSEL TENDS  
TO LIFT OFF THE SUPPORTS FOR  
CASE NO 4 - INLET NOZ

## COMBUSTION ENGINEERING, INC.

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

CHARGE NO. \_\_\_\_\_

NUMBER S-214-P

A 256

SHEET 8 OF 10

DATE 4-11-69

BY C. M. RELL

CHECK DATE \_\_\_\_\_ BY \_\_\_\_\_

DESCRIPTION: STRUCTURAL ANALYSIS OF INLET AND OUTLET  
NOZZLES - VESSEL SUPPORTS UNDER PIPE BREAK LOADS5. DETAILED ANALYSIS:5.6. LOADS ON NOZZLES:OUTLET NOZZLE:REINFORCED PORTION OF NOZZLE:

THE LOCATIONS OF INTEREST ARE 7 & 8 (SEE SHEET 46 OF S-212-P).  
THE CASE WHICH GAVE THE HIGHEST STRESSES WAS CASE 3. THE  
HIGHEST STRESSES WILL OCCUR ON OUTLET NOZZLES 1 AND 3 BECAUSE  
THE SUPPORT LOAD STRESSES HELP TO RELIEVE THE STRESSES.

FOR CASE 3

$$\bar{F}_x = 0 \quad \bar{M}_x = 0 \quad \sqrt{\bar{M}_y^2 + \bar{M}_z^2} = 11441 \text{ IN-KIP}$$

$$\bar{F}_y = 380 \quad \bar{M}_y = -104825$$

$$\bar{F}_z = -800 \quad \bar{M}_z = -45919$$

$$\bar{F}_y \sin \theta + \bar{F}_z \cos \theta = -27^k \quad \text{FOR } \theta = 24.1^\circ \quad \frac{\bar{M}_y}{\bar{M}_z}$$

VESSEL WALL AT THE NOZZLE TO VESSEL SHELL JUNCTURE:

THE LOCATIONS OF INTEREST ARE 9 & 10 (SEE SHEET 49 OF S-212-P).  
THE CASES WHICH GAVE THE HIGHEST STRESSES WERE CASE 2 FOR  
POINTS A & B AND CASE 3 FOR POINTS C & D. THE HIGHEST STRESSES  
OCCURRED ON OUTLET NOZZLES NO. 1 AND 3.

CASE 2

$$\begin{array}{ll} \bar{F}_x = 0 & \bar{M}_x = 0 \\ \bar{F}_y = -1140 & \bar{M}_y = 0 \\ \bar{F}_z = 0 & \bar{M}_z = 111685 \end{array}$$

CASE 3

$$\begin{array}{ll} \bar{F}_x = 0 & \bar{M}_x = 0 \\ \bar{F}_y = 380 & \bar{M}_y = -109125 \\ \bar{F}_z = -800 & \bar{M}_z = -47962 \end{array}$$

SUPPORT PADS:

THE LOCATIONS OF INTEREST ARE THE SIDE AND BOTTOM OF THE  
PADS. CASE 2 FOR THE OUTLET NOZZLE GAVE THE HIGHEST VERTICAL  
FORCE AND CASE 2 FOR THE INLET NOZZLE GAVE THE HIGHEST  
HORIZONTAL FORCE.

$$H_{MAX} = 1021^k \quad \text{FOR CASE 2 (INLET NOZ)}$$

$$V_{MAX} = 1637^k \quad \text{FOR CASE 2 (OUTLET NOZ)}$$

NOTE THAT THE VESSEL TENDS  
TO LIFT OFF THE SUPPORTS  
FOR CASE 4 - INLET NOZ.

**COMBUSTION ENGINEERING, INC.**  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-214-C | A 257

SHEET 9 OF 10

CHARGE NO. \_\_\_\_\_

DATE 4-11-69 BY RODRELL

DESCRIPTION STRUCTURAL ANALYSIS OF INLET AND OUTLET  
NOZZLES - VESSEL SUPPORTS UNDER APE BREAK LOADS

CHECK DATE \_\_\_\_\_ BY \_\_\_\_\_

5. DETAILED ANALYSIS:

C. STRESSES:

INLET NOZZLE:

REINFORCED PORTION OF NOZZLE:

LOCATION	PRESSURE STRESS			APE BREAK LOAD STRESS			PRINCIPAL STRESS			STRESS INTENSITY		
	$\sigma_1$	$\sigma_2$	$\sigma_r$	$\sigma_1$	$\sigma_2$	$T_{RD}$	$\sigma_1$	$\sigma_2$	$\sigma_3$	$\sigma_1 - \sigma_2$	$\sigma_1 - \sigma_3$	$\sigma_2 - \sigma_3$
A	1.40	5.68	-2.25	5.36	0	0	-3.96	3.68	-2.25	-7.64	-1.71	5.93
B				5.36	0	0	6.76			5.08	9.01	
C				5.32	0	0	6.72			3.04	9.97	
D				-5.32	0	0	-3.92			-7.60	-1.67	
10 A			0	-8.58	0	0	-7.18		0	-10.86	-4.93	3.68
B				8.58	0	0	9.98			6.30	12.23	
C				8.51	0	0	9.91			6.23	12.16	
D				-8.51	0	0	-7.11			-10.79	-4.86	

$$S_{MAX} = \sigma_1 - \sigma_3 = 12.23 \text{ KSI} < 1.2 S_m = 32 \text{ KSI} \quad @ \text{LOCATION 9B}$$

VESSEL WALL AT THE NOZZLE TO VESSEL SHELL JUNCTION:

LOCATION	PRESSURE STRESS			APE BREAK LOAD STRESS			PRINCIPAL STRESS			STRESS INTENSITY		
	$\sigma_1$	$\sigma_2$	$\sigma_r$	$\sigma_1$	$\sigma_2$	$T_{RD}$	$\sigma_1$	$\sigma_2$	$\sigma_3$	$\sigma_1 - \sigma_2$	$\sigma_1 - \sigma_3$	$\sigma_2 - \sigma_3$
9 A	6.44	27.92	-2.25	15.97	5.63	0	22.31	33.55	-2.25	-11.24	24.56	35.80
B	6.44	27.92		-15.87	-5.63	0	-9.43	22.29		-31.72	-7.18	24.54
C	18.42	6.36		-11.08	-22.39	0	7.43	-16.02		23.45	9.68	-13.77
D	18.42	6.36		11.08	22.39	0	29.50	29.74		0.76	31.75	30.99
10 A	6.44	27.92	0	-18.63	-15.52	0	-21.48	12.40	0	-33.88	-21.48	12.40
B	6.44	27.92		18.63	15.52	0	34.36	43.44		9.08	34.36	43.44
C	18.42	6.36		16.05	25.09	0	34.47	31.45		3.02	34.97	31.45
D	18.42	6.36		-16.05	-25.09	0	2.37	-18.73		16.36	2.37	-18.73

$$S_{MAX} = \sigma_1 - \sigma_3 = 43.44 \text{ KSI} < 1.8 S_m = 48.1 \text{ KSI} \quad @ \text{LOCATION 10B}$$

SURFACE STRESS:

$$\sigma_{SURF} = \frac{H_{MAX}}{A_{S-0.08}} = 52.2 \text{ KSI}$$

$$\tau_{SURF} = \frac{V_{MAX}}{A_{S-0.08}} = 7.5 \text{ KSI}$$

$$< 1.2 S_y = 56.6 \text{ KSI} \quad @ 200^\circ \text{F}$$

## COMBUSTION ENGINEERING, INC.

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

CHARGE NO. \_\_\_\_\_

NUMBER S-2M-P A 259SHEET 10 OF 10DATE 4-11-69 BY CHAPMANDESCRIPTION STRUCTURAL ANALYSIS OF INLET AND OUTLET


CHECK DATE \_\_\_\_\_ BY \_\_\_\_\_

NOZZLES - VESSEL SUPPORTS UNDER PIPE BEND LOADSDETAILED ANALYSIS:C. STRESSES:OUTLET NOZZLE:REINFORCED PORTION OF NOZZLE:

LOCATION	PRESSURE STRESS			PIPE BEND LOAD STRESS		PRINCIPAL STRESS			STRESS INTENSITY		
	$\sigma_x$	$\sigma_y$	$\sigma_z$	$\sigma_x$	$\tau_{xy}$	$\sigma_1$	$\sigma_2$	$\sigma_3$	$\sigma_1 - \sigma_2$	$\sigma_1 - \sigma_3$	$\sigma_2 - \sigma_3$
7 C'	1.36	3.59	-2.25	-6.87	.04	-5.51	3.59	-2.25	-9.10	-3.26	5.84
D'			-2.25	6.87		9.32		-2.25	4.73	10.57	5.84
8 C'			0	-11.44		-10.00		0	-13.67	-10.00	3.59
D'			0	11.44		12.80		0	9.21	12.80	3.59

$$S_{MAX} = \sigma_1 - \sigma_2 = 13.67 \text{ KSI} < 1.2 S_m = 32 \text{ KSI}$$

@ LOCATION 8C'

VESSEL WALL AT THE NOZZLE TO VESSEL SHELL JUNCTION:

LOCATION	PRESSURE STRESS			PIPE BEND LOAD STRESS			PRINCIPAL STRESS			STRESS INTENSITY		
	$\sigma_x$	$\sigma_y$	$\sigma_z$	$\sigma_x$	$\sigma_y$	$\tau_{xy}$	$\sigma_1$	$\sigma_2$	$\sigma_3$	$\sigma_1 - \sigma_2$	$\sigma_1 - \sigma_3$	$\sigma_2 - \sigma_3$
9 A	6.23	2797	-2.25	-17.53	-5.92	0	-11.30	22.05	-2.25	-33.35	-9.05	24.30
B	6.23	2797		17.53	5.92	0	23.76	33.89		-10.13	26.01	36.14
C	11.48	6.16		11.79	23.79	.42	30.56	29.66		0.90	32.81	31.91
D	18.48	6.16	↓	-11.79	-23.79	-.42	6.70	17.64	↓	-10.94	8.95	19.59
10 A	6.23	2797	0	20.44	16.42	0	26.67	44.39	0	-17.72	26.67	44.39
B	6.23	2797		-20.44	-16.42	0	-14.21	11.55		-25.76	-14.21	11.55
C	18.48	6.16		-16.59	-26.41	.42	1.90	-20.26		22.16	1.90	-20.26
D	18.48	6.16	↓	16.59	26.41	-.42	35.14	32.50	↓	2.64	35.14	32.50

$$S_{MAX} = \sigma_2 - \sigma_3 = 44.39 \text{ KSI} < 1.8 S_m = 48.1 \text{ KSI} @ \text{LOCATION 10 A}$$

SUPPORT PLATE:

$$\sigma_{BOLTER} = \frac{H_{MAX}}{A_{BOLTER}} = 40.8 \text{ KSI}$$

$$\sigma_{BOLTER} = \frac{V_{MAX}}{A_{BOLTER}} = 7.4 \text{ KSI}$$

$$< 1.2 S_y = 56.6 \text{ KSI} @ 200^\circ \text{F}$$

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTAHOOCHEE, TENN.

NUMBER EEIS-P-1209

SHEET 4 OF 16

CHARGE NO. \_\_\_\_\_



DATE 2-3-67 BY C. G. GRIFFIN

DESCRIPTION FATIGUE EVALUATION OF VESSEL SUPPORT PROTECTIVE DATE 2-3-67 BY ALEXANDER

### 5. DETAILED ANALYSIS:

#### a. SYSTEM GEOMETRY:

A CROSS SECTION OF THE INLET AND OUTLET NOZZLES IS SHOWN BELOW.



#### b. SYSTEM ALLOWABLES:

SHOW THAT EACH POINT MEETS THE REQUIREMENTS FOR PEAK STRESS INTENSITY GIVEN IN N-414.5 OF THE ASME CODE SECTION III. THE PROCEDURE WILL BE AS OUTLINED IN N-415.2 OF SECTION III.

## COMBUSTION ENGINEERING, INC.

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-215-P

A-260

SHEET 5 OF 16

CHARGE NO.

DATE 2-3-67 BY C. G. G. G.


DESCRIPTION FAILURE EVALUATION OF VESSEL SUPPORT PADS CHECK DATE 2-3-67 BY ALEXANDER

3- DETAILED ANALYSIS:C- SYSTEM LOADS:

THE VESSEL SUPPORT PAD AT SECTION A-A AS SHOWN ON SHEET - 4 WILL BE INVESTIGATED FOR THE FOLLOWING LOADS:

1- THE PRESSURE AND THERMAL TRANSIENTS AS GIVEN IN REFERENCE - A:

THE VESSEL IS SUPPLIED BY FOUR NOZZLES (TWO INLET AND TWO OUTLET). THE TEMPERATURE GRADIENT THRU THE NOZZLE WALL AND SUPPORT PAD FOR THE HEATUP AND COOLDOWN TRANSIENTS AND STEADYSTATE CONDITIONS WILL BE AS FOLLOWS



CONDITION	INLET NOZZLE			OUTLET NOZZLE		
	T <sub>IN</sub>	T <sub>OUT</sub>	T <sub>M</sub>	T <sub>IN</sub>	T <sub>OUT</sub>	T <sub>M</sub>
HYDRO HEATUP	400	150	263	400	150	263
HYDRO STEADYSTATE	400	170	285	400	170	285
PLANT HEATUP	547	186	354	547	186	354
0% STEADYSTATE	547	203	375	547	203	375
100% STEADYSTATE	555	203	379	613	217	415
END OF COOLING	100	115	120	100	115	120

FOR ALL TRANSIENTS OTHER THAN THE HEATUP AND COOLDOWN TRANSIENT, THE INSIDE SURFACE OF THE NOZZLE (POINT - 1 AS SHOWN ON SHEET - 4) WILL BE AT A TEMPERATURE EQUAL TO THE REACTOR (COOLANT TEMPERATURE, WHILE THE OUTSIDE SURFACE (POINT - 2) AND THE MEAN TEMPERATURE OF THE CROSSSECTION WILL BE AT A TEMPERATURE CORRESPONDING TO STEADYSTATE CONDITIONS.




## COMBUSTION ENGINEERING, INC.

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

CHARGE NO. \_\_\_\_\_

NUMBER S-215-P | A-261SHEET 5 OF 16DATE \_\_\_\_\_ BY OCKELLDESCRIPTION FATIGUE EVALUATION OF VESSEL SUPPORT PAD CHECK DATE \_\_\_\_\_ BY \_\_\_\_\_5. DETAILED ANALYSIS:C. SYSTEM LOADS2. EXTERNAL LOADS

THE EXTERNAL LOADS CONSIST OF THERMAL AND SEISMIC PIPE REACTIONS, STATIC WEIGHT AND EARTHQUAKE LOADING. THE FOLLOWING FIGURE SHOWS THE PIPE REACTIONS AND LOADING THROUGH THE SUPPORT WHICH PERMITS STRESSES AT THE POINTS IN CONSIDERATION.



FORCE	INLET NOZZLE				OUTLET NOZZLE			
	THERMAL INDUCED PIPE REACTIONS	SEISMIC PIPE REACTIONS	STATIC WEIGHT	EARTHQUAKE LOADING THROUGH SUPPORTS	THERMAL INDUCED PIPE REACTIONS	SEISMIC PIPE REACTIONS	STATIC WEIGHT	EARTHQUAKE LOADING THROUGH SUPPORTS
$\bar{F}_x$	14.8	$\pm 57.9$	0	0	26.2	$\pm 122$	0	0
$\bar{F}_y$	-92.0	$\pm 67.0$	0	0	-230.0	$\pm 90$	0	0
$\bar{M}_z$	9291	$\pm 11250$	-1515	$\pm 341$	29909	$\pm 9387$	-1796	$\pm 424$
V	0	0	561.1	$\pm 126.4$	0	0	561.1	$\pm 132.5$

THE ABOVE LOADS ARE THE RESOLVED LOADS TO THE CROSS SECTION IN CONSIDERATION AS FOLLOWS

$$\bar{F}_x = F_{xp}$$

$$\bar{F}_y = F_{yp}$$

$$\bar{M}_z = M_{zp} - x_1 F_{yp} - x_2 V$$

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-818-P | A-232  
SHEET 7 OF 16  
DATE 2-3-67 BY CORRELL  
CHECK DATE 2-3-67 BY ALLEN

CHARGE NO. \_\_\_\_\_  
DESCRIPTION FATIGUE EVALUATION OF VESSEL SUPPORT PADS

5. DETAILED ANALYSIS:

d. STRESSES:

THE FOLLOWING EXPRESSIONS WILL BE USED TO CALCULATE STRESSES AT THE TWO POINTS 1 AND 2 AS INDICATED ON SHEET-4.

INLET NOZZLE:

PRESSURE STRESSES:

$$\sigma_r = \pm \frac{pM}{t^2} + \frac{pP}{2Rt} = \underline{2.26717P} \text{ POINT-1}$$

$$= \underline{-2.16745P} \text{ POINT-2}$$

$$\sigma_o = \pm \frac{pM}{t^2} + \frac{ED}{R} + \frac{pP}{t}$$

$$= \underline{3.39898P} \text{ POINT 1}$$

$$= \underline{1.77444P} \text{ POINT 2}$$

THERMAL STRESSES:

$$\sigma_r = \pm \frac{pM}{t^2} + \frac{E\alpha(T_m - T)}{(1-\nu)}$$

$$= \underline{\pm 0.003254 P + 1.42857E\alpha(T_m - T)}$$

$$\sigma_o = \pm \frac{pM}{t^2} + \frac{E\alpha_{max}}{R} + \frac{E\alpha(T_m - T)}{(1-\nu)}$$

$$= \underline{\pm 3.01576 P + 0.04617E\alpha_{max} + 1.42857E\alpha(T_m - T)}$$

WHERE:

$$M = M_1 + M_2$$

$M_1$  IS THE THERMAL MOMENT DETERMINED IN THE THERMAL INTERACTION

$M_2$  IS THE THERMAL MOMENT AT THE CROSSSECTION DUE TO THE RADIAL GRADIENT

SUPPORT LOAD STRESSES:

$$\sigma_r = -\frac{F_p}{A} + \frac{M_2 C}{I}$$

$$= \underline{-0.00069 F_{p,r} - 0.00005 \bar{M}_2} \text{ POINT 1}$$

$$= \underline{-0.00069 F_{p,r} - 0.00007 \bar{M}_2} \text{ POINT 2}$$

WHERE:

$$\bar{M}_2 = M_{2,r} - \gamma(F_{p,r}) - \gamma_s V$$

$$\sigma_r = -\frac{V}{A} = \underline{-0.00455V} \text{ (POINT 2)}$$

OUTLET NOZZLE:

PRESSURE STRESSES:

$$\sigma_r = \pm \frac{pM}{t^2} + \frac{pP}{2Rt} = \underline{2.91772P} \text{ POINT-1}$$

$$= \underline{-1.83498P} \text{ POINT-2}$$

$$\sigma_o = \pm \frac{pM}{t^2} + \frac{ED}{R} + \frac{pP}{t}$$

$$= \underline{3.20524P} \text{ POINT 1}$$

$$= \underline{1.77942P} \text{ POINT 2}$$

THERMAL STRESSES:

$$\sigma_r = \pm \frac{pM}{t^2} + \frac{E\alpha(T_m - T)}{(1-\nu)}$$

$$= \underline{\pm 0.00330 P + 1.42857E\alpha(T_m - T)}$$

$$\sigma_o = \pm \frac{pM}{t^2} + \frac{E\alpha_{max}}{R} + \frac{E\alpha(T_m - T)}{(1-\nu)}$$

$$= \underline{\pm 0.01785 P + 0.05005E\alpha_{max} + 1.42857E\alpha(T_m - T)}$$

SUPPORT LOAD STRESSES:

$$\sigma_r = -\frac{F_p}{A} + \frac{M_2 C}{I}$$

$$= \underline{-0.00073 F_{p,r} - 0.00005 \bar{M}_2} \text{ POINT 1}$$

$$= \underline{-0.00073 F_{p,r} - 0.00009 \bar{M}_2} \text{ POINT 2}$$

WHERE:

$$\bar{M}_2 = M_{2,r} - \gamma(F_{p,r}) - \gamma_s V$$

$$\sigma_r = -\frac{V}{A} = \underline{-0.00455V} \text{ (POINT 2)}$$

## COMBUSTION ENGINEERING, INC.

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

CHARGE NO. \_\_\_\_\_

NUMBER 5-215-P

A-215

SHEET 8 OF 16

DATE 2-3-67 BY *CHERRY*DESCRIPTION *FATIGUE EVALUATION OF VESSEL SUPPORT PADS*CHECK DATE 2-3-67 BY *ALLEN*5. DETAILED ANALYSIS:d- STRESSSES:

TRANSIENT	INLET NOZZLE	OUTLET NOZZLE					
		M	EA	Tu	Tair	Tm	Eti
Q 1617 hrs	2250	51.584	43.232	547	196	354	0.201
B 1417 hrs	2315	-43.494	-43.279	100	115	120	0.180
C 20 min	2350	6.065	-1.302	594.8	203	375	0.202
E 1417 hrs	2350			555	203	379	0.205
D 20 min	2350			547	203	379	0.205
F 1417 hrs	2350			547	203	375	0.202
G 1417 hrs	2400			543.6	203	379	0.205
H 1417 hrs	2400			540.1			
I 1417 hrs	2400			570			
J 1417 hrs	2400			564			
K 1417 hrs	2400			546			
L 1417 hrs	2400	0	0	100	100	100	0.193
M 1417 hrs	2400	51.584	43.232	400	150	263	0.197
N 1417 hrs	2400	6.065	-1.302	400	170	285	0.180
O 1417 hrs	2400	-43.494	-43.279	100	115	120	0.205
P 1417 hrs	2400	6.065	-1.302	594.8	203	379	0.202
Q 1417 hrs	2400			540.8			
R 1417 hrs	2400			521.3			
S 1417 hrs	2400			595			
T 1417 hrs	2400			596			
U 1417 hrs	2400			559.6			
V 1417 hrs	2400			350	203	375	0.202
W 1417 hrs	2400						
X 1417 hrs	2400						
Y 1417 hrs	2400						
Z 1417 hrs	2400						

Submitted: December 27, 2011

## COMBUSTION ENGINEERING, INC.

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

CHARGE NO.

DESCRIPTION FATIGUE EVALUATION OF VESSEL SUPPORT PADSNUMBER 5-215-P 1A-20SHEET 9 OF 16DATE 2-3-67 BY C. G. G. G.CHECK DATE 2-3-67 BY ALEXANDER5. DETAILED ANALYSIS:d. STRESSES

TRANSVERSE	INLET NOZZLE POINT-1			TANGENTIAL STRESS			PRESSURE STRESS			PIPE LONG STRESS			TOTAL STRESS			STRESS INTENSITY		
	$\sigma_x$	$\sigma_y$	$\sigma_z$	$\sigma_x$	$\sigma_y$	$\sigma_z$	$\sigma_x$	$\sigma_y$	$\sigma_z$	$\sigma_x$	$\sigma_y$	$\sigma_z$	$\sigma_x$	$\sigma_y$	$\sigma_z$	$\sigma_x$	$\sigma_y$	$\sigma_z$
a. 4.47 sec	7.55	7.65	-2.25	-52.71	-52.61	-1.02	0						-46.38	-44.96	-2.25	-1.42	-44.13	-48.71
b. 4.47 sec	1.33	1.07	-0.32	2.85	2.45	0.70							4.58	3.52	-0.32	1.06	4.90	3.84
c. 20 min	7.35	7.65	-2.25	-51.56	-51.84	-0.40							-44.61	-44.19	-2.25	-0.42	-42.36	-41.94
Free Long Stress	7.35	7.65	-2.25	-50.47	-50.75								-43.52	-43.10	-2.25	-0.42	-41.27	-40.85
d. 20 min	7.35	7.65	-2.25	-48.16	-48.44								-41.21	-40.79	-2.25	-0.42	-38.96	-38.54
No Long Stress	7.35	7.65	-2.25	-49.34	-49.59								-42.36	-41.94	-2.25	-0.42	-40.11	-39.69
e. 20 sec	6.91	7.27	-2.14	-47.18	-47.46								-40.59	-40.19	-2.14	-0.40	-38.45	-38.05
f. 100 sec	7.35	7.68	-2.26	-54.25	-54.53								-41.27	-40.85	-2.26	-0.42	-40.01	-40.59
g. 9.2 sec	7.68	7.99	-2.39	-54.80	-55.08								-47.52	-47.09	-2.35	-0.43	-45.17	-44.74
h. 10 sec	7.25	7.59	-2.22	-53.07	-53.35								-46.22	-45.80	-2.22	-0.42	-44.00	-43.58
i. 65 sec	6.34	6.69	-1.91	-47.87	-48.15								-42.03	-41.66	-1.91	-0.37	-40.12	-39.75
j. 20 min	10.21	10.62	-3.13	0	0	0.08							10.29	10.62	-3.13	-0.33	13.42	13.75
Horizontal 3.5 sec	4.08	4.25	-1.25	-35.06	-34.96	-0.40							-31.38	-30.71	-1.25	-0.67	-30.13	-29.46
k. 5.5 sec	8.17	8.50	-2.50	-32.04	-32.32	-0.40							-24.27	-23.82	-2.50	-0.45	-21.77	-21.32
Vertical 3.5 sec	10.3	1.07	-0.32	2.85	2.45	0.08							3.96	3.52	-0.32	1.44	4.28	3.84
l. 7.68 sec	7.68	7.99	-2.35	-48.68	-48.96	-0.40							-41.40	-40.97	-2.35	-0.43	-39.05	-38.62
m. 2.02 sec	7.02	7.31	-2.15	-52.14	-52.42								-45.52	-45.11	-2.15	-0.41	-43.37	-42.96
n. 12 sec	7.35	7.65	-2.25	-40.89	-41.17								-33.94	-33.52	-2.25	-0.42	-31.69	-31.27
o. 10 sec	9.02	9.38	-2.76	-59.15	-59.41								-50.51	-50.03	-2.76	-0.48	-47.75	-47.37
p. 28 sec	6.93	7.21	-2.12	-62.30	-62.58								-56.05	-55.37	-2.12	-0.68	-53.93	-53.25
q. 160 sec	4.70	4.99	-1.44	-51.80	-52.08								-47.50	-47.19	-1.44	-0.31	-46.06	-45.75
r. 4 sec	2.79	2.98	-0.70	7.53	7.25								9.42	9.63	-0.70	-0.21	10.12	10.33

## COMBUSTION ENGINEERING, INC.

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

CHARGE NO.

DESCRIPTION: *Leakage from Inlet of Valve, Super Pass*CHECK DATE: *2-3-67* BY: *ALC/SGH*NUMBER: *5-215-P* 1SHEET *10* OF *16*DATE: *2-3-67* BY: *ALC/SGH**S. PETERSON, ANALYST*  
*D. STEVENS*

## INLET NOZZLE POINT - 2

T. COUNT	PRESSURE STRESS			THERMAL STRESS		PIPE LOAD STRESS		TOTAL STRESS			STRESS INTENSITY		
	$\sigma_x$	$\sigma_y$	$\sigma_z$	$\sigma_x$	$\sigma_y$	$\sigma_z$	$\sigma_r$	$\sigma_x$	$\sigma_y$	$\sigma_z$	$\sigma_x - \sigma_y$	$\sigma_y - \sigma_z$	$\sigma_x - \sigma_z$
CRACK WIDTH 0.01	0	0	0	0	0	0	-2.55	0	0	-2.55	0	2.55	2.55
a 1.47 hrs	-4.83	3.99		45.53	49.43	-1.40	-2.70	39.30	53.42	-2.70	-14.12	42.00	56.12
b 4.47 hrs	-0.68	0.96		3.58	-0.02	0.96	-3.85	3.96	0.54	-3.93	3.32	7.71	4.39
c 20 min	-4.83	3.99		49.31	49.47	-0.55	-2.97	43.93	53.46	-2.97	-9.53	46.90	56.43
FULL LOAD STANDARD	-4.83	3.99		50.47	50.63			45.09	54.62		-9.53	48.06	57.59
d 20 min	-4.83	3.99		50.47	50.63			45.09	54.62		-9.53	48.06	57.59
NO LOAD STANDARD	-4.83	3.99		49.31	49.47			43.93	53.46		-9.53	46.90	56.43
e 100 sec	-4.60	3.80		50.47	50.63			45.32	54.43		-9.11	48.29	57.40
f 100 sec	-4.85	4.01						45.07	54.64		-9.57	48.04	57.61
g 2.2 min	-5.05	4.17						44.97	54.80		-9.93	47.84	57.77
h 10 sec	-4.77	3.94						45.15	54.57		-9.42	48.12	57.54
65 sec	-4.10	3.39						45.92	54.02		-8.20	46.79	56.99
i 280 min	-6.71	5.59		0	0	0.11	-2.55	-6.60	5.59	-2.55	-12.19	-4.05	8.14
j 1100 hr 3.5 hrs	-2.68	2.22		29.45	32.35	-0.55	-2.97	25.22	34.57	-2.97	-9.35	28.19	37.54
5.5 CONCRETE 25 min	-5.37	4.44		32.04	32.20	-0.55	-2.97	26.12	36.64	-2.97	-10.52	29.89	39.61
	-0.68	0.96		3.58	-0.02	0.11	-2.55	3.01	0.54	-2.55	2.47	5.56	3.09
k ~	-5.05	4.17		50.47	50.63	-0.55	-2.97	44.87	54.80	-2.97	-9.93	47.84	57.77
~	-4.62	3.82						45.30	54.45		-9.15	48.27	57.42
l 12 sec	-4.83	3.99						45.09	54.62		-9.53	48.06	57.59
10 sec	-5.93	4.90						43.99	56.53		-11.54	46.96	58.50
m 20 sec	-4.55	3.76						45.37	54.39		-9.02	48.34	57.36
160 sec	-3.09	2.56						46.83	53.19		-6.36	49.30	56.16
n 54 sec	-1.50	1.24		49.31	49.47			47.26	50.71		-3.45	50.73	53.68

## COMBUSTION ENGINEERING, INC.

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 6-215-P

A276

SHEET 11 OF 16

CHARGE NO. \_\_\_\_\_

DATE 2-3-67 BY C. K. KELL

DESCRIPTION FATIGUE EVALUATION OF VESSEL SUPPORT PAD CHECK DATE 2-3-67 BY ALEXANDER5. DETAILED ANALYSIS:d. STRESSESOUTLET NOZZLE POINT-1

TRANSIENT	Primary Stress		Tangential Stress		Pipe Long Stress		Total Stress		Stress Intensity		
	$\sigma_x$	$\sigma_y$	$\sigma_x$	$\sigma_y$	$\sigma_x$	$\sigma_y$	$\sigma_x$	$\sigma_y$	$\sigma_x - \sigma_y$	$\sigma_x - \sigma_z$	$\sigma_y - \sigma_z$
2 15000	659	721	-2.25	-2.25	-53.08	-1.96	0	-4890	-45.97	-2.25	-3.03
6 11000	692	101	-0.32	-0.32	3.91	2.63	0	5.03	4.92	-0.32	1.11
10 20000	659	721	-2.25	-2.25	-64.77	-1.42	0	-58.64	-57.56	-2.25	-1.05
14 20000	659	721	-2.25	-2.25	-58.39	0	0	-52.31	-51.18	-2.25	-1.13
18 20000	659	721	-2.25	-2.25	-42.30	0	0	-36.37	-35.09	-2.25	-1.28
22 20000	659	721	-2.25	-2.25	-48.95	0	0	-43.44	-41.74	-2.25	-1.70
26 20000	627	686	-2.18	-2.18	-46.61	0	0	-40.85	-39.75	-2.14	-1.10
30 20000	662	724	-2.26	-2.26	-53.79	0	0	-47.68	-46.55	-2.26	-1.13
34 20000	688	753	-2.35	-2.35	-62.78	0	0	-56.41	-55.25	-2.35	-1.16
38 20000	650	712	-2.22	-2.22	-52.24	0	0	-46.25	-45.12	-2.22	-1.13
42 20000	566	622	-1.94	-1.94	-39.06	0	0	-33.91	-32.84	-1.94	-1.07
46 20000	915	1002	-3.15	-3.15	0	0.09	0	9.24	10.02	-3.13	-2.78
50 20000	366	401	-1.25	-1.25	-35.43	-1.42	0	-33.64	-31.42	-1.25	-2.22
54 20000	732	801	-2.50	-2.50	-31.68	-1.42	0	-25.44	-23.67	-2.50	-1.77
58 20000	692	101	-0.32	-0.32	3.91	0.09	0	5.19	4.92	-0.32	0.57
62 20000	689	753	-2.35	-2.35	-56.63	-1.42	0	-50.26	-49.10	-2.35	-1.25
66 20000	629	689	-2.15	-2.15	-60.14	0	0	-54.36	-53.25	-2.15	-1.11
70 20000	659	721	-2.25	-2.25	-58.39	0	0	-52.31	-51.18	-2.25	-1.13
74 20000	805	885	-2.76	-2.76	-70.10	0	0	-62.56	-61.25	-2.76	-1.31
78 20000	584	641	-2.00	-2.00	-64.83	0	0	-59.50	-58.42	-2.00	-1.08
82 20000	430	473	-1.48	-1.48	-37.94	0	0	-36.15	-35.21	-1.48	-0.94
86 20000	285	224	-0.70	-0.70	-15.25	0	0	-14.28	-13.01	-0.70	-1.27
90 20000	285	224	-0.70	-0.70	-15.25	0	0	-14.28	-13.01	-0.70	-1.27



**COMBUSTION ENGINEERING, INC.**  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

CHARGE NO. \_\_\_\_\_  
DESCRIPTION FATIGUE EVALUATION OF VESSEL SUPPORT PADS

NUMBER 5-215-P | A297  
SHEET 12 OF 16  
DATE 2-3-67 BY COOPER  
CHECK DATE 2-3-67 BY ALEXANDER

5. DETAILED ANALYSIS:

d. STRESSES:

OUTLET NOZZLE POINT - 2

TRANSIENT	Pressure Stress		Thermal Stress		Pipe Load Stress		Total Stress		Stress Intensity	
	$\sigma_x$	$\sigma_y$	$\sigma_x$	$\sigma_y$	$\sigma_x$	$\sigma_y$	$\sigma_x$	$\sigma_y$	$K_t \sigma_x$	$K_t \sigma_y$
Long term	0	0	0	0	-2.55	0	0	-2.55	2.55	2.55
a 4.7 sec	-4.13	4.00	46.36	47.44	-3.44	39.79	53.44	-3.44	-14.65	42.20
b 4.7 sec	-0.50	0.56	1.95	0.46	1.05	2.42	1.02	-4.61	1.30	7.03
c 20 min	-4.13	4.00	47.62	49.43	-2.55	40.94	53.43	-3.60	-12.49	44.54
Pipe Load	-4.13	4.00	57.88	57.29		50.90	61.21		-10.41	54.10
d 20 min	-4.13	4.00	58.24	57.14		51.56	61.14		-9.58	55.16
Pipe Load	-4.13	4.00	48.61	49.69		41.93	53.69		-11.76	45.43
e 100 sec	-3.93	3.81	57.48	57.29		51.00	61.10		-10.10	54.60
f 60 sec	-4.45	4.02				50.78	61.31		-10.53	54.38
g 3.5 min	-4.31	4.18				50.62	61.47		-10.95	54.22
h 100 sec	-4.07	3.95				50.86	61.24		-10.38	54.46
h 5 sec	-3.56	3.45				51.37	60.74		-9.37	54.97
i 20 min	-5.73	5.56	0	0	0.16	-5.57	5.56	-2.55	-11.13	-3.02
j 3.5 sec	-2.29	2.22	29.27	32.36	-2.55	24.43	34.58	-3.60	-10.15	28.03
k 5 sec	-4.59	4.45	31.34	32.42	-2.55	24.20	36.87	-3.60	-12.67	27.80
l 3.5 sec	-0.58	0.56	1.95	0.46	0.16	1.53	1.02	-2.55	0.57	4.08
m ~	-4.31	4.18	57.48	57.29	-2.55	50.62	61.47	-3.60	-10.85	54.22
n ~	-3.95	3.83				50.98	61.12		-10.14	54.58
o 12 sec	-4.13	4.00				50.90	61.29		-10.49	54.10
p 12 sec	-5.06	4.91				49.87	62.20		-12.33	53.47
q 26 sec	-3.67	3.56				51.26	60.85		-9.59	54.86
r 100 sec	-2.71	2.62				52.72	64.91		-7.69	55.82
s 5 sec	-1.20	1.25	48.61	49.69		44.78	50.94		-6.16	48.38

MINIMUM BEARING STRESS IN PAD =  $\sigma_r = -4.61 \text{ ksi}$





## COMBUSTION ENGINEERING, INC.

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

CHARGE NO.

DESCRIPTION FATIGUE EVALUATION OF VESSEL SUPPORT PADSNUMBER S-215-P

1200

SHEET 13 OF 14DATE 2-3-67BY CORDELLCHECK DATE 2-3-67 BY ALEXANDER5. DETAILED ANALYSIS:C. FATIGUE EVALUATION:

S <sub>max</sub>	S <sub>min</sub>	NUMBER OF CYCLES	S <sub>avg</sub>	N <sup>*</sup>	U
13.42	-53.93	5	33.68	15,000	0.00083
10.12	-53.93	5	32.03	18,000	0.00087
4.90	-53.93	70	29.42	23,000	0.00304
4.90	-45.17	130	25.04	42,000	0.00310
4.28	-45.17	5	24.73	43,000	0.00012
-31.69	-45.17	65	6.74	∞	0

\* FROM FIG. N-415(A)  
REFERENCE 1

$U_{max} = 0.00606$

## COMBUSTION ENGINEERING, INC.



ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-215-P

A-200

SHEET 14 OF 16

CHARGE NO. \_\_\_\_\_

DATE 2-3-67BY SKRELLDESCRIPTION FATIGUE EVALUATION OF VESSEL SUPPORT CHECK DATE 2-3-67 BY ALANER5. DETAILED ANALYSIS:A. FATIGUE EVALUATION:INLET NOZZLE (5a-5c) @ POINT-2

$S_{max}$	$S_{min}$	NUMBER OF CYCLES	$S_{avg}$	$N^*$	$U$
58.50	2.55	80	27.98	27000	0.00296
57.77	2.55	120	27.61	29000	0.00413
39.61	2.55	5	18.53	130000	0.00083
57.77	53.68	5	2.05	infinity	0

\* FROM FIG. N-615(A)  
REFERENCE 1 $U_{TOTAL} = 0.00712$

Submitted: December 27, 2011



## COMBUSTION ENGINEERING, INC.

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

CHARGE NO. \_\_\_\_\_

NUMBER 5-215-P

A 270

SHEET 15 OF 16DATE 2-8-67 BY C. G. R. S. S.CHECK DATE 2-8-67 BY ALEX. M. S.DESCRIPTION Fatigue Evaluation of Vessel Support Pads5- DETAIL ANALYSIS:C. FATIGUE EVALUATION:OUTLET NOZZLE (5-5-1) @ Point 1

S <sub>max</sub>	S <sub>min</sub>	NUMBER OF CYCLES	S <sub>ALT</sub>	N <sup>a</sup>	U
12.37	-59.80	5	36.09	11,000	0.00049
6.35	-59.80	75	3258	15,000	0.00880
6.35	-56.36	120	81.36	18,000	0.00667
-13.58	-56.36	5	21.39	76,000	0.00006
5.81	-32.39	5	18.75	101,000	0.00105
-31.97	-56.36	400	12.20	∞	0



\* FROM FIG. N-415(A)  
REFERENCE 1U<sub>NORMAL</sub> = 0.01828

## COMBUSTION ENGINEERING, INC.

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-215-P A 27SHEET 16 OF 16

CHARGE NO. \_\_\_\_\_

DATE 2-3-67 BY COCKBELLDESCRIPTION FATIGUE EVALUATION OF VESSEL SUPPORT PADS CHECK DATE 2-3-67 BY ALEXANDER5- DETAILED ANALYSIS:C. FATIGUE EVALUATION:OUTLET NOZZLE (50-5) POINT 2

$S_{max}$	$S_{min}$	Number of Occurrences	$S_{alt}$	$N^0$	$U$
65.80	2.55	80	31.63	17,000	0.00470
65.07	2.55	120	31.26	18,000	0.00666
40.47	2.55	5	18.96	120,000	1.00004
65.07	54.54	5	5.27	00	0

\* FROM FIG. N-415(A)  
REFERENCE 1 $U_{total} = 0.01160$

**COMBUSTION ENGINEERING, INC.**  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER S-202-P | A292

SHEET 4 OF 24

CHARGE NO. \_\_\_\_\_

DATE MAY 26, 1966 BY CSHALL


DESCRIPTION STRUCTURAL AND FATIGUE ANALYSIS OF  
THE VESSEL WALL TRANSITION

CHECK DATE MAY 26, 1966 BY CSHALL

5. DETAILED ANALYSIS:

u. SYSTEM GEOMETRY:

A CROSS SECTION OF THE VESSEL WALL TRANSITION IS SHOWN BELOW.



v. SYSTEM LOADS:

THE VESSEL SHELL JUNCTURE (TRANSITION) AS SHOWN ABOVE WILL BE INVESTIGATED FOR DESIGN CONDITIONS (INTERNAL PRESS OF 2.5 KSI). THE EFFECTS OF THE FOLLOWING TRANSIENT CONDITIONS WILL BE INVESTIGATED.

<u>TRANSIENT</u>	<u>NUMBER OF OCCURRENCES</u>
a. PLANT HEATUP AT 100°F PER HOUR	200
b. PLANT COOLDOWN AT 100°F PER HOUR	200
c. PLANT LOADING AT 5% OF FULL POWER PER MIN.	14,500
d. PLANT UNLOADING AT 5% OF FULL POWER PER MIN.	14,500
e. STEP LOAD INCREASE OF 10% OF FULL POWER BUT NOT TO EXCEED FULL POWER	2,000

Submitted: December 27, 2011

**COMBUSTION ENGINEERING, INC.**  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-202-P | 1A195SHEET 5 OF 24

CHARGE NO. \_\_\_\_\_

DATE MAY 26, 1966 BY COOPERDESCRIPTION STRUCTURAL AND FATIGUE ANALYSIS OF  
THE VESSEL WALL TRANSITIONCHECK DATE MAY 26, 1966 BY ALEXANDER5. DETAILED ANALYSIS:C. SYSTEM LOADS:

<u>TRANSIENT</u>	<u>NUMBER OF OCCURRENCES</u>
f. STEP LOAD DECREASE OF 10% OF FULL POWER FROM 100% POWER	2000
g. STEP LOAD REDUCTION FROM 100% TO 50% FULL POWER	200
h. REACTOR TRIP FROM FULL POWER	400
i. PLANT HYDROSTATIC TEST OF 3125 PSIA AT ROOM TEMP.	5
j. PLANT HYDROSTATIC TEST AT 2500 PSIA AT 100°F PER HOUR TO 400°F	5
k. STEADY STATE FLUCTUATIONS OF $\pm 6^\circ\text{F}$ AND $\pm 100\text{ PSI PER MIN.}$	OO
l. LOSS OF FLOW, ONE PUMP	80
m. LOSS OF LOAD	80
n. STEAM BREAK	5

C. SYSTEM ALLOWABLES:

THE FOLLOWING ALLOWABLE STRESSES ARE BASED ON THE A.S.M.E NUCLEAR CODE SECTION III, REFERENCE 1 AND ARE RELEVANT FOR THIS ANALYSIS.




1. THE AVERAGE PRIMARY STRESS INTENSITY ACROSS A SOLID SECTION SHALL NOT EXCEED  $S_m$  AT DESIGN TEMP. ( $650^\circ\text{F}$ ) AND DESIGN PRESSURE (2.5 ksi).
2. THE LOCAL PRIMARY STRESS ALONE OR COMBINED WITH 1. ABOVE SHALL NOT EXCEED  $1.5 S_m$  AT DESIGN TEMP. ( $650^\circ\text{F}$ ) AND DESIGN PRESSURE (2.5 ksi).
3. THE PRIMARY BENDING STRESS ALONE OR COMBINED WITH 1. AND 2. ABOVE SHALL NOT EXCEED  $1.5 S_m$  AT DESIGN TEMP ( $650^\circ\text{F}$ ) AND DESIGN PRESSURE (2.5 ksi).
4. THE RANGE OF PRIMARY PLUS SECONDARY STRESS RESULTING FROM MECHANICAL OR THERMAL LOADS SHALL NOT EXCEED  $S_m$  AT NORMAL METAL TEMPERATURE AND OPERATING PRESSURE.
5. SHOW THAT EACH POINT MEETS THE REQUIREMENTS FOR PEAK STRESS INTENSITY GIVEN IN N-414.5 OF THE A.S.M.E CODE SECTION III. THE PROCEDURE WILL BE AS OUTLINED IN N-415.2 OF SECTION III.

Submitted: December 27, 2011

## COMBUSTION ENGINEERING, INC.

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

CHARGE NO. \_\_\_\_\_

DESCRIPTION STRUCTURAL AND FATIGUE ANALYSIS OF  
THE VESSEL WALL TRANSITIONNUMBER S-202-P | A 294SHEET 8 OF 24DATE MAY 26, 1966 BY C. J. GILLCHECK DATE MAY 26, 1966 BY ALEXANDER5. DETAILED ANALYSIS.1. DEVELOPMENT OF CONTINUITY EQUATIONS:1. ANALYTICAL MODEL:BODY-1  
LONG CYLINDERBODY-2  
SHORT TAPERED CYLINDERBODY-3  
LONG CYLINDER

THE ACTUAL STRUCTURE IS DIVIDED INTO THE ANALYTICAL MODEL AS SHOWN ABOVE TO FACILITATE THE ANALYSIS. THE ASSUMED DIRECTIONS OF THE REDUNDANT FORCES ARE ILLUSTRATED.



COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-202-P A 275

SHEET 7 OF 24

DATE MAY 26, 1966 BY CORRELL

CHECK DATE MAY 26, 1966 BY BLUMBERG


CHARGE NO. \_\_\_\_\_  
DESCRIPTION STRUCTURAL AND FATIGUE ANALYSIS OF  
THE VESSEL WALL TRANSITION

5. DETAILED ANALYSIS:

1. DEVELOPMENT OF CONTINUITY EQUATIONS:

2. MOMENTS DUE TO REDUNDANT AND APPLIED FORCES:

Body-1:



$$R_1 = 91.051''$$

$$t_1 = 85.438''$$

$$t_1 = 10.75''$$

$$\beta = \frac{3(1-\nu^2)}{R_1^3 t_1^3}$$

$$\beta = 0.04109$$

$$D = \frac{Et^3}{12(1-\nu^2)} = 113.76345E$$

DISPLACEMENTS DUE TO REDUNDANT FORCES:

$$E\Delta_{11} = -\frac{E}{2\beta^2 D} \left[ \frac{1}{\beta} H_1 - M_1 \right]$$

$$= -63.34937 H_1 + 2.60306 M_1$$

$$E\Delta_{11}^* = -\frac{E}{2\beta^2 D} [H_1 - 2\beta M_1]$$

$$= -2.60306 H_1 + 0.21392 M_1$$

FROM REF. 7

DISPLACEMENTS DUE TO APPLIED FORCES:

$$E\delta_{11} = \frac{b_1}{t_1} \left( \frac{R_1}{b_1} - \frac{\nu}{2} \right) P = 621.63350P$$


$$E\delta_{11}^* = 0$$

## COMBUSTION ENGINEERING, INC.

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER S-202-P | A278SHEET B OF 24

CHARGE NO. \_\_\_\_\_

DATE MAY 26, 1966 BY CARRILLDESCRIPTION STRUCTURAL AND FATIGUE ANALYSIS OF  
THE VESSEL WALL TRANSITIONCHECK DATE MAY 26, 1966 BY ALEXANDER5. DETAILED ANALYSIS:4. DEVELOPMENT OF CONTINUITY EQUATIONS:2. MOMENTS DUE TO REDUNDANT AND APPLIED FORCES:Body -2:

$$R_2 = 91.031''$$

$$a_1 = 95.969''$$

$$L_1 = 8.625''$$

$$L_2 = 10.75''$$

$$L_2 = 6.026''$$

$$\lambda = \frac{1}{L_2} (L_2 - L_1) = 0.35264$$

THE INFLUENCE COEFFICIENTS FOR A SHORT TAPERED CYLINDER ARE CALCULATED BY THE METHOD OUTLINED OF PAGES 488 TO 492 OF REFERENCE 7. AND ARE PRINTED OUT ON C.E.'S. COMPUTER PROGRAM IN THE FOLLOWING FORM.

DISPLACEMENTS DUE TO REDUNDANT FORCES:

$$E\Delta_{21} = -\phi_{23} H_1 + \phi_{34} M_1 - \phi_{31} H_2 + \phi_{22} M_2$$

$$= 546.07025 H_1 + 139.51823 M_1 + 288.79601 H_2 - 139.54705 M_2$$

$$E\Delta_{22}^* = \phi_{43} H_1 - \phi_{44} M_1 + \phi_{41} H_2 - \phi_{42} M_2$$

$$= -139.06016 H_1 - 48.24337 M_1 - 149.53615 H_2 + 48.23308 M_2$$

$$E\Delta_{31} = -\phi_{13} H_1 + \phi_{14} M_1 - \phi_{11} H_2 + \phi_{12} M_2$$

$$= -288.92626 H_1 - 150.07585 M_1 - 609.44910 H_2 + 150.20263 M_2$$

$$E\Delta_{22}^* = \phi_{23} H_1 - \phi_{24} M_1 + \phi_{21} H_2 - \phi_{22} M_2$$

$$= -139.21081 H_1 - 48.37539 M_1 - 149.77350 H_2 + 48.55079 M_2$$

COMBUSTION ENGINEERING, INC.  
ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

NUMBER 5-202-P | ACT

SHEET 9 OF 24

DATE MAY 26, 1966 BY W. K. RELL

CHECK DATE MAY 26, 1966 BY ALEXANDER

CHARGE NO. \_\_\_\_\_  
SUBJECT STRUCTURAL AND FATIGUE ANALYSIS OF  
THE VESSEL WALL TRANSITION

### 5. DETAILED ANALYSIS:

#### a. DEVELOPMENT OF CONTINUITY EQUATIONS:

#### 1. MOMENTS DUE TO REDUNDANT AND APPLIED FORCES:

##### BODY 2 (CONT'D):

#### DISPLACEMENTS DUE TO APPLIED FORCES:


$$E\delta_{21} = a_2^2 \left( \frac{R_1}{a_1} - \frac{v}{2} \right) \left[ (\phi_{12} + \phi_{10}) \frac{-\lambda^2}{6(1-v^2)} + \frac{1}{E_0} \right] P = \underline{629.27110P}$$

$$E\delta_{21}^* = -a_2^2 \left( \frac{R_1}{a_1} - \frac{v}{2} \right) \left[ (\phi_{12} + \phi_{10}) \frac{-\lambda^2}{6(1-v^2)} - \frac{\lambda}{E_0} \right] P = \underline{22.03255P}$$

$$E\delta_{22} = a_2^2 \left( \frac{R_1}{a_1} - \frac{v}{2} \right) \left[ (\phi_{12} + \phi_{10}) \frac{-\lambda^2}{6(1-v^2)} + \frac{1}{E_0} \right] P = \underline{762.47399P}$$

$$E\delta_{22}^* = -a_2^2 \left( \frac{R_1}{a_1} - \frac{v}{2} \right) \left[ (\phi_{12} + \phi_{10}) \frac{-\lambda^2}{6(1-v^2)} - \frac{\lambda}{E_0} \right] P = \underline{22.09972P}$$

##### BODY -3:



$$R_1 = 91.031''$$

$$b_3 = 86.5''$$

$$t_3 = 8.625''$$

$$\beta^2 = \frac{3(1-v^2)}{R_1^2 t_3^3}$$

$$\beta = 0.04507$$

$$D = \frac{E t_3^3}{12(1-v^2)}$$

$$= 58.7563 E$$

#### DISPLACEMENTS DUE TO REDUNDANT FORCES:

$$E\Delta_{32} = \frac{E}{2\beta^2 D} \left[ \frac{1}{\beta} H_2 + M_2 \right] = \underline{88.14885 H_2 + 4.04373 M_2}$$

$$E\Delta_{32}^* = -\frac{E}{2\beta^2 D} \left[ H_2 + 2\beta M_2 \right] = \underline{-4.04373 H_2 - 0.37100 M_2}$$

#### DISPLACEMENTS DUE TO APPLIED FORCES:

$$E\delta_{12} = \frac{b_1^3}{t_1} \left( \frac{R_1}{b_1} - \frac{v}{2} \right) P = \underline{782.82249P}$$

$$E\delta_{12}^* = \underline{0}$$

FROM REF. 7:

## COMBUSTION ENGINEERING, INC.

ENGINEERING DEPARTMENT, CHATTANOOGA, TENN.

CHARGE NO.

NUMBER

S-202-P

A 298

SHEET

10

OF

24

DATE

May 26, 1966

BY

C. C. C. C.

CHECK DATE

May 26, 1966

BY

A. L. L. L.

DESCRIPTION STRUCTURAL AND FATIGUE ANALYSIS OF  
THE VESSEL WALL TRANSITION5. DETAILED ANALYSIS:1. DEVELOPMENT OF CONTINUITY EQUATIONS:3. CONTINUITY MATRIX AND LOADING VECTORS:

FROM CONTINUITY AT EACH CUT, WE WRITE THE CONTINUITY MATRIX  
IN THE FOLLOWING FORM,

$$\begin{aligned} E\Delta_{11} - E\Delta_{21} &= E\delta_{21} - E\delta_{11} \\ E\Delta_{11}^* - E\Delta_{21}^* &= E\delta_{21}^* - E\delta_{11}^* \\ E\Delta_{21} - E\Delta_{32} &= E\delta_{32} - E\delta_{22} \\ E\Delta_{21}^* - E\Delta_{32}^* &= E\delta_{32}^* - E\delta_{22}^* \end{aligned}$$

IN MATRIX FORM WE HAVE,

$$\begin{bmatrix} -609.41962 & -136.91517 & -288.79601 & 139.54705 \\ 136.45710 & 49.45729 & 149.53615 & -48.23308 \\ -288.92626 & -150.09595 & -697.59793 & 146.15890 \\ -139.21089 & -48.27539 & -145.73007 & 48.70999 \end{bmatrix} \begin{bmatrix} H_1 \\ M_1 \\ H_2 \\ M_2 \end{bmatrix} = \begin{bmatrix} 7.63772 \\ 22.03255 \\ 20.34850 \\ -22.09972 \end{bmatrix} P$$

4. REDUNDANT LOAD VALUES:

SOLVING THE ABOVE MATRIX, WE GET THE FOLLOWING VALUES  
FOR THE REDUNDANT FORCES,

$$\begin{aligned} H_1 &= -0.01732P \\ M_1 &= 5.22711P \\ H_2 &= -0.84249P \\ M_2 &= -0.12963P \end{aligned}$$