

## Clay, Earnestine

**From:** GEBERS, STEVEN W [sgebers@oppd.com]  
**Sent:** Monday, June 06, 2011 10:33 AM  
**To:** 'Bill Pook'; 'Dan'; 'Jeff Theulen'; 'Jon Schwarz'; 'Kathy Stodola'; Kirkland, John; 'Larry Oliver'; Jim Kellsay (jgkellsay@nppd.com)  
**Cc:** BERCK, ALLEN; DEANGELIS, PETER A; HANKINS, RHONDA R; MOELLER, CHRISTOPHER J; RELLER, MARK H; SILKE, DEENA L  
**Subject:** Flooding Status

### Fort Calhoun Flooding Status

1. Reactor Status: Shutdown
2. Reactor is covered with > 23-ft of water
3. Offsite power and Emergency Diesel Generators are available
4. Spent Fuel Pooling cooling is in service and protected
5. Shutdown cooling is in service and protected
6. Current river level is 1003' 3"
7. Current Blair gauge level is 28.55-ft with the current projection at 30-ft at about 07:00 on June 11, 2011.
8. The site has implemented procedures to protect power supplies and vital equipment.
9. No release of radioactivity has occurred.
10. Fort Calhoun has declared a Notification of Unusual Even at 08:00 6/6/11.
11. Backup evacuation route onsite is inundated however the primary route onsite is passable and not expected to be affected. At this time no known offsite evacuation routes are affected.

Requested Information from state and counties:

1. When offsite evaluation routes are affected please contact emergency planning.
2. When the Blair Water plant is affected please contact emergency planning.

The river flow rate is increasing and the rate of rise is also increasing.

Emergency Planning Contacts at FCS:

Steve Gebers:

Pager: (b)(6)

Work Phone: 402-533-7308

Cell Phone: (b)(6)

Mark Reller:

Pager: (b)(6)

Work Phone: 402-533-7314

Steve Gebers, CHP

Manager Emergency Planning & Health Physics

Fort Calhoun Nuclear Station

e-mail (w) [sgebers@oppd.com](mailto:sgebers@oppd.com)

e-mail (h) (b)(6)

Phone 402 533-7308

Information in this record was deleted  
in accordance with the Freedom of Information  
Act, exemptions  
FOIA- 2011-0539