

REG II

From: Clark, Jeff
To: Kennedy, Kriss; Howell, Linda
Subject: FW: Daily Status
Date: Monday, June 13, 2011 7:51:31 AM

FYI

-----Original Message-----

From: bill@region5-6.org [mailto:bill@region5-6.org]
Sent: Monday, June 13, 2011 7:23 AM
To: sgebers@oppd.com; bill@region5-6.org; dan@region5-6.org; eric.plautz@douglascounty-ne.gov; Clark, Jeff; jeffrey.theulen@pottcounty.com; jon.schwarz@nebraska.gov; kathey.stodola@iowa.gov; Kirkland, John; loliver@harrisoncountyia.org; laurel.ryan@dhs.gov; paul.johnson@douglascounty-ne.gov; whitney.shipley@douglascounty-ne.gov
Cc: aberck@oppd.com; pdeangelis@oppd.com; rhankins@oppd.com; cjmoeller@oppd.com; mreller@oppd.com; dlsilke@oppd.com
Subject: RE: Daily Status

Technically there is a "Major" evacuation route closed according to the current planning document.
All of Sub-Area 3 & 4 & 5 can no longer go through IOWA to BELLEVUE via I-29

Bill
5/6

>
>
>----- Original Message ----
>From: sgebers@oppd.com
>To: bill@region5-6.org, dan@region5-6.org,
>eric.plautz@douglascounty-ne.gov, jeff.clark@nrc.gov,
>jeffrey.theulen@pottcounty.com, jon.schwarz@nebraska.gov,
>kathey.stodola@iowa.gov, John.Kirkland@NRC.GOV,
>loliver@harrisoncountyia.org, laurel.ryan@dhs.gov,
>paul.johnson@douglascounty-ne.gov,
>whitney.shipley@douglascounty-ne.gov
>Subject: RE: Daily Status
>Date: Mon, 13 Jun 2011 07:10:09 -0500
>
>>Fort Calhoun Flooding Status
>>
>>
>>
>>1. Reactor Status: Shutdown
>>
>>2. Reactor is covered with > 23-ft of cooling water
>>
>>3. Offsite power and Emergency Diesel Generators are available.
>Both vital buses are energized at this time.
>>
>>4. Spent Fuel Pooling cooling is in service and protected.
>>
>>5. Shutdown cooling is in service and protected
>>
>>6. Current river level is 1005' 6".
>>
>>7. Current Blair gauge level is 31.38-ft with the current

Information in this record was deleted
in accordance with the Freedom of Information
Act, exemptions
FOIA- 2011-1359

>projection at 31.6-ft at about 07:00 on June 17, 2011.

>>

>>8. The site has implemented procedures to protect power supplies.

>and vital equipment. Water is onsite, and flood barriers are

>protecting vital equipment.

>>

>>9. No release of radioactivity has occurred.

>>

>>10. Fort Calhoun has declared a Notification of Unusual Event at

>08:00 6/6/11.

>>

>>11. Backup evacuation route onsite is inundated however the primary
>route onsite is passable and not expected to be affected.

>>

>>12. Power was removed from siren 257 and 260 in Pottawattamie Co.

>IA, which is just on the edge of the 10-mile EPZ south east of the

>plant. Siren 75, 76 in Desoto National Wildlife Refuge have no power.

>Currently the refuge is closed due to flooding. Siren 142 in Harrison

>Co. has no power which is north of Loveland IA ~ 9.5 miles from the

>plant. Siren 1 east of Fort Calhoun on county road 34 between Fort

>Calhoun and Boyer Chute Recreational Area is without power. This area

>is closed due to flooding.

>>

>>13. At this time no known major evacuation routes are affected.

>Interstate 29 in both directions: from Exit 55 North 25th Street to

>Exit 71: I-680 road closed to traffic because of flooding -- follow

>the detour signs. Interstate 680 in both directions: from before Exit

>1 130th Street to Exit 62: I-29; Old Mormon Bridge Road --- road

>closed because of flooding. All in Pottawattamie Co, IA.

>>

>>Requested Information from states and counties:

>>

>>

>>1. When offsite evaluation routes are affected please contact

>emergency planning.

>>

>>2. When the Blair Water plant is affected please contact

>emergency planning.

>>

>>3. Authorized power outages that affect or could affect siren

>operability, please contact emergency planning.

>>

>>The river flow rate is relatively constant at Blair NE, however the

>river level continues to rise. The Corp of Engineers is releasing at

>Gavins Point dam at 145,000 cubic feet per second (cfs) today and is

>expected to remain constant until next Tuesday, and then increase to

>150,000 cfs.

>>

>>Emergency Planning Contacts at FCS:

>>

>>Steve Gehers:

>>Pager: (b)(6)

>>Work Phone: 402-533-7308

>>Cell Phone: (b)(6)

>>

>>Allen Berk:

>>Pager: (b)(6)

>>Work Phone: 402-636-2836

>>

>>

>>Steve Gebers, CHP
>>Manager Emergency Planning & Health Physics
>>Fort Calhoun Nuclear Station
>>e-mail (w) sgebers@oppd.com<mailto:sgebers@oppd.com>
>>e-mail (h)(b)(6)
>>Phone 402 533-7308

>>

>>-----

>>

>>This e-mail contains Omaha Public Power District's confidential and
>proprietary information and is for use only by the intended
>recipient. Unless explicitly stated otherwise, this e-mail is not a
>contract offer, amendment, nor acceptance. If you are not the
>intended recipient you are notified that disclosing, copying,
>distributing or taking any action in reliance on the contents of this
>information is strictly prohibited.

>>