

Clay, Earnestine

From: GEBERS, STEVEN W [sgebers@oppd.com]
Sent: Friday, June 03, 2011 2:22 PM
To: Kirkland, John
Subject: FW: Flooding Status

John, This is the update I have been sending the state and counties.

Steve Gebers, CHP
Manager Emergency Planning & Health Physics
Fort Calhoun Nuclear Station
e-mail (w) sgebers@oppd.com
e-mail (h) (b)(6) Ex 6
Phone 402-533-7308

From: GEBERS, STEVEN W
Sent: Friday, June 03, 2011 7:45 AM
To: 'Schwarz, Jon'; 'Stodola Kathy'; 'loliver@harrisoncountya.org'; 'jeffery.theulen@pottcounty.com'; 'Bill Pook'; NRC
Cc: (b)(6); BERCK, ALLEN; DEANGELIS, PETER A; HANKINS, RHONDA R; MOELLER, CHRISTOPHER J;
RELLER, MARK H; SILKE, DEENA L
Subject: Flooding Status

Fort Calhoun Flooding Status

1. Reactor Status: Shutdown
2. Reactor is covered with > 23-ft of water
3. Offsite power and Emergency Diesel Generators are available
4. Spent Fuel Pooling cooling is in service and protected
5. Shutdown cooling is in service and protected
6. Current river level is 1002' 8.4"
7. Current Blair gauge level is 28.01-ft with the current projection at 28.6-ft at about 00:00 on June 7, 2011.
8. The site has implemented procedures to protect power supplies and vital equipment.
9. No release of radioactivity has occurred.
10. Fort Calhoun has not met any criteria for implementing the radiological emergency response plan at this time.
11. Backup evacuation route onsite is inundated however the primary route onsite is passable and not expected to be affected. At this time no known offsite evacuation routes are affected.

Requested Information from state and counties:

1. When offsite evaluation routes are affected please contact emergency planning.
2. When the Blair Water plant is affected please contact emergency planning.

Emergency Planning Contacts at FCS:

Steve Gebers:
Pager: (b)(6)
Work Phone: 402-533-7308

Information in this record was deleted
in accordance with the Freedom of Information
Act, exemptions 6
FOIA- 811-0339

C/1

Cell Phone: (b)(6)

Mark Reller:

Pager: (b)(6)

Work Phone: 402-533-7314

Steve Gebers, CHP

Manager Emergency Planning & Health Physics

Fort Calhoun Nuclear Station

e-mail (w) sgebers@oppd.com

e-mail (h) (b)(6)

Phone 402-533-7308

This e-mail contains Omaha Public Power District's confidential and proprietary information and is for use only by the intended recipient. Unless explicitly stated otherwise, this e-mail is not a contract offer, amendment, nor acceptance. If you are not the intended recipient you are notified that disclosing, copying, distributing or taking any action in reliance on the contents of this information is strictly prohibited.