

RESOLUTION OF WESTINGHOUSE ELECTRIC COMPANY
COMMENTS ON DRAFT SAFETY EVALUATION FOR
TOPICAL REPORT WCAP-13360-NP, SUPPLEMENT 1, REVISION 0,
“CLARIFICATION ON USE OF DYNAMIC ROD WORTH MEASUREMENT (DRWM)
IN INITIAL PLANT START-UP APPLICATIONS”
WESTINGHOUSE ELECTRIC COMPANY
PROJECT NO. 700

By letter dated November 17, 2011, Westinghouse Electric Company (Westinghouse) provided three comments on the draft safety evaluation (SE) for Topical Report (TR) WCAP-13360-NP, Supplement 1, Revision 0, “Clarification on Use of Dynamic Rod Worth Measurement (DRWM) in Initial plant Start-up Applications.” The following are the U.S. Nuclear Regulatory Commission (NRC) staff’s resolution of these comments:

Draft SE comments for TR WCAP-13360-NP, Supplement 1, Revision 0:

1. Westinghouse proposed the removal of the Paragraph 3 of Section 2.2. The NRC staff does not find this comment acceptable – the paragraph further clarifies the NRC staff position and will remain a part of the final SE. The NRC staff had explained its position to the Westinghouse staff and Westinghouse agreed with it.

NRC Resolution for Comment 1 on Draft SE:

Paragraph 3 of Section 2.2 will remain a part of the SE.

2. Westinghouse provided two comments related to typographical errors and stylistic changes.

NRC Resolution for Comment 2 on Draft SE:

The NRC staff reviewed the Westinghouse recommendation and found it acceptable, because the changes are editorial in nature.