

MPL No.SP64 1015M

WET PIPE SPRINKLER SYSTEM  
NTP640162  
AUX. BLDG. EL. 166'-0"

FLUSHING CONN.

1/2" NPT SPRAY NOZZLE  
WITH 1/2" ORIFICE (TYP. 58')

TO LOCAL  
ALARM

SEE NOTE 3

# NOTES:

1. FOR GENERAL NOTES SEE W-0035A.
2. ALL PIPING IS JBD-1250, UNLESS OTHERWISE NOTED.
3. FOR TYPICAL WET PIPE SPRINKLER SYSTEM SEE W-0035J(G-S).
4. MODIFIED SPRINKLER HEAD USED AS INSPECTORS TEST CONNECTION.

001	AS-BUILT PER ODR 0213-91	JMH	CH	RL	EGR	ENG	12-10-91
000	AS-BUILT PER DCP 83/0003	PFB	TRG	EGR	WTM	WFM	10/6/86
GRAND GULF NUCLEAR STATION UNIT 1 NUCLEAR PLANT ENGINEERING							
P & I DIAGRAM FIRE PROTECTION SYSTEM UNIT 1							
SCALE:	NONE	DRAWING NO.	M-0035R	REV.	001	HYBRID DFN: m0035r.dgn	

## COMPONENTS SUBJECT TO AMR

- FIRE PROTECTION WATER SYSTEM AMM15
- NON-SAFETY RELATED SYSTEMS & COMPONENTS AFFECTING SAFETY RELATED SYSTEMS AMM20

0	9-29-2011						
NO.	DATE	DESCRIPTION	BY	ENG	CHK	APP	
REVISIONS							
LRA-M-0035R							
CAD FILE m0035r.dgn							
MASTER FILE							