



TABLE 1		
FIRE DAMPER	F. P. SYSTEM	PROVIDING CLOSING SIGNAL
(F-8)	F015	NIP640006
(B-7 & F-4)	F014	NIP640006
(D-7)	F016	NIP640006
(F-4)	F017	NIP640006
(E-8)	F018	NIP640006
(C-7 & G-4)	F019	NIP640006
(D-7)	F020	NIP640006
(C-7)	F021	NIP640006
(G-4)	F022	NIP640006
(D-7)	F023	NIP640006
(C-7 & G-4)	F024	NIP640006
(D-7)	F025	NIP640006
(C-7 & G-4)	F026	NIP640006
(G-4)	F027	NIP640006
(D-7)	F028	NIP640006
(C-7 & G-4)	F029	NIP640006
(D-7)	F030	NIP640006
(G-4)	F031	NIP640006
(D-7)	F032	NIP640006
(C-7 & G-4)	F033A	NIP640006
(D-7)	F033B	NIP640006
(G-4)	F034A	NIP640006
(D-7)	F034B	NIP640006
(C-7 & G-4)	F035A	NIP640006
(D-7)	F035B	NIP640006
(G-4)	F036	NIP640006

- NOTES:
1. ALL EQUIPMENT NUMBERS ON THIS DRAWING ARE PREFIXED BY NSZ17 UNLESS OTHERWISE NOTED.
 2. ALL INSTRUMENT NUMBERS ON THIS DRAWING ARE PREFIXED BY S217 UNLESS OTHERWISE NOTED.
 3. FOR HVAC LEGEND, SEE M-0047.
 4. DELETED.
 5. THIS DWG. IS NOT A LISTED, Q IDENTIFICATION IS FOR MINOR AREAS AS SHOWN.
 6. CLOSE THE REGISTERS IN THE UNIT 2 COMPUTER ROOM BY SHUTTING THE DAMPERS BEHIND THE REGISTERS.
 7. DISCONNECT AND BLANK OFF UNIT 2 DUCTWORK, UNIT 2 DUCTWORK, REGISTERS, AND FIRE DAMPERS TO REMAIN IN PLACE.
 8. CLOSE THE REGISTERS BY SHUTTING THE DAMPERS BEHIND REGISTERS.
 9. DISCONNECT DUCTWORK AND BLANK OFF DUCTWORK IN RM 003B.
 10. CLOSE OPEN IN DUCT.

COMPONENTS SUBJECT TO AMR

HEATING, VENTILATION AND AIR CONDITIONING SYSTEMS AMM17

NON-SAFETY RELATED SYSTEMS & COMPONENTS AFFECTING SAFETY RELATED SYSTEMS AMM20

012	AS-BUILT PER DRN 06-242	WE	N/A	N/A	SP	5-8
011	AS-BUILT PER ER 96/368, SWO REMOVED ATTACHMENT STAMP	WE	N/A	N/A	SP	5-8
REVISIONS						
NO.	DATE	DESCRIPTION	BY	ENG	CHK	APP
REVISIONS						
LRA-M-0050A						
CAD FILE m0050a.dgn						
PASTER FILE						

GRAND GULF NUCLEAR STATION
UNIT 1
NUCLEAR PLANT ENGINEERING
UPDATED FINAL SAFETY ANALYSIS REPORT
FIGURE NUMBER - 09.4-016A
P & I DIAGRAM
CONTROL BUILDING HVAC SYSTEM
UNIT 1 & 2

COMMON - UNIT 1 CONTROLLED
MPL No. SZ17 1015M
SCALE: NONE
DRAWING No. M-0050A
REV. 012

0	9-29-2011					
NO.	DATE	DESCRIPTION	BY	ENG	CHK	APP
REVISIONS						
LRA-M-0050A						
CAD FILE m0050a.dgn						
PASTER FILE						