

Alexander, Ryan

From: Farnholtz, Thomas *REC IV*
Sent: Friday, July 08, 2011 9:26 AM
To: Howell, Linda; Alexander, Ryan
Subject: FW: Daily Event Status at Fort Calhoun- Friday

Hi -

The daily status report for Fort Calhoun for Friday July 8. No significant changes. The river level remains constant at about 1006' 1". They are approximately 75 percent done installing the new AquaDam. Expect that to be completed tomorrow and begin pumping out the area inside the AquaDam this weekend. We will be monitoring this activity.

Thank you and have great weekend.

Tom.

From: SILKE, DEENA L [<mailto:dsilke@oppd.com>]
Sent: Friday, July 08, 2011 8:55 AM
To: Bill Pook; Dan; Eric Plautz; Jeff Theulen; Jon Schwarz; Kirkland, John; Larry Oliver; Laurel Ryan; Paul Johnson; Whitney Shipley; 'Rasmusson, Melanie'; kathy.stodola@iowa.gov; Farnholtz, Thomas
Cc: GEBERS, STEVEN W; DEANGELIS, PETER A; MOELLER, CHRISTOPHER J; HANKINS, RHONDA R; BERCK, ALLEN; SILKE, DEENA L; RELLER, MARK H
Subject: Daily Event Status at Fort Calhoun- Friday

Fort Calhoun Flooding Status (changes from yesterday's report are in **bold**)

1. Reactor Status: Shutdown
2. Reactor is covered with > 23-ft of cooling water
3. Offsite power and Emergency Diesel Generators are available. Both vital buses are energized at this time.
4. Spent Fuel Pooling cooling is in service and protected.
5. Shutdown cooling is in service and protected
6. **Current river level is 1006' 1" at Fort Calhoun Station.**
7. **Current Blair gauge level is 31.65 ft., which is a slight decrease in the last 24 hours.**
9. The site has implemented procedures to protect power supplies and vital equipment. Water is onsite, and flood barriers are protecting vital equipment.
10. No release of radioactivity has occurred.
11. Fort Calhoun has declared a Notification of Unusual Event at 08:00 6/6/11.
12. Backup evacuation route onsite is inundated however the primary route onsite is passable and not expected to be affected.
13. Power was removed from siren **259, 257 and 260** in Pottawattamie Co. IA. All of Sub area 14 has been evacuated by Pottawattamie Co. IA. Siren **75, 76** in Desoto National Wildlife Refuge have no power. Currently the refuge is closed due to flooding. Siren **1** east of Fort Calhoun on county road 34 between Fort Calhoun and Boyer Chute Recreational Area is without power. This area is closed due to flooding. Power was removed to one additional siren in Washington County - sirens **69** was removed from service due to flooding and may require route alerting for any non-evacuated residents. Power has been removed from sirens **143** in Harrison Co. IA due to flooding. This area has been evacuated and is not populated. Power was removed to siren **135**, located one mile east of NE/IA border on HWY 30. **AC power has been restored to Siren 144 on 7-7-2011.**
14. The Reception and Care Center in Fremont is now official, replacing Bellevue. This has been planned for quite some time, but also provides us with greater protection for the public, as no evacuation routes to that location are affected at this time.
15. At this time no known major evacuation routes are affected without contingency actions planned. Interstate 29 in both directions: from Exit 54A (G Avenue) to Exit 71 (I-680 exit): I-680 road closed to traffic because of flooding. I-680 is closed in both directions: from before Exit 1 130th Street to Exit 62: I-29; Old Mormon Bridge Road --- road closed because of flooding. Highway 30 from Blair to Missouri Valley is **open with limited width** and remains an evacuation route.

Information in this record was deleted
in accordance with the Freedom of Information
Act, exemptions

FOIA- *111-0559*

438

Requested Information from states and counties:

1. When offsite evacuation routes are affected please contact emergency planning.
2. When the Blair Water plant is affected please contact emergency planning.
3. Authorized power outages that affect or could affect siren operability, please contact emergency planning.

The river flow rate and level have been relatively constant at Blair NE. The Corp of Engineers is releasing Gavin's Point dam at **160,000** cubic feet per second (cfs).

Emergency Planning Contacts at FCS:

Steve Gebers:

[Pager: (b)(6)] EX 6

Work Phone: 402-533-7308

[Cell Phone: (b)(6)] EX 6

Allen Berck:

[Pager: (b)(6)] EX 6

[Cell phone: (b)(6)] EX 6

Deena Silke, CNMT
Senior Emergency Planning Representative
Fort Calhoun Station 2-1
402-533-7365

This e-mail contains Omaha Public Power District's confidential and proprietary information and is for use only by the intended recipient. Unless explicitly stated otherwise, this e-mail is not a contract offer, amendment, nor acceptance. If you are not the intended recipient you are notified that disclosing, copying, distributing or taking any action in reliance on the contents of this information is strictly prohibited.