

Clay, Earnestine

From: BERCK, ALLEN [aberck@oppd.com]
Sent: Friday, July 22, 2011 7:44 AM
To: 'Bill Pook'; 'Dan'; 'Eric Plautz'; 'Jeff Theulen'; 'Jon Schwarz'; Kirkland, John; 'Larry Oliver'; 'Laurel Ryan'; 'Paul Johnson'; 'Whitney Shipley'; 'Rasmusson, Melanie'; 'kathy.stodola@iowa.gov'; Haire, Mark; Wingeback, Jacob; 'Schmitt, Julia'; Presby, Peter; Baca, Bernadette
Cc: GEBERS, STEVEN W; RELLER, MARK H; HANKINS, RHONDA R; MOELLER, CHRISTOPHER J; SILKE, DEENA L; BERCK, ALLEN; DEANGELIS, PETER A
Subject: Fort Calhoun Event Status - Friday

Fort Calhoun Flooding Status

1. Reactor Status: Shutdown
2. Reactor is covered with > 23-ft of cooling water
3. Offsite power and Emergency Diesel Generators are available. Both vital buses are energized at this time.
4. Spent Fuel Pooling cooling is in service and protected.
5. Shutdown cooling is in service and protected
6. **Current river level is 1006' 4" at Fort Calhoun Station.**
7. **Current Blair gauge level is 31.76 ft.; According to the NWS/USACE, a rise (4 inches) trend is predicted over the next 12 hours, then a lowering trend for the next 4 days.**
8. The site has implemented procedures to protect power supplies and vital equipment. Water is onsite, and flood barriers are protecting vital equipment.
9. No release of radioactivity has occurred.
10. Fort Calhoun has declared a Notification of Unusual Event at 08:00 6/6/11.
11. Backup evacuation route onsite is inundated however the primary route onsite is passable and not expected to be affected.
12. **9 sirens remain with no AC power.** Power has been removed from siren **259, 257 and 260** in Pottawattamie County IA. Power has been removed from sirens **143 and 135** in Harrison County, IA. Power has been removed from sirens **1, 69, 75, 76** in Washington County, NE. Power was removed from these sirens due to flooding in the surrounding areas. The coverage areas for these sirens has been reviewed with state and county agencies. For those residents that do remain in these areas, the counties are responsible for route alerting.
13. The Reception and Care Center in Fremont is now official, replacing Bellevue; no evacuation routes to that location are affected at this time.
14. At this time no known major evacuation routes are affected without contingency actions planned. Interstate 29 in both directions: from Exit 54A (G Avenue) to Exit 71 (I-680 exit): I-680 road closed to traffic because of flooding. I-680 is closed in both directions: from before Exit 1 130th Street to Exit 62: I-29; Old Mormon Bridge Road --- road closed because of flooding.

Requested information from states and counties:

1. When offsite evacuation routes are affected please contact emergency planning.
2. When the Blair Water plant is affected please contact emergency planning.
3. Authorized power outages that affect or could affect siren operability, please contact emergency planning.

The river flow rate and level have been relatively constant at Blair NE. The Corp of Engineers is releasing Gavin's Point dam at **160,000** cubic feet per second (cfs).

Emergency Planning Contacts at FCS:

Steve Gebers:

Information in this record was deleted
in accordance with the Freedom of Information
Act, exemptions 6
FOIA- 2111-0339

C/46

Pager: (b)(6) Ex 6
Work Phone: 402-533-7308
Cell Phone: (b)(6) Ex 6

Allen Berck:
Pager: (b)(6)
Cell phone: (b)(6) Ex 6

Allen D. Berck
Supervisor - Emergency Planning
Fort Calhoun Station
Omaha Public Power District
phone: 402-533-6064
pager: (b)(6) Ex 6
email: aberck@oppd.com

This e-mail contains Omaha Public Power District's confidential and proprietary information and is for use only by the intended recipient. Unless explicitly stated otherwise, this e-mail is not a contract offer, amendment, nor acceptance. If you are not the intended recipient you are notified that disclosing, copying, distributing or taking any action in reliance on the contents of this information is strictly prohibited.