

WBN2Public Resource

From: Poole, Justin
Sent: Thursday, January 26, 2012 11:26 AM
To: Arent, Gordon; Bryan, Robert H Jr
Cc: WBN2HearingFile Resource
Subject: Talking point for the meeting on Feb 2

Gordon,

I intend to get a full list of talking points from our staff for the meeting on 2/2, but in the meantime here is one that came up. It seems to be more of a clarification on the terms below. Thanks.

Justin C. Poole
Sr. Project Manager
NRR/DORL/LPWB
U.S. Nuclear Regulatory Commission
(301)415-2048
email: Justin.Poole@nrc.gov

While reviewing the revisions to the FPR, Part VII, Section 4.5, LACK OF AUTOMATIC DETECTION IN 757.0-A13 (REFUELING ROOM) AND NEW FUEL STORAGE VAULT (741.5), it became evident that clarification of the terms Refueling Room, Refueling Area, New Fuel Storage Vault and New Fuel Storage Area was necessary to complete this section of the Safety Evaluation.

It appears that the only place in the FPR that the term New Fuel Storage Area is used is in Table 14.1 (page 5 of 10) where it indicates that detection is available.

However, TVA DWG NO. 2-47W240-12, R1, Figure II-38A indicates that there is a New Fuel Storage Area on elevation 741.5.

Hearing Identifier: Watts_Bar_2_Operating_LA_Public
Email Number: 645

Mail Envelope Properties (19D990B45D535548840D1118C451C74DC8B74C3A47)

Subject: Talking point for the meeting on Feb 2
Sent Date: 1/26/2012 11:26:06 AM
Received Date: 1/26/2012 11:26:07 AM
From: Poole, Justin

Created By: Justin.Poole@nrc.gov

Recipients:

"WBN2HearingFile Resource" <WBN2HearingFile.Resource@nrc.gov>
Tracking Status: None
"Arent, Gordon" <garent@tva.gov>
Tracking Status: None
"Bryan, Robert H Jr" <rhbryan@tva.gov>
Tracking Status: None

Post Office: HQCLSTR02.nrc.gov

Files	Size	Date & Time
MESSAGE	1044	1/26/2012 11:26:07 AM

Options

Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received: