GENERAL EMERGENCY | SITE AREA EMERGENCY | ALERT | UNUSUAL EVENT

R – Abnorm. Rad Release / Rad Effluent

1 – Offsite Rad Conditions

General Emergency

None

RG1.2 1 2 3 4 D

Dose assessment using actual meteorology indicates doses > 1,000 mRem TEDE or 5,000 mRem thyroid CDE at or beyond the SITE BOUNDARY

RG1.3 1 2 3 4 D

Field survey results indicate closed window dose rates > 1,000 mRem/hr expected to continue for ≥ 60 min. at or beyond the SITE BOUNDARY (Note 1)
OR
Analyses of field survey samples indicate thyroid CDE > 5,000 mRem for 1 hr of inhalation at or beyond the SITE BOUNDARY (Note 1)

Site Area Emergency

RS1.1 1 2 3 4 D

ANY monitor reading > Table R-1 "SAE" column for ≥ 15 min. (Note 1)
- Do **not** delay declaration awaiting dose assessment results
- If dose assessment results are available, declaration should be based on dose assessment instead of radiation monitor values (see EAL RS1.2)

RS1.2 1 2 3 4 D

Dose assessment using actual meteorology indicates doses > 100 mRem TEDE or 500 mRem thyroid CDE at or beyond the SITE BOUNDARY

RS1.3 1 2 3 4 D

Field survey results indicate closed window dose rates > 100 mRem/hr expected to continue for ≥ 60 min. at or beyond the SITE BOUNDARY (Note 1)
OR
Analyses of field survey samples indicate thyroid CDE > 500 mRem for 1 hr of inhalation at or beyond the SITE BOUNDARY (Note 1)

Alert

RA1.1 1 2 3 4 D

ANY gaseous monitor reading > Table R-1 "Alert" column for ≥ 15 min. (Note 2)

RA1.2 1 2 3 4 D

ANY liquid monitor reading > Table R-1 "Alert" column for ≥ 15 min. (Note 2)

RA1.3 1 2 3 4 D

Confirmed sample analyses for gaseous or liquid releases indicate concentrations or release rates > 200 x ODCM limits for ≥ 15 min. (Note 2)

None

None

Unusual Event

RU1.1 1 2 3 4 D

ANY gaseous monitor reading > Table R-1 "UE" column for ≥ 60 min. (Note 2)

RU1.2 1 2 3 4 D

ANY liquid monitor reading > Table R-1 "UE" column for ≥ 60 min. (Note 2)

RU1.3 1 2 3 4 D

Confirmed sample analyses for gaseous or liquid releases indicate concentrations or release rates > 2 x ODCM limits for ≥ 60 min. (Note 2)

None

None

2 – Onsite Rad Conditions & Spent Fuel Events

Table R-1 Effluent Monitor Classification Thresholds

	Monitor	GE	SAE	ALERT	UE
GASEOUS	Stack (RN 10A/B)	N/A	N/A	3.0E4 cps	300 cps
GASEOUS	EC Vent	N/A	300 mRem/hr	30 mRem/hr	10 mRem/hr
LIQUID	SW Effluent	N/A	N/A	90,000 cpm	900 cpm
LIQUID	RW Discharge	N/A	N/A	200 x batch	2 x batch

Alert

RA2.1 1 2 3 4 D

Alarm on **ANY** of the following radiation monitors due to damage to irradiated fuel or loss of water level:
- ARM 18 (West end of shield wall)
- ARM 25 (Rx building - east wall)
- ARM 29 (Refuel bridge (LOW RANGE))
- Refuel Bridge (HIGH RANGE)
- Reactor Building Vent Radiation Monitor

RA2.2 1 2 3 4 D

A water level drop in a reactor refueling pathway that will result in irradiated fuel becoming uncovered

Unusual Event

RU2.1 1 2 3 4 D

UNPLANNED water level drop in a reactor refueling pathway as indicated by inability to restore and maintain SFP level > low water level alarm (Note 3)
AND
Area radiation monitor reading rise on **ANY** of the following:
- ARM 18 (West end of shield wall)
- ARM 25 (Rx building - east wall)
- ARM 29 (Refuel bridge (LOW RANGE))
- Refuel Bridge (HIGH RANGE)

RU2.2 1 2 3 4 D

UNPLANNED area radiation readings rise by a factor of 1,000 over NORMAL LEVELS

3 – CR/CAS Rad

General Emergency: None

Site Area Emergency: None

RA3.1 1 2 3 4 D

Dose rates > 15 mRem/hr in **EITHER** of the following areas requiring continuous occupancy to maintain plant safety functions:
Control Room
OR
CAS

H – Hazards & Other Conditions Affecting Plant Safety

1 – Natural or Destructive Phenomena

Table H-1 Safe Shutdown Areas

- Reactor Building (including Primary Containment)
- Control Room
- Screenhouse
- Turbine Building
  - Battery Rooms
  - Battery Board Rooms
  - Cable Spreading Room
  - Main Steam Isolation Valve Room
  - Diesel Generator Engine and Board Rooms
- Security
  - Central Alarm Station
  - Secondary Alarm Station
  - Security Uninterruptible Power Supply Room

Notes

1. The ED should **not** wait until the applicable time has elapsed, but should declare the event as soon as it is determined that the condition will likely exceed the applicable time
2. The ED should **not** wait until the applicable time has elapsed, but should declare the event as soon as it is determined that the release duration has exceeded, or will likely exceed, the applicable time. In the absence of data to the contrary, assume that the release duration has exceeded the applicable time if an ongoing release is detected and the release start time is unknown.
3. If loss of water level in the refueling pathway occurs while in Mode 3, 4 or D, consider classification under EALs CU3.1, CU3.2 or CU3.3
4. The ED should **not** wait until the applicable time has elapsed, but should declare the event as soon as it is determined that the condition has exceeded, or will likely exceed, the applicable time.
5. If the equipment in the stated area was already inoperable, or out of service, before the event occurred, then EAL HA3.1 should **not** be declared as it will have **no** adverse impact on the ability of the plant to safely operate or safely shutdown beyond that already allowed by Technical Specifications at the time of the event.

Alert

HA1.1 1 2 3 4 D

NMP-2 seismic instrumentation indicates > 0.075 g
AND
Earthquake confirmed by **ANY** of the following:
- Earthquake felt in plant
- JAFNPP seismic instrumentation
- Control Room indication of degraded performance of systems required for the safe shutdown of the plant

HA1.2 1 2 3 4 D

Tornado striking
OR
Sustained high winds > 90 mph
resulting in **EITHER**:
VISIBLE DAMAGE to **ANY** SAFETY-RELATED STRUCTURE, SYSTEM or COMPONENT within **ANY** Table H-1 area
OR
Control Room indication of degraded performance of **ANY** SAFETY-RELATED STRUCTURE, SYSTEM or COMPONENT within **ANY** Table H-1 area

HA1.3 1 2 3 4 D

Internal flooding
resulting in **EITHER**:
An electrical shock hazard that precludes access to operate or monitor **ANY** SAFETY-RELATED STRUCTURE, SYSTEM or COMPONENT within **ANY** Table H-1 area
OR
Control Room indication of degraded performance of **ANY** SAFETY-RELATED STRUCTURE, SYSTEM or COMPONENT within **ANY** Table H-1 area

HA1.4 1 2 3 4 D

Turbine failure-generated PROJECTILEs
resulting in **EITHER**:
VISIBLE DAMAGE to or penetration of **ANY** SAFETY-RELATED STRUCTURE, SYSTEM or COMPONENT within **ANY** Table H-1 area
OR
Control Room indication of degraded performance of **ANY** SAFETY-RELATED STRUCTURE, SYSTEM or COMPONENT within ANY Table H-1 area

HA1.5 1 2 3 4 D

Lake water level > 254 ft
OR
Intake water level < 236 ft

HA1.6 1 2 3 4 D

Vehicle crash
resulting in **EITHER**:
VISIBLE DAMAGE to **ANY** SAFETY-RELATED STRUCTURE, SYSTEM or COMPONENT within **ANY** Table H-1 area
OR
Control Room indication of degraded performance of **ANY** SAFETY-RELATED STRUCTURE, SYSTEM or COMPONENT within **ANY** Table H-1 area

Unusual Event

HU1.1 1 2 3 4 D

Seismic event identified by **ANY two** of the following:
- Annunciator H2-1-6 SEISMIC DETECTION EQUIPMENT EVENT indicates seismic event detected
- Confirmation of earthquake received on NMP-2 or JAFNPP seismic instrumentation
- Earthquake felt in plant

HU1.2 1 2 3 4 D

Tornado striking within PROTECTED AREA boundary
OR
Sustained high winds > 90 mph

HU1.3 1 2 3 4 D

Internal flooding that has the potential to affect **ANY** SAFETY-RELATED STRUCTURE, SYSTEM, OR COMPONENT required by Technical Specifications for the current operating mode in **ANY** Table H-1 area

HU1.4 1 2 3 4 D

Turbine failure resulting in **ANY** of the following:
- Casing penetration
- Damage to turbine seals
- Damage to generator seals

HU1.5 1 2 3 4 D

Lake water level > 248.2 ft
OR
Intake water level < 238.8 ft

2 – Fire or Explosion

General Emergency: None

Site Area Emergency: None

HA2.1 1 2 3 4 D

FIRE or EXPLOSION
resulting in **EITHER**:
VISIBLE DAMAGE to **ANY** SAFETY-RELATED STRUCTURE, SYSTEM or COMPONENT within **ANY** Table H-1 area
OR
Control Room indication of degraded performance of **ANY** SAFETY-RELATED STRUCTURE, SYSTEM or COMPONENT within **ANY** Table H-1 area

HU2.1 1 2 3 4 D

FIRE **not** extinguished within 15 min. of Control Room notification or verification of a Control Room FIRE alarm in **ANY** Table H-1 area, RadWaste Solidification and Storage Bldg, or Security West Bldg (Note 4)

HU2.2 1 2 3 4 D

EXPLOSION of sufficient force to damage permanent structures or equipment within the PROTECTED AREA

3 – Hazardous Gas

General Emergency: None

Site Area Emergency: None

HA3.1 1 2 3 4 D

Access to **ANY** Table H-1 area is prohibited due to toxic, corrosive, asphyxiant or flammable gases which jeopardize operation of **ANY** SAFETY-RELATED STRUCTURE, SYSTEM or COMPONENT (Note 5)

HU3.1 1 2 3 4 D

Toxic, corrosive, asphyxiant or flammable gases in amounts that have or could adversely affect NORMAL PLANT OPERATIONS

HU3.2 1 2 3 4 D

Recommendation by local, county or state officials to evacuate or shelter site personnel based on an offsite event

4 – Security

HG4.1 1 2 3 4 D

A HOSTILE ACTION has occurred such that plant personnel are unable to operate equipment required to maintain safety functions

HG4.2 1 2 3 4 D

A HOSTILE ACTION has caused failure of Spent Fuel Cooling systems
AND
IMMINENT fuel damage is likely

HS4.1 1 2 3 4 D

A HOSTILE ACTION is occurring or has occurred within the PROTECTED AREA as reported by the Security Site Supervisor

HA4.1 1 2 3 4 D

A HOSTILE ACTION is occurring or has occurred within the Owner Controlled Area as reported by the Security Site Supervisor
OR
A validated notification from NRC of an AIRLINER attack threat within 30 min. of the site

HU4.1 1 2 3 4 D

A SECURITY CONDITION that does **not** involve a HOSTILE ACTION as reported by the Security Site Supervisor
OR
A credible site-specific security threat notification
OR
A validated notification from NRC providing information of an aircraft threat

5 – Control Room Evacuation

General Emergency: None

HS5.1 1 2 3 4 D

Control Room evacuation has been initiated
AND
Control of the plant **cannot** be established within 15 min. ~~(Note 4)~~

HA5.1 1 2 3 4 D

Control Room evacuation has been initiated

Unusual Event: None

6 – Judgment

HG6.1 1 2 3 4 D

Other conditions exist which in the judgment of the Emergency Director indicate that events are in progress or have occurred which involve actual or IMMINENT substantial core degradation or melting with potential for loss of containment integrity or HOSTILE ACTION that results in an actual loss of physical control of the facility. Releases can be reasonably expected to exceed EPA Protective Action Guideline exposure levels (1,000 mRem TEDE or 5,000 mRem thyroid CDE) offsite for more than the immediate site area

HS6.1 1 2 3 4 D

Other conditions exist which in the judgment of the Emergency Director indicate that events are in progress or have occurred which involve actual or likely major failures of plant functions needed for protection of the public or HOSTILE ACTION that results in intentional damage or malicious acts; (1) toward site personnel or equipment that could lead to the likely failure of or; (2) that prevent effective access to equipment needed for the protection of the public. **ANY** releases are **not** expected to result in exposure levels which exceed EPA Protective Action Guideline exposure levels (1,000 mRem TEDE or 5,000 mRem thyroid CDE) beyond the SITE BOUNDARY

HA6.1 1 2 3 4 D

Other conditions exist which in the judgment of the Emergency Director indicate that events are in progress or have occurred which involve an actual or potential substantial degradation of the level of safety of the plant or a security event that involves probable life threatening risk to site personnel or damage to site equipment because of HOSTILE ACTION. **ANY** releases are expected to be limited to small fractions of the EPA Protective Action Guideline exposure levels (1,000 mRem TEDE or 5,000 mRem thyroid CDE)

HU6.1 1 2 3 4 D

Other conditions exist which in the judgment of the Emergency Director indicate that events are in progress or have occurred which indicate a potential degradation of the level of safety of the plant or indicate a security threat to facility protection has been initiated. **No** releases of radioactive material requiring offsite response or monitoring are expected unless further degradation of safety systems occurs

E – ISFSI

General Emergency: None

Site Area Emergency: None

Alert: None

EU1.1 1 2 3 4 D

Damage to a loaded cask CONFINEMENT BOUNDARY as indicated by measured dose rates > then **ANY** of the following:
- 400 mRem/hr at 3 feet from the HSM surface
- 100 mRem/hr outside HSM door on centerline
- 20 mRem/hr end shield wall exterior

Modes: 1 Power Operation | 2 Hot Shutdown | 3 Cold Shutdown | 4 Refuel | D Defueled

Constellation Energy
Nine Mile Point Nuclear Station Unit 1

EPIP-EP-001
Attachment 1
EAL Matrix Unit 1
Page 2 of 2

Approved: ______ Director, Emergency Planning ______ Date

Prepared for Constellation by: Operations Support Services, Inc. - www.ossi-net.com (Draft F 4/15/11)

D02

GENERAL EMERGENCY | SITE AREA EMERGENCY | ALERT | UNUSUAL EVENT

C – Cold SD/ Refuel System Malfunct.

1 – Loss of AC Power

Table C-1 AC Power Sources

- Onsite
  - DG102
  - DG103
- Offsite
  - T-101N
  - T-101S
  - T-10 backfed from offsite through T-1 or T-2 (**only** if already aligned)

CA1.1 3 4 D

Loss of **all** offsite and **all** onsite AC power, Table C-1, to 4.16 kV emergency buses for ≥ 15 min. (Note 4)

CU1.1 3 4 D

AC power capability to 4.16 kV emergency buses reduced to a single power source, Table C-1, for ≥ 15 min. (Note 4)
AND
ANY additional single power source failure will result in a loss of **all** 4.16 kV emergency bus power

2 – Loss of DC Power

Alert: None

CU2.1 3 4

< 106 VDC on **required** 125 VDC buses (Battery board 11, Battery board 12) for ≥ 15 min. (Note 4)

3 – RPV Water Level

CG3.1 3 4

RPV water level < -84 in. for ≥ 30 min. (Note 4)
AND
ANY Containment Challenge Indication, Table C-3

CG3.2 3 4

RPV water level **cannot** be monitored with core uncovery indicated by **ANY** of the following for ≥ 30 min. (Note 4):
- **ANY** UNPLANNED RPV leakage indication, Table C-2
- Erratic Source Range Monitor indication

AND
ANY Containment Challenge Indication, Table C-3

CS3.1 3 4

With CONTAINMENT CLOSURE **not** established, RPV water level < -1 in.

CS3.2 3 4

With CONTAINMENT CLOSURE established, RPV water level < -84 in.

CS3.3 3 4

RPV water level **cannot** be monitored for ≥ 30 min. (Note 4) with a loss of RPV inventory as indicated by **ANY** of the following:
- **ANY** UNPLANNED RPV leakage indication, Table C-2
- Erratic Source Range Monitor indication

CA3.1 3 4

RPV water level < +5 in.
OR
RPV water level **cannot** be monitored for ≥ 15 min. with **ANY** UNPLANNED RPV leakage indication, Table C-2 (Note 4)

CU3.1 3

RCS leakage results in the inability to maintain or restore RPV water level > +53 in. for ≥ 15 min. (Note 4)

CU3.2 4

UNPLANNED RPV water level drop below **EITHER** of the following for ≥ 15 min. (Note 4):
- 0 ft Flange Level (RPV flange)
- RPV water level band (when the RPV water level band is established below the RPV flange)

CU3.3 4

RPV water level **cannot** be monitored with a loss of RPV inventory as indicated by **ANY** UNPLANNED RPV leakage indication, Table C-2

Table C-2 RPV Leakage Indications

- Drywell equipment drain tank level rise
- Drywell floor drain tank level rise
- Reactor building equipment sump level rise
- Reactor Building floor drain sump level rise
- Torus water level rise
- UNPLANNED rise in RPV make-up rate
- Observation of UNISOLABLE RCS leakage

4 – RCS Temp.

Table C-3 Containment Challenge Indications

- CONTAINMENT CLOSURE **not** established
- Explosive mixture exists inside Primary Containment ($H_2 \geq 6\%$ and $O_2 \geq 5\%$)
- UNPLANNED rise in Primary Containment pressure
- RB area radiation > 8 R/hr

CA4.1 3 4

An UNPLANNED event results in **EITHER**:
RCS temperature > 212°F for > Table C-4 duration
OR
RPV pressure increase > 10 psi due to an UNPLANNED loss of decay heat removal capability

CU4.1 3 4

Unplanned event results in RCS temperature > 212°F

CU4.2 3 4

Loss of **all** RCS temperature and RPV water level indication for ≥ 15 min. (Note 4)

5 – Inadvertent Criticality

CU5.1 3 4

An UNPLANNED sustained positive period observed on nuclear instrumentation

6 – Comm.

Table C-4 RCS Reheat Duration Thresholds

RCS Status	CONTAINMENT CLOSURE Status	Duration
INTACT	N/A	60 min.*
Not INTACT	Established	20 min.*
	Not established	0 min.

* If an RCS heat removal system is in operation within this time frame and RCS temperature is being reduced, the EAL is **not** applicable

Table C-5 Communications Systems

System	Onsite (internal)	Offsite (external)
PBX (normal dial telephones)	X	X
Gaitronics	X	
Hand-Held Portable Radio (station radio)	X	
Control Room installed satellite phones (non portable)		X
ENS		X
RECS		X
~~UHF radios~~		~~X~~

CU6.1 3 4 D

Loss of **all** Table C-5 onsite (internal) communication methods affecting the ability to perform routine operations
OR
Loss of **all** Table C-5 offsite (external) communication methods affecting the ability to perform offsite notifications

EAL Identifier

XXX.X

- Category (R, H, E, S, F, C)
- Emergency classification (G, S, A, U)
- Subcategory number (1 if no subcategory)
- Sequential number within subcategory/classification

MODE 3, 4 or D