

**Levy Nuclear Plant Units 1 and 2
COL Application
Part 2, Final Safety Analysis Report**

CHAPTER 15
ACCIDENT ANALYSES

TABLE OF CONTENTS

<u>Section</u>	<u>Title</u>	<u>Page</u>
15.0	ACCIDENT ANALYSES	15.0-1
15.0.3.2	Initial Conditions.....	15.0-1
15.0.15	COMBINED LICENSE INFORMATION	15.0-1
15.0.16	REFERENCES.....	15.0-1
15.1	INCREASE IN HEAT REMOVAL FROM THE PRIMARY SYSTEM	15.1-1
15.2	DECREASE IN HEAT REMOVAL BY THE SECONDARY SYSTEM	15.2-1
15.3	DECREASE IN REACTOR COOLANT SYSTEM FLOW RATE ...	15.3-1
15.4	REACTIVITY AND POWER DISTRIBUTION ANOMALIES.....	15.4-1
15.5	INCREASE IN REACTOR COOLANT INVENTORY	15.5-1
15.6	DECREASE IN REACTOR COOLANT INVENTORY	15.6-1
15.6.5.3.7.3	Atmospheric Dispersion Factors	15.6-1
15.7	RADIOACTIVE RELEASE FROM A SUBSYSTEM OR COMPONENT	15.7-1
15.7.6	COMBINED LICENSE INFORMATION	15.7-1
15.8	ANTICIPATED TRANSIENTS WITHOUT SCRAM	15.8-1
APP. 15A	EVALUATION MODELS AND PARAMETERS FOR ANALYSIS OF RADIOLOGICAL CONSEQUENCES OF ACCIDENTS	15A-1
15A.3.3	ATMOSPHERIC DISPERSION FACTORS.....	15A-1
APP. 15B	REMOVAL OF AIRBORNE ACTIVITY FROM THE CONTAINMENT ATMOSPHERE FOLLOWING A LOCA.....	15B-1

**Levy Nuclear Plant Units 1 and 2
COL Application
Part 2, Final Safety Analysis Report**

LIST OF TABLES

Number

Title

None

**Levy Nuclear Plant Units 1 and 2
COL Application
Part 2, Final Safety Analysis Report**

LIST OF FIGURES

Number

Title

None

**Levy Nuclear Plant Units 1 and 2
COL Application
Part 2, Final Safety Analysis Report**

CHAPTER 15

ACCIDENT ANALYSES

15.0 ACCIDENT ANALYSES

This **section** of the referenced DCD is incorporated by reference with the following departures and/or supplements.

15.0.3.2 Initial Conditions

Add the following paragraph at the end of DCD **Subsection 15.0.3.2**.

STD COL 15.0-1 The plant operating instrumentation selected for feedwater flow measurement is a Caldon [Cameron] LEFM CheckPlus System (**Reference 201**), which will be calibrated (in a certified laboratory using a piping configuration representative of the plant piping design) prior to installation and will be tested after installation in the plant in accordance with the LEFM CheckPlus commissioning procedure. This selected plant operating instrumentation has documented instrumentation uncertainties to calculate a power calorimetric uncertainty that confirms the 1% uncertainty assumed for the initial reactor power in the safety analysis bounds the calculated calorimetric power uncertainty values. The calculated calorimetric is done in accordance with a previously accepted Westinghouse methodology (**Reference 202**). Administrative controls implement maintenance and contingency activities related to the power calorimetric instrumentation.

15.0.15 COMBINED LICENSE INFORMATION

Add the following text to the end of DCD **Subsection 15.0.15.1**.

STD COL 15.0-1 This COL item is addressed in FSAR **Subsection 15.0.3.2**.

15.0.16 REFERENCES

Add the following text to the end of DCD **Subsection 15.0.16**.

201. Final Safety Evaluation for Cameron Measurement Systems Engineering Report ER-157P, Revision 8, "Caldon Ultrasonics Engineering Report ER-157P, 'Supplement to Topical Report ER-80P: Basis for a Power Uprate with the LEFM Check or Checkplus™ System'," (TAC No. ME1321). August 16, 2010. ADAMS Accession No. ML102160694.

Levy Nuclear Plant Units 1 and 2
COL Application
Part 2, Final Safety Analysis Report

202. Final Safety Evaluation for Beaver Valley Power Station, Unit Nos. 1 and 2 (BVPS-1 and 2) - Issuance of Amendment re: 1.4-Percent Power Uprate and Revised BVPS-2 Heatup and Cooldown Curves. September 24, 2001, ADAMS Accession No. ML012490569.

**Levy Nuclear Plant Units 1 and 2
COL Application
Part 2, Final Safety Analysis Report**

15.1 INCREASE IN HEAT REMOVAL FROM THE PRIMARY SYSTEM

This **section** of the referenced DCD is incorporated by reference with no departures or supplements.

Levy Nuclear Plant Units 1 and 2
COL Application
Part 2, Final Safety Analysis Report

15.2 DECREASE IN HEAT REMOVAL BY THE SECONDARY SYSTEM

This **section** of the referenced DCD is incorporated by reference with no departures or supplements.

**Levy Nuclear Plant Units 1 and 2
COL Application
Part 2, Final Safety Analysis Report**

15.3 DECREASE IN REACTOR COOLANT SYSTEM FLOW RATE

This **section** of the referenced DCD is incorporated by reference with no departures or supplements.

**Levy Nuclear Plant Units 1 and 2
COL Application
Part 2, Final Safety Analysis Report**

15.4 REACTIVITY AND POWER DISTRIBUTION ANOMALIES

This **section** of the referenced DCD is incorporated by reference with no departures or supplements.

**Levy Nuclear Plant Units 1 and 2
COL Application
Part 2, Final Safety Analysis Report**

15.5 INCREASE IN REACTOR COOLANT INVENTORY

This **section** of the referenced DCD is incorporated by reference with no departures or supplements.

**Levy Nuclear Plant Units 1 and 2
COL Application
Part 2, Final Safety Analysis Report**

15.6 DECREASE IN REACTOR COOLANT INVENTORY

This **section** of the referenced DCD is incorporated by reference with the following departures and/or supplements.

15.6.5.3.7.3 Atmospheric Dispersion Factors

Add the following paragraph at the end of DCD **Subsection 15.6.5.3.7.3**.

LNP COL 2.3-4

Site-specific χ/Q (atmospheric dilution factor) values provided in **Subsection 2.3.4** are bounded by the values given in DCD **Table 15A-5** and **Table 15A-6**.

**Levy Nuclear Plant Units 1 and 2
COL Application
Part 2, Final Safety Analysis Report**

15.7 RADIOACTIVE RELEASE FROM A SUBSYSTEM OR COMPONENT

This **section** of the referenced DCD is incorporated by reference with the following departures and/or supplements.

15.7.6 COMBINED LICENSE INFORMATION

LNP COL 15.7-1

This COL Item is addressed in **Section 2.4.13**.

**Levy Nuclear Plant Units 1 and 2
COL Application
Part 2, Final Safety Analysis Report**

15.8 ANTICIPATED TRANSIENTS WITHOUT SCRAM

This **section** of the referenced DCD is incorporated by reference with no departures or supplements.

**Levy Nuclear Plant Units 1 and 2
COL Application
Part 2, Final Safety Analysis Report**

APPENDIX 15A EVALUATION MODELS AND PARAMETERS FOR
ANALYSIS OF RADIOLOGICAL CONSEQUENCES OF
ACCIDENTS

This **section** of the referenced DCD is incorporated by reference with the following departures and/or supplements.

15A.3.3 ATMOSPHERIC DISPERSION FACTORS

Replace the third paragraph in DCD **Subsection 15A.3.3** with the following:

LNP COL 2.3-4

Site-specific χ/Q values provided in **Subsection 2.3.4** are bounded by the values given in DCD **Table 15A-5** and **Table 15A-6**.

**Levy Nuclear Plant Units 1 and 2
COL Application
Part 2, Final Safety Analysis Report**

**APPENDIX 15B REMOVAL OF AIRBORNE ACTIVITY FROM THE
CONTAINMENT ATMOSPHERE FOLLOWING A LOCA**

This **section** of the referenced DCD is incorporated by reference with no departures or supplements.