



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

February 16, 2012

Mr. Preston Gillespie
Site Vice President
Oconee Nuclear Station
Duke Energy Carolinas, LLC
7800 Rochester Highway
Seneca, SC 29672

SUBJECT: OCONEE NUCLEAR STATION, UNITS 1, 2, AND 3 (ONS) - REQUEST FOR ADDITIONAL INFORMATION (RAI) REGARDING THE LICENSE AMENDMENT REQUESTS (LARs) FOR UPGRADING THE LICENSING BASIS FOR HIGH ENERGY LINE BREAK (HELB) MITIGATION (TAC NOS. ME7737, ME7738, ME7739, ME7743, ME7744, ME7745, ME7746, ME7747, AND ME7748)

Dear Mr. Gillespie:

By letter dated December 16, 2011, as supplemented January 16, 2012, Duke Energy Carolinas, LLC (the licensee), resubmitted LARs for ONS which propose revisions to the current licensing basis regarding HELB mitigating strategies. The above LAR and supplement supersede the previous LARs submitted by the licensee associated with the HELB mitigating strategies dated June 26, 2008, December 22, 2008, and June 29, 2009.

The U.S. Nuclear Regulatory Commission (NRC) staff is in the process of reviewing the LARs, and has determined that additional information is required in order to complete the review. The RAI is enclosed. The draft RAI was provided to your staff electronically, and telephone calls between your staff and the NRC staff have occurred to ensure that the right level of detail is provided in the RAI responses. Please provide a response to the RAI 30 days after the receipt of this letter. If you cannot respond within 30 days please provide the reason and a schedule of when you can respond to the RAI.

If you have any questions, please contact me at 301-415-1345.

Sincerely,

A handwritten signature in black ink, appearing to read "John Stang", is written over the word "Sincerely,".

John Stang, Senior Project Manager
Plant Licensing Branch II-1
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket Nos. 50-269, 50-270, and 50-287

Enclosure: As Stated

cc w/encl: Distribution via Listserv

REQUEST FOR ADDITIONAL INFORMATION (RAI)
LICENSE AMENDMENT REQUESTS (LARs)
TO REVISE PORTIONS OF THE UPDATED FINAL SAFETY ANALYSIS REPORT (UFSAR)
RELATED TO THE
HIGH ENERGY LINE BREAK (HELB) MITIGATION LICENSING BASIS
DUKE ENERGY CAROLINAS, LLC
OCONEE NUCLEAR STATION, UNITS 1, 2, AND 3 (ONS)
DOCKET NOS. 50-269, 50-270, AND 50-287

By letters dated June 26, 2008, December 22, 2008, and June 29, 2009, to the U.S. Nuclear Regulatory Commission (NRC) (Agencywide Documents Access and Management System, (ADAMS) Accession Nos. ML081910559, ML090020355, and ML091870501, respectively), Duke Energy Carolinas, LLC (the licensee, Duke), submitted LARs for ONS, which proposed revisions to the current licensing basis regarding HELB mitigating strategies. By letter dated December 16, 2011 (ADAMS Accession No. ML12003A070), as supplemented January 20, 2012 (ADAMS Accession No. ML12025A124), the licensee submitted a LAR and supplemental information which has superseded all the above LARs.

The NRC staff is in the process of reviewing the LAR, and has determined that the following RAI is required in order to complete the review.

[H] RAI 109

Provide the following information associated with the protected service water (PSW) system modification:

- a. Provide all proposed UFSAR pages for the PSW system modification including piping and instrumentation drawing showing all pumps, valves, pump design data, and the pump performance curves.
- b. Provide the proposed changes to UFSAR Section 3.2.2 for PSW system, and the American Society for Mechanical Engineers (ASME) *Boiler and Pressure Vessel Code* (Code) classification for PSW system pumps and valves.
- c. Provide the proposed changes to the inservice testing (IST) program for the PSW system including any bases for excluding any PSW pumps and valves from IST program.

- d. Provide the proposed changes to the motor operated valve programs associated with the PSW system modifications related to Generic Letter (GL) 89-10 "Safety-Related Motor-Operated Valve Testing and Surveillance," GL 95-07 "Pressure Locking and Thermal Binding of Safety-Related Power-Operated Gate Valves," and GL 96-05 "Periodic Verification of Design-Basis Capability of Safety-Related Power-Operated Valves."
- e. Will there be any relief requested from ASME Operations and Maintenance Code requirements associated with the PSW system modification?

February 16, 2012

Mr. Preston Gillespie
Site Vice President
Oconee Nuclear Station
Duke Energy Carolinas, LLC
7800 Rochester Highway
Seneca, SC 29672

SUBJECT: OCONEE NUCLEAR STATION, UNITS 1, 2, AND 3 (ONS) - REQUEST FOR ADDITIONAL INFORMATION (RAI) REGARDING THE LICENSE AMENDMENT REQUESTS (LARs) FOR UPGRADING THE LICENSING BASIS FOR HIGH ENERGY LINE BREAK (HELB) MITIGATION (TAC NOS. ME7737, ME7738, ME7739, ME7743, ME7744, ME7745, ME7746, ME7747, AND ME7748)

Dear Mr. Gillespie:

By letter dated December 16, 2011, as supplemented January 16, 2012, Duke Energy Carolinas, LLC (the licensee), resubmitted LARs for ONS which propose revisions to the current licensing basis regarding HELB mitigating strategies. The above LAR and supplement supersede the previous LARs submitted by the licensee associated with the HELB mitigating strategies dated June 26, 2008, December 22, 2008, and June 29, 2009.

The U.S. Nuclear Regulatory Commission (NRC) staff is in the process of reviewing the LARs, and has determined that additional information is required in order to complete the review. The RAI is enclosed. The draft RAI was provided to your staff electronically, and telephone calls between your staff and the NRC staff have occurred to ensure that the right level of detail is provided in the RAI responses. Please provide a response to the RAI 30 days after the receipt of this letter. If you cannot respond within 30 days please provide the reason and a schedule of when you can respond to the RAI.

If you have any questions, please contact me at 301-415-1345.

Sincerely,

/RA/

John Stang, Senior Project Manager
Plant Licensing Branch II-1
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket Nos. 50-269, 50-270, and 50-287
Enclosure: As Stated
cc w/encl: Distribution via Listserv

DISTRIBUTION:

PUBLIC LPL2-1 R/F
RidsNrrDorILp2-1

RidsAcraAcnw_MailCtr
RidsOgcRp

RidsNrrLASFigueroa
RidsDeEptb

RidsNrrPMOconee
RidsRgn2MailCenter

ADAMS Accession No. ML12047A177

***By E-mail**

OFFICE	NRR/LPL2-1/PM	NRR/LPL2-1/LA	NRR/EMCB/BC	NRR/LPL2-1/BC	NRR/LPL2-1/PM
NAME	JStang	SFigueroa	AMcMurtray	NSalgado (JThompson for)	JStang
DATE	02/16/12	02/16/12	02/13/12	02/16/12	02/16/12