



**INDIANA
MICHIGAN
POWER**

A unit of American Electric Power

Indiana Michigan Power
Cook Nuclear Plant
One Cook Place
Bridgman, MI 49106
AEP.com

January 20, 2012

AEP-NRC-2012-1
10 CFR 50.55a

Docket No.: 50-315

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555-0001

Donald C. Cook Nuclear Plant Unit 1
Form OAR-1 Owner's Activity Report

This letter provides a copy of Form OAR-1 Owner's Activity Report for inservice inspection activities performed at Donald C. Cook Nuclear Plant (CNP) Unit 1 through the completion of the U1C24 refueling outage. This report meets the requirements of the American Society of Mechanical Engineers (ASME) Code Case N-532-4, "Repair/Replacement Activity Documentation Requirements and Inservice Summary Report Preparation and Submission, Section XI, Division 1." This code case is used as an alternative to the requirements of the ASME Boiler and Pressure Vessel Code, Section XI, Article IWA-6000 as approved by Regulatory Guide 1.147, "Inservice Inspection Code Case Acceptability, ASME Section XI, Division 1, Revision 16."

The Authorized Code Inspection Company is OneCIS Insurance Co., of Lynn, Massachusetts. The Authorized Nuclear Inspector is Reuel Schenck.

There are no new or revised commitments in this letter. Should you have any questions, please contact Mr. Michael K. Scarpello, Regulatory Affairs Manager, at (269) 466-2649.

Sincerely,

Michael H. Carlson
Vice President - Site Support Services

DMB/jen

Enclosure: Form OAR-1 Owner's Activity Report for the Donald C. Cook Nuclear Plant Unit 1
Refueling Outage U1C24

A047
NRR

c: J. T. King – MPSC, w/o enclosure
S. M. Krawec - AEP Ft. Wayne, w/o enclosure
MDNRE – WHMD/RPS, w/o enclosure
NRC Resident Inspector
C. D. Pederson – NRC Region III
P. S. Tam – NRC Washington DC
W. Vallance – DLEG/BCCFS/BD

Enclosure to AEP-NRC-2012-1

FORM OAR-1 OWNER'S ACTIVITY REPORT FOR DONALD C. COOK NUCLEAR PLANT
UNIT 1 CYCLE 24 2011 REFUELING OUTAGE

D.C. Cook Nuclear Unit 1


Form OAR-1 Owner's Activity Report

Report Number	<u>1-2011-4-1-01</u>		
Plant	<u>Donald C Cook Nuclear Plant, One Cook Place, Bridgman, Michigan 49106</u> (Name and Address of Plant)		
Unit No.	<u>1</u> (if applicable)	Commercial Service Date	<u>8/23/1975</u> Refueling Outage No. <u>U1C24</u>
Current Inspection Interval	<u>4th for Components and Supports (C&S) and 2nd for Containment ISI (CISI) Program</u> (1st, 2nd, 3rd, 4th, other)		
Current Inspection Period	<u>1st for C&S and 1st for CISI</u> (1st, 2nd, 3rd)		
Edition and Addenda of Section XI applicable to the inspection plans	<u>2004 Edition/No Addenda</u>		
Date and Revision of inspection plans	<u>4/5/2011, Revision 2 for C&S, and 6/22/2011, Revision 1 for CISI</u>		
Edition and Addenda of Section XI applicable to repair/replacement activities, if different than the inspection plans Edition and Addenda are the same as the Inspection Plans			
Code Case used:	<u>N-526, N-566-2, N-586-1, N-624, N-648-1, N-716, N-722-1, N-729-1 for C&S and N-649 for CISI</u> (If applicable)		

CERTIFICATE OF CONFORMANCE

I certify that (a) the statements made in this report are correct; (b) the examinations and tests meet the Inspection Plan as required by the ASME Code, Section XI; and (c) the repair/replacement activities and evaluations supporting the completion of U1C24 conform to the requirements of Section XI. (Refueling Outage Number)

Signed

 (SUPERVISOR) FOR ROBURY RICKARD
Owners or Owner's Designee, Title (PROGRAM MANAGER)

Date

01/10/2012

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Michigan and employed by One CIS Insurance Co. of Lynn, MA have inspected the items described in this Owner's Activity Report, and state that, to the best of my knowledge and belief, the Owner has performed all activities represented by this report in accordance with the requirements of Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the repair/replacement activities and evaluation described in this report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or loss of any kind arising from or connected with this inspection.


Inspector's Signature

Commissions Michigan 300959, NB 11412, Endorsements: A, I, N & IS

National Board, State, Province, and Endorsements

Date

01-10-2012

Table 1

**Items with flaws or relevant conditions that
required evaluation for continued service**

Examination Category	Item Number	Item Description	Evaluation Description
N-729-1	B4.40	VE of Reactor Vessel Head with nozzles and partial penetration welds of PWSCC resistant materials	Evaluation of fibrous debris and staining. Evaluation concluded that material was indeed fibrous and not Boric Acid. Additionally the staining was determined to be from reactor head venting operations. Reference Work Order 55377628-01 for condition and evaluation.
B-P	B15.10	Evaluation of white substance at elbow on 1-NFP-222-V2	Evaluation concluded that the substance was not boric acid and no leakage was observed. Documented under AR 2011-12437.

D.C. Cook Nuclear Unit 1**Table 2****Abstract of repair/replacement activities
required for continued service**

Code Class	Item Description	Description of Work	Date Complete	Repair / Replacement Plan Number
1	Steam Generator 1-OME-3-1 Tube Plugging	Mechanical tube plugging of 8 tubes due to wear indications	10/7/11	Work Order Task 55315870-31
1	Steam Generator 1-OME-3-2 Tube Plugging	Mechanical tube plugging of 1 tubes due to wear indications	10/7/11	Work Order Task 55315871-18
1	Steam Generator 1-OME-3-3 Tube Plugging	Mechanical tube plugging of 11 tubes due to wear indications	10/8/11	Work Order Task 55315872-17
1	Steam Generator 1-OME-3-4 Tube Plugging	Mechanical tube plugging of 6 tubes due to wear indications	10/8/11	Work Order Task 55315873-17