



**UNITED STATES  
NUCLEAR REGULATORY COMMISSION**  
REGION II  
245 PEACHTREE CENTER AVENUE NE, SUITE 1200  
ATLANTA, GEORGIA 30303-1257

February 23, 2012

Mr. Thomas D. Gatlin  
Vice President - Nuclear Operations  
South Carolina Electric & Gas Company  
Virgil C. Summer Nuclear Station  
P.O. Box 88  
Jenkinsville, SC 29065

SUBJECT: VIRGIL C. SUMMER NUCLEAR STATION UNIT 1 - NOTIFICATION OF A  
TRIENNIAL FIRE PROTECTION BASELINE INSPECTION (NRC INSPECTION  
REPORT NO. 05000395/2012007)

Dear Mr. Gatlin:

The purpose of this letter is to notify you that the U.S. Nuclear Regulatory Commission (NRC) Region II staff will conduct a triennial fire protection baseline inspection at Virgil C. (V.C.) Summer Nuclear Station Unit 1, in May 2012. The inspection team will be lead by Mr. Gerald Wiseman, NRC Senior Reactor Inspector, of the Region II Office. The team will be composed of personnel from NRC Region II Office. The inspection will be conducted in accordance with Inspection Procedure 71111.05T, the NRC's triennial fire protection baseline inspection procedure dated October 28, 2011.

On February 22, 2012, during a telephone conversation between Mr. Eric Rumfelt (V.C. Summer Licensing Supervisor) of your staff, and Mr. Gerald Wiseman, our respective staffs confirmed arrangements for the following schedule for the inspection:

- Information gathering visit: April 24 - 26, 2012
- Week 1 of onsite inspection: May 07 -11, 2012
- Week 2 of onsite inspection: May 21 - 25, 2012

The purposes of the information gathering visit are to obtain information and documentation needed to support the inspection, to become familiar with the V.C. Summer Nuclear Station Unit 1 fire protection programs, fire protection features, post-fire safe shutdown capabilities, and plant layout, mitigating strategies to address Section B.5.b of NRC Order EA-02-026, "Order for Interim Safeguards and Security Compensatory Measures," dated February 25, 2002, and Title 10 of the *Code of Federal Regulations* (10 CFR) 50.54(hh)(2); and, as necessary, obtain plant-specific site access training and badging for unescorted site access. A list of the types of documents the team may be interested in reviewing, and possibly obtaining, are listed in

SCE&G

Enclosures 1 and 2. Please contact Mr. Wiseman prior to preparing copies of the materials listed in the Enclosures. The inspection team will try to minimize your administrative burden by specifically identifying those documents required for inspection preparation.

During the information gathering visit, the team will also discuss the following inspection support administrative details: office space size and location; specific documents requested to be made available to the team in its office spaces; arrangements for reactor site access (including radiation protection training, security, safety, and fitness for duty requirements); and the availability of knowledgeable plant engineering and licensing organization personnel to serve as points of contact during the inspection.

We request that, during the onsite inspection weeks, you ensure that copies of analyses, evaluations, or documentation regarding the implementation and maintenance of the V.C. Summer Nuclear Station fire protection program, including post-fire safe shutdown capability, be readily accessible to the team for their review. Of specific interest for the fire protection portion of the inspection are the documents that establish that your fire protection program satisfies NRC regulatory requirements and conforms to applicable NRC and industry fire protection guidance. For the B.5.b portion of the inspection, the documents implementing your mitigating strategies and demonstrating the management of your commitments for the strategies are of specific interest. Also, personnel should be available at the site during the inspection who are knowledgeable regarding those plant systems required to achieve and maintain safe shutdown conditions from inside and outside the control room (including the electrical aspects of the relevant post-fire safe shutdown analyses), reactor plant fire protection systems and features, and the V.C. Summer Nuclear Station fire protection program and its implementation.

This letter does not contain new or amended information collection requirements subject to the Paperwork Reduction Act of 1995 (44 U.S.C. 3501 et seq.). Existing information collection requirements were approved by the Office of Management and Budget, under control number 3150-0011. The NRC may not conduct or sponsor, and a person is not required to respond to, a request for information or an information collection requirement unless the requesting document displays a currently valid Office of Management and Budget control number.

Your cooperation and support during this inspection will be appreciated. If you have questions concerning this inspection, or the inspection team's information or logistical needs, please contact Mr. Gerald Wiseman, the team leader at (404) 997-4542, or me at (404) 997-4498.

SCE&G

In accordance with 10 CFR 2.390 of the NRC's "Rules of Practice," a copy of this letter, its enclosures will be available electronically for public inspection in the NRC Public Document Room or from the Publicly Available Records (PARS) component of NRC's document system (ADAMS). ADAMS is accessible from the NRC Web site at <http://www.nrc.gov/reading-rm/adams.html> <http://www.nrc.gov/reading-rm/adams.html> (the Public Electronic Reading Room).

Sincerely,

**/RA by Rebecca L. Nease for/**

Reinaldo Rodriguez, Acting Chief  
Engineering Branch 2  
Division of Reactor Safety

Docket No. 50-395  
License No. NPF-12

Enclosures:

1. Triennial Fire Protection Program Supporting Documentation
2. Mitigating Strategies Supporting Documentation

cc w/encl: (See page 4)

SCE&amp;G

In accordance with 10 CFR 2.390 of the NRC's "Rules of Practice," a copy of this letter, its enclosures will be available electronically for public inspection in the NRC Public Document Room or from the Publicly Available Records (PARS) component of NRC's document system (ADAMS). ADAMS is accessible from the NRC Web site at <http://www.nrc.gov/reading-rm/adams.html> <http://www.nrc.gov/reading-rm/adams.html> (the Public Electronic Reading Room).

Sincerely,

**/RA by Rebecca L. Nease for/**

Reinaldo Rodriguez, Acting Chief  
Engineering Branch 2  
Division of Reactor Safety

Docket No. 50-395  
License No. NPF-12

## Enclosures:

1. Triennial Fire Protection Program Supporting Documentation
2. Mitigating Strategies Supporting Documentation

cc w/encl: (See page 4)

Distribution w/encl:

G. McCoy, RII, DRP  
S. Ninh, RII, DRP  
RIDSNNRRDIRS  
PUBLIC  
RidsNrrPMSummer Resource

☒ PUBLICLY AVAILABLE☐ NON-PUBLICLY AVAILABLE☐ SENSITIVE☒ NON-SENSITIVEADAMS: ☒ Yes ACCESSION NUMBER: ML# 12054A684☐ SUNSI REVIEW COMPLETE ☒ FORM 665 ATTACHED

OFFICE	RII:DRS	RII:DRP	RII:DRS				
SIGNATURE	/RA/	/RA/	/RA R. Nease for/				
NAME	G. Wiseman	G. McCoy	R. Rodriguez				
DATE	2/22/2012	2/22/2012	2/23/2012				
E-MAIL COPY	<b>YES</b> NO	<b>YES</b> NO	<b>YES</b> NO				

OFFICIAL RECORD COPY DOCUMENT NAME: S:\DRS\ENG BRANCH 2\REPORTS\SUMMER\NOTIFICATION LETTER\SUMMER UNIT 1 IR 2012-007 TFPI NOTIFICATION LETTER-GRW.DOCX

SCE&G

cc w/encl:

J. B. Archie  
Senior Vice President  
Nuclear Operations and Chief Nuclear  
Officer  
South Carolina Electric & Gas Company  
Electronic Mail Distribution

George A. Lippard, III  
General Manager  
Nuclear Plant Operations  
South Carolina Electric & Gas Company  
Electronic Mail Distribution

Andy T. Barbee  
Director  
Nuclear Training  
South Carolina Electric & Gas Company  
Electronic Mail Distribution

Wayne D. Stuart  
(Acting) General Manager  
Engineering Services  
South Carolina Electric & Gas Company  
Electronic Mail Distribution

Robin R. Haselden  
General Manager  
Organizational Development &  
Effectiveness  
South Carolina Electric & Gas Company  
Electronic Mail Distribution

Shaun M. Zarandi  
General Manager  
Nuclear Support Services  
South Carolina Electric & Gas Company  
Electronic Mail Distribution

Robert L. Justice  
Manager  
Nuclear Operations  
South Carolina Electric & Gas Company

Donna W. Railey  
Licensing Technician  
Nuclear Licensing  
South Carolina Electric & Gas Company  
Electronic Mail Distribution

Robin J. White  
Nuclear Coordinator  
S.C. Public Service Authority Mail Code 802  
Electronic Mail Distribution

Susan E. Jenkins  
SC Department of Health & Environmental  
Control  
Bureau of Land and Waste Management  
Electronic Mail Distribution

Sandra Threath, Manager  
Nuclear Response and Emergency  
Environmental Surveillance  
Bureau of Land and Waste Management  
Department of Health and Environmental  
Control  
Electronic Mail Distribution

Kathryn M. Sutton, Esq.  
Morgan, Lewis & Bockius LLP  
Electronic Mail Distribution

Division of Radiological Health  
TN Dept. of Environment & Conservation  
401 Church Street  
Nashville, TN 37243-1532

Senior Resident Inspector  
Virgil C. Summer Nuclear Station  
U.S. NRC  
576 Stairway Road  
Jenkinsville, SC 29065

Bruce L. Thompson  
Manager  
Nuclear Licensing (Mail Code 830)  
South Carolina Electric & Gas Company  
Electronic Mail Distribution

### Triennial Fire Protection Program Supporting Documentation

Note: This is a broad list of the documents the NRC inspection team may be interested in reviewing, and possibly obtaining, during the information gathering site visit. Electronic media is preferred, if readily available. (The preferred file format on CD-ROM or DVDROM is “.pdf”). The CD/DVD-ROM should be indexed, hyperlinked, readable, and searchable to facilitate ease of use. Please provide 5 copies of each CD/DVD-ROM submitted. Information in “lists” should contain enough information to be easily understood by someone who has knowledge of the technology. The lead inspector will discuss specific information needs with the licensee staff and may request additional documents or electronic information.

1. The current version of the fire protection program and fire hazards analysis.
2. Corrective action closeouts as part of operator manual actions corrective actions.
3. List of identified fire induced circuit failure configurations for the selected fire areas/zones (to be determined during information gathering visit).
4. Corrective actions for fire-induced circuit failures, both single and multiple spurious actuations for the selected fire areas/zones (to be determined during information gathering visit).
5. Cable routing for components and equipment credited for safe shutdown for the selected fire areas/zones (to be determined during information gathering visit).
6. List of protected safe shutdown train equipment for the selected fire areas/zones (to be determined during information gathering visit).
7. Current versions of the fire protection program implementing procedures (e.g., administrative controls, surveillance testing, fire brigade).
8. Fire brigade training program and pre-fire plans.
9. Post-fire safe shutdown systems and separation analysis.
10. Post-fire alternative shutdown analysis.
11. Piping and instrumentation diagrams showing the components used to achieve and maintain hot standby and cold shutdown for fires outside the control room and those components used for those areas requiring alternative shutdown capability.
12. Plant layout and equipment drawings which identify the physical plant locations of hot standby and cold shutdown equipment.
13. Plant layout drawings which identify plant fire area delineation, areas protected by automatic fire suppression and detection, and the locations of fire protection equipment.
14. Plant layout drawings which identify the general location of the post-fire emergency lighting.
15. Plant operating procedures which would be used and describe shutdown from inside

Enclosure

the control room with a postulated fire occurring in any plant area outside the control room, procedures which would be used to implement alternative shutdown capability in the event of a fire in the control or cable spreading room.

16. Maintenance and surveillance testing procedures for alternative shutdown capability and fire barriers, detectors, pumps and suppression systems.
17. Maintenance procedures that routinely verify fuse breaker coordination in accordance with the post-fire safe shutdown coordination analysis.
18. A list of significant fire protection and post-fire safe shutdown related design change packages and evaluations according to Generic Letter 86-10, "Implementation of Fire Protection Requirements."
19. The reactor plant's Individual Plant Examination for External Events (IPEEE), results of any post-IPEEE reviews, and listings of actions taken/plant modifications conducted in response to IPEEE information.
21. Organization charts of site personnel (including fire protection staff personnel).
22. If applicable, drawings of potential reactor coolant/recirculation pump lube oil system leakage points and associated lube oil collection systems.
23. Licensing basis documents for fire protection (safety evaluation reports, pertinent sections of the final safety analysis report, exemptions, deviations, letters to/from the NRC regarding fire protection/fire safe shutdown, etc.).
24. Procedures/instructions that control the configuration of the plant's fire protection program, features, and post-fire safe shutdown methodology, and system design.
25. A list of applicable codes and standards related to the design of plant fire protection features and evaluations of code deviations.
26. Procedures/instructions that govern the implementation of plant modifications, maintenance, special operations, and their impact on fire protection.
27. Internal and external self-assessments, audits, peer-assessments or similar reviews related to post-fire safe shutdown capability or the fire protection program completed since the previous NRC fire protection triennial inspection.
28. Recent quality assurance surveillances of fire protection activities.
29. A listing of open and closed fire protection condition reports (problem reports/nuclear condition reports/event analysis reports/problem identification, and resolution reports) since the last triennial inspection.

### Mitigating Strategies Supporting Documentation

Note: This is a broad list of the documents the NRC inspection team may be interested in reviewing, and possibly obtaining, during the information gathering site visit. The current version of these documents is expected unless specified otherwise. Electronic media is preferred, if readily available. (The preferred file format on CD-ROM or DVDROM is ".pdf"). The CD/DVD-ROM should be indexed, hyperlinked, readable, and searchable to facilitate ease of use. Please provide 5 copies of each CD/DVD-ROM submitted. The lead inspector will discuss specific information needs with the licensee staff and may request additional documents or electronic information.

1. A list of all modifications to regulatory commitments made to meet the requirements of Section B.5.b of NRC Order, EA-02-026, "Order for NRC Interim Safeguards and Security Compensatory Measures," dated February 25, 2002, the subsequently imposed license conditions, and Title 10 of the *Code of Federal Regulations* (10 CFR) 50.54(hh)(2).
2. Lists of procedures/guidelines that were revised or generated to implement the mitigation strategies. These could be extensive damage mitigation guidelines (EDMGs), severe accident management guidelines (SAMGs), emergency operating procedures (EOPs), abnormal operating procedures (AOPs), etc.
3. A matrix that shows the correlation between the mitigation strategies identified in Nuclear Energy Institute 06-12, Revision 2, "B.5.b Phase 2 & 3 Submittal Guideline," issued December 2006, and the site-specific procedures or guidelines used to implement each strategy.
4. Engineering evaluations/calculations that were used to verify engineering bases for the mitigation strategies.
5. Piping and instrumentation diagram for systems relied upon in the mitigation strategies. These could be of the type used for training.
6. A list of modification packages or simplified drawings or descriptions of modifications that were made to plant systems to implement the mitigation strategies.
7. Copies of procedures used to inventory equipment (hoses, fittings, pumps, etc.) required to implement the mitigation strategies.
8. A list of B.5.b strategies, if any, that have implementing details that differ from those documented in the submittals and the safety evaluation report.
9. A copy of site general arrangement drawing(s) that show the majority of buildings/areas referenced in B.5.b documents.
10. Training records, training matrix, and lesson plans related to B.5.b.
11. Copies of Memoranda of Understanding (MOUs) (e.g., with local fire departments) required to implement any mitigating strategies.