

ArevaEPRDCPEm Resource

From: Tesfaye, Getachew
Sent: Friday, May 18, 2012 3:59 PM
To: 'usepr@areva.com'
Cc: Hernandez, Raul; McKenna, Eileen; Hearn, Peter; Segala, John; ArevaEPRDCPEm Resource
Subject: Draft - U.S. EPR Design Certification Application RAI No. 550 (6501), FSAR Ch. 9 - NEW PHASE 4 RAI - Fukushima
Attachments: Draft RAI_550_BPFP_6501.doc

Attached please find draft RAI No. 550 regarding your application for standard design certification of the U.S. EPR. If you have any question or need clarifications regarding this RAI, please let me know as soon as possible, I will have our technical Staff available to discuss them with you.

Please also review the RAI to ensure that we have not inadvertently included proprietary information. If there are any proprietary information, please let me know within the next ten days. If I do not hear from you within the next ten days, I will assume there are none and will make the draft RAI publicly available.

Thanks,
Getachew Tesfaye
Sr. Project Manager
NRO/DNRL/LB1
(301) 415-3361

Hearing Identifier: AREVA_EPR_DC_RAIs
Email Number: 3918

Mail Envelope Properties (0A64B42AAA8FD4418CE1EB5240A6FED17DB154E231)

Subject: Draft - U.S. EPR Design Certification Application RAI No. 550 (6501), FSAR Ch.
9 - NEW PHASE 4 RAI - Fukushima
Sent Date: 5/18/2012 3:58:32 PM
Received Date: 5/18/2012 3:58:52 PM
From: Tesfaye, Getachew

Created By: Getachew.Tesfaye@nrc.gov

Recipients:

"Hernandez, Raul" <Raul.Hernandez@nrc.gov>
Tracking Status: None
"McKenna, Eileen" <Eileen.McKenna@nrc.gov>
Tracking Status: None
"Hearn, Peter" <Peter.Hearn@nrc.gov>
Tracking Status: None
"Segala, John" <John.Segala@nrc.gov>
Tracking Status: None
"ArevaEPRDCPEm Resource" <ArevaEPRDCPEm.Resource@nrc.gov>
Tracking Status: None
"usepr@areva.com" <usepr@areva.com>
Tracking Status: None

Post Office: HQCLSTR02.nrc.gov

Files	Size	Date & Time
MESSAGE	897	5/18/2012 3:58:52 PM
Draft RAI_550_BPFP_6501.doc		30202

Options

Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received:

Draft

Request for Additional Information No. 550 (6501), Revision 0

5/18/2012

U. S. EPR Standard Design Certification

AREVA NP Inc.

Docket No. 52-020

SRP Section: 09.01.03 - Spent Fuel Pool Cooling and Cleanup System

Application Section: 9.1.3

QUESTIONS for Balance of Plant & Fire Protection Branch (BPFP)

09.01.03-16

Open Item

New Phase 4 RAI - Fukushima

Implementation of Fukushima Task Force Recommendation 7.1

Provide sufficient reliable instrumentation, able to withstand design-basis natural phenomena, and monitor spent fuel pool water level, as described in Attachment 3 to Order EA-12-051 (ML12054A679).