

ArevaEPRDCPEm Resource

From: WILLIFORD Dennis (AREVA) [Dennis.Williford@areva.com]
Sent: Tuesday, May 29, 2012 11:23 AM
To: Tesfaye, Getachew
Cc: BENNETT Kathy (AREVA); DELANO Karen (AREVA); ROMINE Judy (AREVA); RYAN Tom (AREVA)
Subject: Response to U.S. EPR Design Certification Application RAI No. 505 (5902,5735,5869,5754,5803,5950,5744), FSAR Ch. 7, Supplement 21
Attachments: RAI 505 Supplement 21 Response US EPR DC.pdf

Getachew,

On September 29, 2011, AREVA NP Inc. provided a schedule for technically correct and complete responses to the 34 questions in RAI 505. In Supplement 1 sent on October 27, 2011, and Supplement 2 sent on November 17, 2011, AREVA NP provided a revised schedule for technically correct and complete responses to 33 questions and a preliminary revised schedule for Question 07.01-33. AREVA NP provided Supplement 3 on November 22, 2011 to provide a final response to 4 questions. On December 9, 2011, AREVA NP provided Supplement 4 to revise the schedule for 7 questions. On December 14, 2011, AREVA NP provided Supplement 5 to revise the schedule for 5 questions. On December 15, 2011, AREVA NP provided Supplement 6 to provide a complete and final response to 6 questions. On January 10, 2012, AREVA NP provided Supplement 7 to provide a complete and final response to 2 questions. On January 19, 2012, AREVA NP provided Supplement 8 to provide a complete and final response to one question and a revised preliminary schedule for the response to Question 07.01-33. On February 9, 2012, AREVA NP provided Supplement 9 to revise the schedule for 11 questions. On February 17, 2012, AREVA NP provided Supplement 10 to revise the schedule for 20 questions. On February 21, 2012, AREVA NP provided Supplement 11 to revise the schedule for Question 07.01-33. On March 16, 2012, AREVA NP provided Supplement 12 to provide a complete and final response to 2 of the remaining questions (07.01-41 and 07.05-10), and a revised response to 2 questions (07.08-46 and 07.09-72). On April 3, 2012, AREVA NP provided Supplement 13 to provide a complete and final response to one of the remaining questions (07.08-47). On April 11, 2012, AREVA NP provided Supplement 14 to provide a complete and final response to one of the remaining questions (07.01-38). On April 17, 2012, AREVA NP provided Supplement 15 to provide a complete and final response to 2 of the remaining questions (07.01-37 and 07.03-38). On April 18, 2012, AREVA NP provided Supplement 16 to provide a correct and complete final response to one of the remaining questions (07.01-50) and a revised final response to another question (07.09-72) based on NRC staff comments. On April 19, 2012, AREVA NP provided Supplement 17 to provide a correct and complete final response to one of the remaining questions (07.01-45). On April 27, 2012, AREVA NP provided Supplement 18 to provide a correct and complete final response to three of the remaining questions. On May 9, 2012, AREVA NP provided Supplement 19 to provide a correct and complete final response to three of the remaining questions. On May 22, 2012, AREVA NP provided Supplement 20 to provide a correct and complete final response to four of the remaining questions.

The attached file, "RAI 505 Supplement 21 Response US EPR DC.pdf" provides a technically correct and complete final response to one of the remaining three questions (07.01-49). Appended to this file are affected pages of the U.S. EPR Final Safety Analysis Report in redline-strikeout format which support the response to this question.

The following table indicates the respective pages in the response document, "RAI 505 Supplement 21 Response US EPR DC.pdf," that contain AREVA NP's response to the subject question.

Question #	Start Page	End Page
RAI 505 — 07.01-49	2	3

The schedule for a technically correct and complete final response to the remaining 2 questions remains unchanged as provided below.

Question #	Response Date
RAI 505 — 07.01-33	July 30, 2013
RAI 505 — 07.01-35	May 30, 2012

Sincerely,

Dennis Williford, P.E.
U.S. EPR Design Certification Licensing Manager
AREVA NP Inc.

7207 IBM Drive, Mail Code CLT 2B
Charlotte, NC 28262
Phone: 704-805-2223
Email: Dennis.Williford@areva.com

From: WILLIFORD Dennis (RS/NB)
Sent: Tuesday, May 22, 2012 4:53 PM
To: Getachew.Tesfaye@nrc.gov
Cc: BENNETT Kathy (RS/NB); DELANO Karen (RS/NB); ROMINE Judy (RS/NB); RYAN Tom (RS/NB)
Subject: Response to U.S. EPR Design Certification Application RAI No. 505 (5902,5735,5869,5754,5803,5950,5744), FSAR Ch. 7, Supplement 20

Getachew,

AREVA NP Inc. letter NRC:12:030 dated May 22, 2012 provides a technically correct and complete final response to 4 questions (Questions 07.01-39, 07.01-40, 07.01-47 and 07.01-51) in RAI 505.

Enclosed with the letter as a part of the response are affected pages of ANP-10315P, "U.S. EPR Protection System Surveillance Testing and TELEPERM XS Self-Monitoring Technical Report," in redline-strikeout format which support the response to RAI 505, Questions 07.01-39, 07.01-40, 07.01-47 and 07.01-51. A complete revision to the technical report will be submitted after the final submittal of all responses to RAI 505 that impact the report are completed. Since AREVA NP considers some of the material contained in the response to be proprietary, an affidavit is included with the letter, as required by 10 CFR 2.390(b), to support the withholding of the information from public disclosure. Proprietary and non-proprietary versions of the enclosure to this letter are provided separately.

The following table indicates the respective pages in the response that contain AREVA NP's final response to the subject questions.

Question #	Start Page	End Page
RAI 505 — 07.01-39	2	4

RAI 505 — 07.01-40	5	6
RAI 505 — 07.01-47	7	7
RAI 505 — 07.01-51	8	16

The schedule for a technically correct and complete response to Question 07.01-33 has been changed as provided below. The response schedule for the other questions remains unchanged. This schedule was transmitted to the NRC in AREVA NP letter 12:024 dated May 10, 2012.

Question #	Response Date
RAI 505 — 07.01-33	July 30, 2013
RAI 505 — 07.01-35	May 30, 2012
RAI 505 — 07.01-49	May 30, 2012

Sincerely,

Dennis Williford, P.E.
U.S. EPR Design Certification Licensing Manager
AREVA NP Inc.

7207 IBM Drive, Mail Code CLT 2B
Charlotte, NC 28262
Phone: 704-805-2223
Email: Dennis.Williford@areva.com

From: WILLIFORD Dennis (RS/NB)
Sent: Wednesday, May 09, 2012 10:02 PM
To: Getachew.Tesfaye@nrc.gov
Cc: BENNETT Kathy (RS/NB); DELANO Karen (RS/NB); ROMINE Judy (RS/NB); RYAN Tom (RS/NB)
Subject: Response to U.S. EPR Design Certification Application RAI No. 505 (5902,5735,5869,5754,5803,5950,5744), FSAR Ch. 7, Supplement 19

Getachew,

AREVA NP Inc. letter NRC:12:027 dated May 9, 2012 provides a technically correct and complete final response to 3 questions (Questions 07.01-34, 07.01-44, and 07.01-48) in RAI 505.

Enclosed with the letter as a part of the response are affected pages of ANP-10315P, "U.S. EPR Protection System Surveillance Testing and TELEPERM XS Self-Monitoring Technical Report," Revision 2, in redline-strikeout format which support the response to RAI 505, Questions 07.01-34, 07.01-44, and 07.01-48. A complete revision to the technical report will be submitted after the final submittal of all responses to RAI 505 that impact the report are completed. Since AREVA NP considers some of the material contained in the response to be proprietary, an affidavit is enclosed, as required by 10 CFR 2.390(b), to support the withholding of the information from public disclosure. Proprietary and non-proprietary versions of the enclosure to this letter are provided separately.

The following table indicates the respective pages in the response that contain AREVA NP's final response to the subject questions.

Question #	Start Page	End Page
RAI 505 — 07.01-34	2	4
RAI 505 — 07.01-44	5	6
RAI 505 — 07.01-48	7	10

The schedule for a technically correct and complete final response to the remaining 7 questions remains unchanged as provided below.

Question #	Response Date
RAI 505 — 07.01-33	August 30, 2013
RAI 505 — 07.01-35	May 30, 2012
RAI 505 — 07.01-39	May 22, 2012
RAI 505 — 07.01-40	May 22, 2012
RAI 505 — 07.01-47	May 22, 2012
RAI 505 — 07.01-49	May 30, 2012
RAI 505 — 07.01-51	May 22, 2012

Sincerely,

Dennis Williford, P.E.
U.S. EPR Design Certification Licensing Manager
AREVA NP Inc.

7207 IBM Drive, Mail Code CLT 2B
Charlotte, NC 28262
Phone: 704-805-2223
Email: Dennis.Williford@areva.com

From: WILLIFORD Dennis (RS/NB)
Sent: Friday, April 27, 2012 2:51 PM
To: Getachew.Tesfaye@nrc.gov
Cc: BENNETT Kathy (RS/NB); DELANO Karen (RS/NB); ROMINE Judy (RS/NB); RYAN Tom (RS/NB)
Subject: Response to U.S. EPR Design Certification Application RAI No. 505 (5902,5735,5869,5754,5803,5950,5744), FSAR Ch. 7, Supplement 18

Getachew,

On September 29, 2011, AREVA NP Inc. provided a schedule for technically correct and complete responses to the 34 questions in RAI 505. In Supplement 1 sent on October 27, 2011, and Supplement 2 sent on November 17, 2011, AREVA NP provided a revised schedule for technically correct and complete responses to 33 questions and a preliminary revised schedule for Question 07.01-33. AREVA NP provided Supplement 3 on November 22, 2011 to provide a final response to 4 questions. On December 9, 2011, AREVA NP provided Supplement 4 to revise the schedule for 7 questions. On December 14, 2011, AREVA NP provided Supplement 5 to revise the schedule for 5 questions. On December 15, 2011, AREVA NP provided Supplement 6 to provide a complete and final response to 6 questions. On January 10, 2012, AREVA NP provided Supplement 7 to provide a complete and final response to 2 questions. On January 19, 2012, AREVA NP provided Supplement 8 to provide a complete and final response to one question and a revised preliminary schedule for the response to Question 07.01-33. On February 9, 2012, AREVA NP provided

Supplement 9 to revise the schedule for 11 questions. On February 17, 2012, AREVA NP provided Supplement 10 to revise the schedule for 20 questions. On February 21, 2012, AREVA NP provided Supplement 11 to revise the schedule for Question 07.01-33. On March 16, 2012, AREVA NP provided Supplement 12 to provide a complete and final response to 2 of the remaining questions (07.01-41 and 07.05-10), and a revised response to 2 questions (07.08-46 and 07.09-72). On April 3, 2012, AREVA NP provided Supplement 13 to provide a complete and final response to one of the remaining questions (07.08-47). On April 11, 2012, AREVA NP provided Supplement 14 to provide a complete and final response to one of the remaining questions (07.01-38). On April 17, 2012, AREVA NP provided Supplement 15 to provide a complete and final response to 2 of the remaining questions (07.01-37 and 07.03-38). On April 18, 2012, AREVA NP provided Supplement 16 to provide a correct and complete final response to one of the remaining questions (07.01-50) and a revised final response to another question (07.09-72) based on NRC staff comments. On April 19, 2012, AREVA NP provided Supplement 17 to provide a correct and complete final response to one of the remaining questions (07.01-45).

The attached file, "RAI 505 Supplement 18 Response US EPR DC.pdf" provides a technically correct and complete final response to 3 of the remaining 13 questions (07.01-36, 07.01-46 and 07.09-71). Appended to this file are affected pages of the U.S. EPR Final Safety Analysis Report in redline-strikeout format which support the response to these questions.

The following table indicates the respective pages in the response document, "RAI 505 Supplement 18 Response US EPR DC.pdf," that contain AREVA NP's response to the subject questions.

Question #	Start Page	End Page
RAI 505 — 07.01-36	2	6
RAI 505 — 07.01-46	7	8
RAI 505 — 07.09-71	9	11

The schedule for a technically correct and complete final response to the remaining 10 questions remains unchanged as provided below.

Question #	Response Date
RAI 505 — 07.01-33	August 30, 2013
RAI 505 — 07.01-34	May 9, 2012
RAI 505 — 07.01-35	May 30, 2012
RAI 505 — 07.01-39	May 22, 2012
RAI 505 — 07.01-40	May 22, 2012
RAI 505 — 07.01-44	May 9, 2012
RAI 505 — 07.01-47	May 22, 2012
RAI 505 — 07.01-48	May 9, 2012
RAI 505 — 07.01-49	May 30, 2012
RAI 505 — 07.01-51	May 22, 2012

Sincerely,

Dennis Williford, P.E.
U.S. EPR Design Certification Licensing Manager

AREVA NP Inc.

7207 IBM Drive, Mail Code CLT 2B

Charlotte, NC 28262

Phone: 704-805-2223

Email: Dennis.Williford@areva.com

From: WILLIFORD Dennis (RS/NB)**Sent:** Thursday, April 19, 2012 11:13 AM**To:** Getachew.Tesfaye@nrc.gov**Cc:** BENNETT Kathy (RS/NB); DELANO Karen (RS/NB); ROMINE Judy (RS/NB); RYAN Tom (RS/NB)**Subject:** Response to U.S. EPR Design Certification Application RAI No. 505 (5902,5735,5869,5754,5803,5950,5744), FSAR Ch. 7, Supplement 17

Getachew,

On September 29, 2011, AREVA NP Inc. provided a schedule for technically correct and complete responses to the 34 questions in RAI 505. In Supplement 1 sent on October 27, 2011, and Supplement 2 sent on November 17, 2011, AREVA NP provided a revised schedule for technically correct and complete responses to 33 questions and a preliminary revised schedule for Question 07.01-33. AREVA NP provided Supplement 3 on November 22, 2011 to provide a final response to 4 questions. On December 9, 2011, AREVA NP provided Supplement 4 to revise the schedule for 7 questions. On December 14, 2011, AREVA NP provided Supplement 5 to revise the schedule for 5 questions. On December 15, 2011, AREVA NP provided Supplement 6 to provide a complete and final response to 6 questions. On January 10, 2012, AREVA NP provided Supplement 7 to provide a complete and final response to 2 questions. On January 19, 2012, AREVA NP provided Supplement 8 to provide a complete and final response to one question and a revised preliminary schedule for the response to Question 07.01-33. On February 9, 2012, AREVA NP provided Supplement 9 to revise the schedule for 11 questions. On February 17, 2012, AREVA NP provided Supplement 10 to revise the schedule for 20 questions. On February 21, 2012, AREVA NP provided Supplement 11 to revise the schedule for Question 07.01-33. On March 16, 2012, AREVA NP provided Supplement 12 to provide a complete and final response to 2 of the remaining questions (07.01-41 and 07.05-10), and a revised response to 2 questions (07.08-46 and 07.09-72). On April 3, 2012, AREVA NP provided Supplement 13 to provide a complete and final response to one of the remaining questions (07.08-47). On April 11, 2012, AREVA NP provided Supplement 14 to provide a complete and final response to one of the remaining questions (07.01-38). On April 17, 2012, AREVA NP provided Supplement 15 to provide a complete and final response to 2 of the remaining questions (07.01-37 and 07.03-38). On April 18, 2012, AREVA NP provided Supplement 16 to provide a correct and complete final response to one of the remaining questions (07.01-50) and a revised final response to another question (07.09-72) based on NRC staff comments.

The attached file, "RAI 505 Supplement 17 Response - US EPR DC.pdf" provides a technically correct and complete final response to 1 of the remaining 14 questions (07.01-45). Appended to this file are affected pages of the U.S. EPR Technical Report ANP-10315P in redline-strikeout format which support the response to Question 07.01-45.

The following table indicates the respective pages in the response document, "RAI 505 Supplement 17 Response - US EPR DC.pdf," that contain AREVA NP's response to the subject question.

Question #	Start Page	End Page
RAI 505 — 07.01-45	2	3

The schedule for a technically correct and complete final response to the remaining 13 questions remains unchanged as provided below.

Question #	Response Date
RAI 505 — 07.01-33	August 30, 2013
RAI 505 — 07.01-34	May 9, 2012
RAI 505 — 07.01-35	May 30, 2012
RAI 505 — 07.01-36	May 1, 2012
RAI 505 — 07.01-39	May 22, 2012
RAI 505 — 07.01-40	May 22, 2012
RAI 505 — 07.01-44	May 9, 2012
RAI 505 — 07.01-46	May 1, 2012
RAI 505 — 07.01-47	May 22, 2012
RAI 505 — 07.01-48	May 9, 2012
RAI 505 — 07.01-49	May 30, 2012
RAI 505 — 07.01-51	May 22, 2012
RAI 505 — 07.09-71	May 9, 2012

Sincerely,

Dennis Williford, P.E.
U.S. EPR Design Certification Licensing Manager
AREVA NP Inc.

7207 IBM Drive, Mail Code CLT 2B
Charlotte, NC 28262
Phone: 704-805-2223
Email: Dennis.Williford@areva.com

From: WILLIFORD Dennis (RS/NB)
Sent: Wednesday, April 18, 2012 3:06 PM
To: Getachew.Tesfaye@nrc.gov
Cc: BENNETT Kathy (RS/NB); DELANO Karen (RS/NB); ROMINE Judy (RS/NB); RYAN Tom (RS/NB)
Subject: Response to U.S. EPR Design Certification Application RAI No. 505 (5902,5735,5869,5754,5803,5950,5744), FSAR Ch. 7, Supplement 16

Getachew,

On September 29, 2011, AREVA NP Inc. provided a schedule for technically correct and complete responses to the 34 questions in RAI 505. In Supplement 1 sent on October 27, 2011, and Supplement 2 sent on November 17, 2011, AREVA NP provided a revised schedule for technically correct and complete responses to 33 questions and a preliminary revised schedule for Question 07.01-33. AREVA NP provided Supplement 3 on November 22, 2011 to provide a final response to 4 questions. On December 9, 2011, AREVA NP provided Supplement 4 to revise the schedule for 7 questions. On December 14, 2011, AREVA NP provided Supplement 5 to revise the schedule for 5 questions. On December 15, 2011, AREVA NP provided Supplement 6 to provide a complete and final response to 6 questions. On January 10, 2012, AREVA NP provided Supplement 7 to provide a complete and final response to 2 questions. On January 19, 2012, AREVA NP provided Supplement 8 to provide a complete and final response to one question and a revised preliminary schedule for the response to Question 07.01-33. On February 9, 2012, AREVA NP provided

Supplement 9 to revise the schedule for 11 questions. On February 17, 2012, AREVA NP provided Supplement 10 to revise the schedule for 20 questions. On February 21, 2012, AREVA NP provided Supplement 11 to revise the schedule for Question 07.01-33. On March 16, 2012, AREVA NP provided Supplement 12 to provide a complete and final response to 2 of the remaining questions (07.01-41 and 07.05-10), and a revised response to 2 questions (07.08-46 and 07.09-72). On April 3, 2012, AREVA NP provided Supplement 13 to provide a complete and final response to one of the remaining questions (07.08-47). On April 11, 2012, AREVA NP provided Supplement 14 to provide a complete and final response to one of the remaining questions (07.01-38). On April 17, 2012, AREVA NP provided Supplement 15 to provide a complete and final response to 2 of the remaining questions (07.01-37 and 07.03-38).

The attached file, "RAI 505 Supplement 16 Response - US EPR DC.pdf" provides a technically correct and complete final response to 1 of the remaining 15 questions (07.01-50) and a revised final response to another question (07.09-72) based on NRC staff comments. Appended to this file are affected pages of the U.S. EPR Final Safety Analysis Report in redline-strikeout format which support the response to Question 07.01-50 and Question 07.09-72.

The following table indicates the respective pages in the response document, "RAI 505 Supplement 16 Response - US EPR DC.pdf," that contain AREVA NP's response to the subject questions.

Question #	Start Page	End Page
RAI 505 — 07.01-50	2	3
RAI 505 — 07.09-72	4	5

The schedule for a technically correct and complete final response to the remaining 14 questions remains unchanged as provided below.

Question #	Response Date
RAI 505 — 07.01-33	August 30, 2013
RAI 505 — 07.01-34	May 9, 2012
RAI 505 — 07.01-35	May 30, 2012
RAI 505 — 07.01-36	May 1, 2012
RAI 505 — 07.01-39	May 22, 2012
RAI 505 — 07.01-40	May 22, 2012
RAI 505 — 07.01-44	May 9, 2012
RAI 505 — 07.01-45	May 1, 2012
RAI 505 — 07.01-46	May 1, 2012
RAI 505 — 07.01-47	May 22, 2012
RAI 505 — 07.01-48	May 9, 2012
RAI 505 — 07.01-49	May 30, 2012
RAI 505 — 07.01-51	May 22, 2012
RAI 505 — 07.09-71	May 9, 2012

Sincerely,

Dennis Williford, P.E.
U.S. EPR Design Certification Licensing Manager

AREVA NP Inc.

7207 IBM Drive, Mail Code CLT 2B

Charlotte, NC 28262

Phone: 704-805-2223

Email: Dennis.Williford@areva.com**From:** WILLIFORD Dennis (RS/NB)**Sent:** Tuesday, April 17, 2012 12:05 PM**To:** Getachew.Tesfaye@nrc.gov**Cc:** BENNETT Kathy (RS/NB); DELANO Karen (RS/NB); ROMINE Judy (RS/NB); RYAN Tom (RS/NB)**Subject:** Response to U.S. EPR Design Certification Application RAI No. 505 (5902,5735,5869,5754,5803,5950,5744), FSAR Ch. 7, Supplement 15

Getachew,

On September 29, 2011, AREVA NP Inc. provided a schedule for technically correct and complete responses to the 34 questions in RAI 505. In Supplement 1 sent on October 27, 2011, and Supplement 2 sent on November 17, 2011, AREVA NP provided a revised schedule for technically correct and complete responses to 33 questions and a preliminary revised schedule for Question 07.01-33. AREVA NP provided Supplement 3 on November 22, 2011 to provide a final response to 4 questions. On December 9, 2011, AREVA NP provided Supplement 4 to revise the schedule for 7 questions. On December 14, 2011, AREVA NP provided Supplement 5 to revise the schedule for 5 questions. On December 15, 2011, AREVA NP provided Supplement 6 to provide a complete and final response to 6 questions. On January 10, 2012, AREVA NP provided Supplement 7 to provide a complete and final response to 2 questions. On January 19, 2012, AREVA NP provided Supplement 8 to provide a complete and final response to one question and a revised preliminary schedule for the response to Question 07.01-33. On February 9, 2012, AREVA NP provided Supplement 9 to revise the schedule for 11 questions. On February 17, 2012, AREVA NP provided Supplement 10 to revise the schedule for 20 questions. On February 21, 2012, AREVA NP provided Supplement 11 to revise the schedule for Question 07.01-33. On March 16, 2012, AREVA NP provided Supplement 12 to provide a complete and final response to 2 of the remaining questions (07.01-41 and 07.05-10), and a revised response to 2 questions (07.08-46 and 07.09-72). On April 3, 2012, AREVA NP provided Supplement 13 to provide a complete and final response to one of the remaining questions (07.08-47). On April 11, 2012, AREVA NP provided Supplement 14 to provide a complete and final response to one of the remaining questions (07.01-38).

The attached file, "RAI 505 Supplement 15 Response - US EPR DC.pdf" provides a technically correct and complete final response to 2 of the remaining 17 questions (07.01-37 and 07.03-38). Appended to this file are affected pages of the U.S. EPR Final Safety Analysis Report in redline-strikeout format which support the response to Questions 07.01-37 and Question 07.03-38.

The following table indicates the respective pages in the response document, "RAI 505 Supplement 15 Response - US EPR DC.pdf," that contain AREVA NP's response to the subject questions.

Question #	Start Page	End Page
RAI 505 — 07.01-37	2	2
RAI 505 — 07.03-38	3	35

The schedule for a technically correct and complete final response to the remaining 15 questions remains unchanged as provided below.

Question #	Response Date
RAI 505 — 07.01-33	August 30, 2013
RAI 505 — 07.01-34	May 9, 2012
RAI 505 — 07.01-35	May 30, 2012
RAI 505 — 07.01-36	May 1, 2012
RAI 505 — 07.01-39	May 22, 2012
RAI 505 — 07.01-40	May 22, 2012
RAI 505 — 07.01-44	May 9, 2012
RAI 505 — 07.01-45	May 1, 2012
RAI 505 — 07.01-46	May 1, 2012
RAI 505 — 07.01-47	May 22, 2012
RAI 505 — 07.01-48	May 9, 2012
RAI 505 — 07.01-49	May 30, 2012
RAI 505 — 07.01-50	May 30, 2012
RAI 505 — 07.01-51	May 22, 2012
RAI 505 — 07.09-71	May 9, 2012

Sincerely,

Dennis Williford, P.E.
U.S. EPR Design Certification Licensing Manager
AREVA NP Inc.

7207 IBM Drive, Mail Code CLT 2B
Charlotte, NC 28262
Phone: 704-805-2223
Email: Dennis.Williford@areva.com

From: WILLIFORD Dennis (RS/NB)
Sent: Wednesday, April 11, 2012 11:00 AM
To: Getachew.Tesfaye@nrc.gov
Cc: BENNETT Kathy (RS/NB); DELANO Karen (RS/NB); ROMINE Judy (RS/NB); RYAN Tom (RS/NB)
Subject: Response to U.S. EPR Design Certification Application RAI No. 505 (5902,5735,5869,5754,5803,5950,5744), FSAR Ch. 7, Supplement 14

Getachew,

On September 29, 2011, AREVA NP Inc. provided a schedule for technically correct and complete responses to the 34 questions in RAI 505. In Supplement 1 sent on October 27, 2011, and Supplement 2 sent on November 17, 2011, AREVA NP provided a revised schedule for technically correct and complete responses to 33 questions and a preliminary revised schedule for Question 07.01-33. AREVA NP provided Supplement 3 on November 22, 2011 to provide a final response to 4 questions. On December 9, 2011, AREVA NP provided Supplement 4 to revise the schedule for 7 questions. On December 14, 2011, AREVA NP provided Supplement 5 to revise the schedule for 5 questions. On December 15, 2011, AREVA NP provided Supplement 6 to provide a complete and final response to 6 questions. On January 10, 2012, AREVA NP provided Supplement 7 to provide a complete and final response to 2 questions. On January 19, 2012, AREVA NP provided Supplement 8 to provide a complete and final response to one question and a revised preliminary schedule for the response to Question 07.01-33. On February 9, 2012, AREVA NP provided

Supplement 9 to revise the schedule for 11 questions. On February 17, 2012, AREVA NP provided Supplement 10 to revise the schedule for 20 questions. On February 21, 2012, AREVA NP provided Supplement 11 to revise the schedule for Question 07.01-33. On March 16, 2012, AREVA NP provided Supplement 12 to provide a complete and final response to 2 of the remaining questions (07.01-41 and 07.05-10), and a revised response to 2 questions (07.08-46 and 07.09-72). On April 3, 2012, AREVA NP provided Supplement 13 to provide a complete and final response to one of the remaining questions (07.08-47).

The attached file, "RAI 505 Supplement 14 Response - US EPR DC.pdf" provides a technically correct and complete response to 1 of the remaining 18 questions (07.01-38). Appended to this file are affected pages of the U.S. EPR Final Safety Analysis Report in redline-strikeout format which support the response to Question 07.01-38.

The following table indicates the respective pages in the response document, "RAI 505 Supplement 14 Response - US EPR DC.pdf," that contain AREVA NP's response to the subject question.

Question #	Start Page	End Page
RAI 505 — 07.01-38	2	3

The schedule for a technically correct and complete response to the remaining 17 questions remains unchanged as provided below.

Question #	Response Date
RAI 505 — 07.01-33	August 30, 2013
RAI 505 — 07.01-34	May 9, 2012
RAI 505 — 07.01-35	May 30, 2012
RAI 505 — 07.01-36	May 1, 2012
RAI 505 — 07.01-37	April 17, 2012
RAI 505 — 07.01-39	May 22, 2012
RAI 505 — 07.01-40	May 22, 2012
RAI 505 — 07.01-44	May 9, 2012
RAI 505 — 07.01-45	May 1, 2012
RAI 505 — 07.01-46	May 1, 2012
RAI 505 — 07.01-47	May 22, 2012
RAI 505 — 07.01-48	May 9, 2012
RAI 505 — 07.01-49	May 30, 2012
RAI 505 — 07.01-50	May 30, 2012
RAI 505 — 07.01-51	May 22, 2012
RAI 505 — 07.03-38	April 17, 2012
RAI 505 — 07.09-71	May 9, 2012

Sincerely,

Dennis Williford, P.E.
U.S. EPR Design Certification Licensing Manager
AREVA NP Inc.

7207 IBM Drive, Mail Code CLT 2B

From: WILLIFORD Dennis (RS/NB)
Sent: Tuesday, April 03, 2012 3:27 PM
To: Getachew.Tesfaye@nrc.gov
Cc: BENNETT Kathy (RS/NB); DELANO Karen (RS/NB); ROMINE Judy (RS/NB); RYAN Tom (RS/NB)
Subject: Response to U.S. EPR Design Certification Application RAI No. 505 (5902,5735,5869,5754,5803,5950,5744), FSAR Ch. 7, Supplement 13

Getachew,

On September 29, 2011, AREVA NP Inc. provided a schedule for technically correct and complete responses to the 34 questions in RAI 505. In Supplement 1 sent on October 27, 2011, and Supplement 2 sent on November 17, 2011, AREVA NP provided a revised schedule for technically correct and complete responses to 33 questions and a preliminary revised schedule for Question 07.01-33. AREVA NP provided Supplement 3 on November 22, 2011 to provide a final response to 4 questions. On December 9, 2011, AREVA NP provided Supplement 4 to revise the schedule for 7 questions. On December 14, 2011, AREVA NP provided Supplement 5 to revise the schedule for 5 questions. On December 15, 2011, AREVA NP provided Supplement 6 to provide a complete and final response to 6 questions. On January 10, 2012, AREVA NP provided Supplement 7 to provide a complete and final response to 2 questions. On January 19, 2012, AREVA NP provided Supplement 8 to provide a complete and final response to one question and a revised preliminary schedule for the response to Question 07.01-33. On February 9, 2012, AREVA NP provided Supplement 9 to revise the schedule for 11 questions. On February 17, 2012, AREVA NP provided Supplement 10 to revise the schedule for 20 questions. On February 21, 2012, AREVA NP provided Supplement 11 to revise the schedule for Question 07.01-33. On March 16, 2012, AREVA NP provided Supplement 12 to provide a complete and final response to 2 of the remaining questions (07.01-41 and 07.05-10), and a revised response to 2 questions (07.08-46 and 07.09-72).

The attached file, "RAI 505 Supplement 13 Response - US EPR DC.pdf" provides a technically correct and complete response to 1 of the remaining 19 questions (07.08-47). Appended to this file are affected pages of the U.S. EPR Final Safety Analysis Report in redline-strikeout format which support the response to Question 07.08-47. Also appended to this file are affected pages of Technical Report ANP-10315P. The revision to this technical report will be submitted by separate letter after completion of all responses to RAI 505.

The following table indicates the respective pages in the response document, "RAI 505 Supplement 13 Response - US EPR DC.pdf," that contain AREVA NP's response to the subject question.

Question #	Start Page	End Page
RAI 505 — 07.08-47	2	7

The schedule for a technically correct and complete response to the remaining 18 questions remains unchanged as provided below.

Question #	Response Date
RAI 505 — 07.01-33	August 30, 2013
RAI 505 — 07.01-34	May 9, 2012

RAI 505 — 07.01-35	May 30, 2012
RAI 505 — 07.01-36	May 1, 2012
RAI 505 — 07.01-37	April 17, 2012
RAI 505 — 07.01-38	May 1, 2012
RAI 505 — 07.01-39	May 22, 2012
RAI 505 — 07.01-40	May 22, 2012
RAI 505 — 07.01-44	May 9, 2012
RAI 505 — 07.01-45	May 1, 2012
RAI 505 — 07.01-46	May 1, 2012
RAI 505 — 07.01-47	May 22, 2012
RAI 505 — 07.01-48	May 9, 2012
RAI 505 — 07.01-49	May 30, 2012
RAI 505 — 07.01-50	May 30, 2012
RAI 505 — 07.01-51	May 22, 2012
RAI 505 — 07.03-38	April 17, 2012
RAI 505 — 07.09-71	May 9, 2012

Sincerely,

Dennis Williford, P.E.
U.S. EPR Design Certification Licensing Manager
AREVA NP Inc.

7207 IBM Drive, Mail Code CLT 2B
Charlotte, NC 28262
Phone: 704-805-2223
Email: Dennis.Williford@areva.com

From: WILLIFORD Dennis (RS/NB)
Sent: Friday, March 16, 2012 12:59 PM
To: Getachew.Tesfaye@nrc.gov
Cc: BENNETT Kathy (RS/NB); DELANO Karen (RS/NB); ROMINE Judy (RS/NB); RYAN Tom (RS/NB)
Subject: Response to U.S. EPR Design Certification Application RAI No. 505 (5902,5735,5869,5754,5803,5950,5744), FSAR Ch. 7, Supplement 12

Getachew,

On September 29, 2011, AREVA NP Inc. provided a schedule for technically correct and complete responses to the 34 questions in RAI 505. In Supplement 1 sent on October 27, 2011, and Supplement 2 sent on November 17, 2011, AREVA NP provided a revised schedule for technically correct and complete responses to 33 questions and a preliminary revised schedule for Question 07.01-33. AREVA NP provided Supplement 3 on November 22, 2011 to provide a final response to 4 questions. On December 9, 2011, AREVA NP provided Supplement 4 to revise the schedule for 7 questions. On December 14, 2011, AREVA NP provided Supplement 5 to revise the schedule for 5 questions. On December 15, 2011, AREVA NP provided Supplement 6 to provide a complete and final response to 6 questions. On January 10, 2012, AREVA NP provided Supplement 7 to provide a complete and final response to 2 questions. On January 19, 2012, AREVA NP provided Supplement 8 to provide a complete and final response to one question and a revised preliminary schedule for the response to Question 07.01-33. On February 9, 2012, AREVA NP provided Supplement 9 to revise the schedule for 11 questions. On February 17, 2012, AREVA NP provided

Supplement 10 to revise the schedule for 20 questions. On February 21, 2012, AREVA NP provided Supplement 11 to revise the schedule for Question 07.01-33.

The attached file, "RAI 505 Supplement 12 Response - US EPR DC.pdf" provides technically correct and complete responses to 2 of the remaining 21 questions (07.01-41 and 07.05-10), and a revised response to 2 questions (07.08-46 and 07.09-72). Appended to this file are affected pages of the U.S. EPR Final Safety Analysis Report in redline-strikeout format which support the responses to Question 07.01-41, 07.05-10, 07.08-46, and 07.09-72. Also appended to this file are affected pages of Technical Reports ANP-10304, ANP-10309P and ANP-10315P. Revisions to these Technical Reports will be submitted by separate letter after completion of all responses to RAI 505.

The following table indicates the respective pages in the response document, "RAI 505 Supplement 12 Response - US EPR DC.pdf," that contain AREVA NP's response to the subject questions.

Question #	Start Page	End Page
RAI 505 — 07.01-41	2	5
RAI 505 — 07.05-10	6	9
RAI 505 — 07.08-46	10	10
RAI 505 — 07.09-72	11	12

The schedule for a technically correct and complete response to the remaining 19 questions remains unchanged as provided below.

Question #	Response Date
RAI 505 — 07.01-33	August 30, 2013
RAI 505 — 07.01-34	May 9, 2012
RAI 505 — 07.01-35	May 30, 2012
RAI 505 — 07.01-36	May 1, 2012
RAI 505 — 07.01-37	April 17, 2012
RAI 505 — 07.01-38	May 1, 2012
RAI 505 — 07.01-39	May 22, 2012
RAI 505 — 07.01-40	May 22, 2012
RAI 505 — 07.01-44	May 9, 2012
RAI 505 — 07.01-45	May 1, 2012
RAI 505 — 07.01-46	May 1, 2012
RAI 505 — 07.01-47	May 22, 2012
RAI 505 — 07.01-48	May 9, 2012
RAI 505 — 07.01-49	May 30, 2012
RAI 505 — 07.01-50	May 30, 2012
RAI 505 — 07.01-51	May 22, 2012
RAI 505 — 07.03-38	April 17, 2012
RAI 505 — 07.08-47	May 30, 2012
RAI 505 — 07.09-71	May 9, 2012

Sincerely,

Dennis Williford, P.E.
U.S. EPR Design Certification Licensing Manager
AREVA NP Inc.

7207 IBM Drive, Mail Code CLT 2B
Charlotte, NC 28262
Phone: 704-805-2223
Email: Dennis.Williford@areva.com

From: WILLIFORD Dennis (RS/NB)
Sent: Tuesday, February 21, 2012 9:31 PM
To: Getachew.Tesfaye@nrc.gov
Cc: BENNETT Kathy (RS/NB); DELANO Karen (RS/NB); ROMINE Judy (RS/NB); RYAN Tom (RS/NB)
Subject: Response to U.S. EPR Design Certification Application RAI No. 505 (5902,5735,5869,5754,5803,5950,5744), FSAR Ch. 7, Supplement 11

Getachew,

On September 29, 2011, AREVA NP Inc. provided a schedule for technically correct and complete responses to the 34 questions in RAI 505. In Supplement 1 sent on October 27, 2011, and Supplement 2 sent on November 17, 2011, AREVA NP provided a revised schedule for technically correct and complete responses to 33 questions and a preliminary revised schedule for Question 07.01-33. AREVA NP provided Supplement 3 on November 22, 2011 to provide a final response to 4 questions. On December 9, 2011, AREVA NP provided Supplement 4 to revise the schedule for 7 questions. On December 14, 2011, AREVA NP provided Supplement 5 to revise the schedule for 5 questions. On December 15, 2011, AREVA NP provided Supplement 6 to provide a complete and final response to 6 questions. On January 10, 2012, AREVA NP provided Supplement 7 to provide a complete and final response to 2 questions. On January 19, 2012, AREVA NP provided Supplement 8 to provide a complete and final response to one question and a revised preliminary schedule for the response to Question 07.01-33. On February 9, 2012, AREVA NP provided Supplement 9 to revise the schedule for 11 questions. On February 17, 2012, AREVA NP provided Supplement 10 to revise the schedule for 20 questions.

The schedule for a technically correct and complete response to question 07.01-33 has been changed as provided below. The response schedule for the other questions remains unchanged. This schedule was transmitted to the NRC in AREVA NP letter 12:008 dated February 21, 2012.

Question #	Response Date
RAI 505 — 07.01-33	August 30, 2013
RAI 505 — 07.01-34	May 9, 2012
RAI 505 — 07.01-35	May 30, 2012
RAI 505 — 07.01-36	May 1, 2012
RAI 505 — 07.01-37	April 17, 2012
RAI 505 — 07.01-38	May 1, 2012
RAI 505 — 07.01-39	May 22, 2012
RAI 505 — 07.01-40	May 22, 2012
RAI 505 — 07.01-41	April 17, 2012
RAI 505 — 07.01-44	May 9, 2012
RAI 505 — 07.01-45	May 1, 2012

RAI 505 — 07.01-46	May 1, 2012
RAI 505 — 07.01-47	May 22, 2012
RAI 505 — 07.01-48	May 9, 2012
RAI 505 — 07.01-49	May 30, 2012
RAI 505 — 07.01-50	May 30, 2012
RAI 505 — 07.01-51	May 22, 2012
RAI 505 — 07.03-38	April 17, 2012
RAI 505 — 07.05-10	April 17, 2012
RAI 505 — 07.08-47	May 30, 2012
RAI 505 — 07.09-71	May 9, 2012

Sincerely,

Dennis Williford, P.E.
U.S. EPR Design Certification Licensing Manager
AREVA NP Inc.

7207 IBM Drive, Mail Code CLT 2B
Charlotte, NC 28262
Phone: 704-805-2223
Email: Dennis.Williford@areva.com

From: WILLIFORD Dennis (RS/NB)
Sent: Friday, February 17, 2012 4:09 PM
To: Getachew.Tesfaye@nrc.gov
Cc: BENNETT Kathy (RS/NB); DELANO Karen (RS/NB); ROMINE Judy (RS/NB); RYAN Tom (RS/NB)
Subject: Response to U.S. EPR Design Certification Application RAI No. 505 (5902,5735,5869,5754,5803,5950,5744), FSAR Ch. 7, Supplement 10

Getachew,

On September 29, 2011, AREVA NP Inc. provided a schedule for technically correct and complete responses to the 34 questions in RAI 505. In Supplement 1 sent on October 27, 2011, and Supplement 2 sent on November 17, 2011, AREVA NP provided a revised schedule for technically correct and complete responses to 33 questions and a preliminary revised schedule for Question 07.01-33. AREVA NP provided Supplement 3 on November 22, 2011 to provide a final response to 4 questions. On December 9, 2011, AREVA NP provided Supplement 4 to revise the schedule for 7 questions. On December 14, 2011, AREVA NP provided Supplement 5 to revise the schedule for 5 questions. On December 15, 2011, AREVA NP provided Supplement 6 to provide a complete and final response to 6 questions. On January 10, 2012, AREVA NP provided Supplement 7 to provide a complete and final response to 2 questions. On January 19, 2012, AREVA NP provided Supplement 8 to provide a complete and final response to one question and a revised preliminary schedule for the response to Question 07.01-33. On February 9, 2012, AREVA NP provided Supplement 9 to revise the schedule for 11 questions.

The schedule for a technically correct and complete response to 20 of the remaining 21 questions has been changed as provided below. The response schedule to the other question remains unchanged.

Question #	Response Date
------------	---------------

RAI 505 — 07.01-33	February 21, 2012
RAI 505 — 07.01-34	May 9, 2012
RAI 505 — 07.01-35	May 30, 2012
RAI 505 — 07.01-36	May 1, 2012
RAI 505 — 07.01-37	April 17, 2012
RAI 505 — 07.01-38	May 1, 2012
RAI 505 — 07.01-39	May 22, 2012
RAI 505 — 07.01-40	May 22, 2012
RAI 505 — 07.01-41	April 17, 2012
RAI 505 — 07.01-44	May 9, 2012
RAI 505 — 07.01-45	May 1, 2012
RAI 505 — 07.01-46	May 1, 2012
RAI 505 — 07.01-47	May 22, 2012
RAI 505 — 07.01-48	May 9, 2012
RAI 505 — 07.01-49	May 30, 2012
RAI 505 — 07.01-50	May 30, 2012
RAI 505 — 07.01-51	May 22, 2012
RAI 505 — 07.03-38	April 17, 2012
RAI 505 — 07.05-10	April 17, 2012
RAI 505 — 07.08-47	May 30, 2012
RAI 505 — 07.09-71	May 9, 2012

Sincerely,

Dennis Williford, P.E.
U.S. EPR Design Certification Licensing Manager
AREVA NP Inc.

7207 IBM Drive, Mail Code CLT 2B
Charlotte, NC 28262
Phone: 704-805-2223
Email: Dennis.Williford@areva.com

From: WILLIFORD Dennis (RS/NB)
Sent: Thursday, February 09, 2012 8:15 AM
To: Getachew.Tesfaye@nrc.gov
Cc: BENNETT Kathy (RS/NB); DELANO Karen (RS/NB); ROMINE Judy (RS/NB); RYAN Tom (RS/NB)
Subject: Response to U.S. EPR Design Certification Application RAI No. 505 (5902,5735,5869,5754,5803,5950,5744), FSAR Ch. 7, Supplement 9

Getachew,

On September 29, 2011, AREVA NP Inc. provided a schedule for technically correct and complete responses to the 34 questions in RAI 505. In Supplement 1 sent on October 27, 2011, and Supplement 2 sent on November 17, 2011, AREVA NP provided a revised schedule for technically correct and complete responses to 33 questions and a preliminary revised schedule for Question 07.01-33. AREVA NP provided Supplement 3 on November 22, 2011 to provide a final response to 4 questions. On December 9, 2011, AREVA NP provided Supplement 4 to revise the schedule for 7 questions. On December 14, 2011, AREVA NP provided Supplement 5 to revise the schedule for 5 questions. On December 15, 2011, AREVA NP provided

Supplement 6 to provide a complete and final response to 6 questions. On January 10, 2012, AREVA NP provided Supplement 7 to provide a complete and final response to 2 questions. On January 19, 2012, AREVA NP provided Supplement 8 to provide a complete and final response to one question and a revised preliminary schedule for the response to Question 07.01-33.

The schedule for a technically correct and complete response to 11 of the remaining 21 questions has been changed as provided below. The response schedule to the other 10 questions remains unchanged.

Question #	Response Date
RAI 505 — 07.01-33	February 21, 2012
RAI 505 — 07.01-34	April 5, 2012
RAI 505 — 07.01-35	April 26, 2012
RAI 505 — 07.01-36	April 5, 2012
RAI 505 — 07.01-37	March 8, 2012
RAI 505 — 07.01-38	April 5, 2012
RAI 505 — 07.01-39	April 26, 2012
RAI 505 — 07.01-40	April 26, 2012
RAI 505 — 07.01-41	March 8, 2012
RAI 505 — 07.01-44	April 5, 2012
RAI 505 — 07.01-45	April 26, 2012
RAI 505 — 07.01-46	April 26, 2012
RAI 505 — 07.01-47	April 5, 2012
RAI 505 — 07.01-48	April 5, 2012
RAI 505 — 07.01-49	April 26, 2012
RAI 505 — 07.01-50	April 26, 2012
RAI 505 — 07.01-51	April 26, 2012
RAI 505 — 07.03-38	March 8, 2012
RAI 505 — 07.05-10	March 8, 2012
RAI 505 — 07.08-47	April 26, 2012
RAI 505 — 07.09-71	April 5, 2012

Sincerely,

Dennis Williford, P.E.
U.S. EPR Design Certification Licensing Manager
AREVA NP Inc.

7207 IBM Drive, Mail Code CLT 2B
Charlotte, NC 28262
Phone: 704-805-2223
Email: Dennis.Williford@areva.com

From: WILLIFORD Dennis (RS/NB)
Sent: Thursday, January 19, 2012 11:19 AM
To: Getachew.Tesfaye@nrc.gov
Cc: BENNETT Kathy (RS/NB); DELANO Karen (RS/NB); ROMINE Judy (RS/NB); RYAN Tom (RS/NB)

Subject: Response to U.S. EPR Design Certification Application RAI No. 505 (5902,5735,5869,5754,5803,5950,5744), FSAR Ch. 7, Supplement 8

Getachew,

On September 29, 2011, AREVA NP Inc. provided a schedule for technically correct and complete responses to the 34 questions in RAI 505. In Supplement 1 sent on October 27, 2011, and Supplement 2 sent on November 17, 2011, AREVA NP provided a revised schedule for technically correct and complete responses to 33 questions and a preliminary revised schedule for Question 07.01-33. AREVA NP provided Supplement 3 on November 22, 2011 to provide a final response to 4 questions. On December 9, 2011, AREVA NP provided Supplement 4 to revise the schedule for 7 questions. On December 14, 2011, AREVA NP provided Supplement 5 to revise the schedule for 5 questions. On December 15, 2011, AREVA NP provided Supplement 6 to provide a complete and final response to 6 questions. On January 10, 2012, AREVA NP provided Supplement 7 to provide a complete and final response to 2 questions.

The attached file, "RAI 505 Supplement 8 Response US EPR DC.pdf" provides a technically correct and complete final response to 1 of the remaining 22 questions.

The following table indicates the respective pages in the response document, "RAI 505 Supplement 8 Response US EPR DC.pdf," that contain AREVA NP's response to the subject question.

Question #	Start Page	End Page
RAI 505 — 07.01-42	2	2

The schedule for a technically correct and complete response to the remaining 21 questions is provided below. The preliminary schedule for the response to Question 07.01-33 has been revised and is being reevaluated and a new supplement with a revised schedule will be transmitted by February 21, 2012.

Question #	Response Date
RAI 505 — 07.01-33	February 21, 2012
RAI 505 — 07.01-34	April 5, 2012
RAI 505 — 07.01-35	April 26, 2012
RAI 505 — 07.01-36	February 9, 2012
RAI 505 — 07.01-37	March 8, 2012
RAI 505 — 07.01-38	February 9, 2012
RAI 505 — 07.01-39	February 9, 2012
RAI 505 — 07.01-40	February 9, 2012
RAI 505 — 07.01-41	February 9, 2012
RAI 505 — 07.01-44	February 9, 2012
RAI 505 — 07.01-45	April 26, 2012
RAI 505 — 07.01-46	April 26, 2012
RAI 505 — 07.01-47	February 9, 2012
RAI 505 — 07.01-48	February 9, 2012
RAI 505 — 07.01-49	February 9, 2012
RAI 505 — 07.01-50	April 26, 2012

RAI 505 — 07.01-51	February 9, 2012
RAI 505 — 07.03-38	April 26, 2012
RAI 505 — 07.05-10	March 8, 2012
RAI 505 — 07.08-47	April 26, 2012
RAI 505 — 07.09-71	April 5, 2012

Sincerely,

Dennis Williford, P.E.

U.S. EPR Design Certification Licensing Manager

AREVA NP Inc.

7207 IBM Drive, Mail Code CLT 2B

Charlotte, NC 28262

Phone: 704-805-2223

Email: Dennis.Williford@areva.com

From: WILLIFORD Dennis (CORP/QP)

Sent: Tuesday, January 10, 2012 5:21 PM

To: Getachew.Tesfaye@nrc.gov

Cc: BENNETT Kathy (RS/NB); DELANO Karen (RS/NB); ROMINE Judy (RS/NB); RYAN Tom (RS/NB)

Subject: Response to U.S. EPR Design Certification Application RAI No. 505 (5902,5735,5869,5754,5803,5950,5744), FSAR Ch. 7, Supplement 7

Getachew,

On September 29, 2011, AREVA NP Inc. provided a schedule for technically correct and complete responses to the 34 questions in RAI 505. In Supplement 1 sent on October 27, 2011, and Supplement 2 sent on November 17, 2011, AREVA NP provided a revised schedule for technically correct and complete responses to 33 questions and a preliminary revised schedule for Question 07.01-33. AREVA NP provided Supplement 3 on November 22, 2011 to provide a final response to 4 questions. On December 9, 2011, AREVA NP provided Supplement 4 to revise the schedule for 7 questions. On December 14, 2011, AREVA NP provided Supplement 5 to revise the schedule for 5 questions. On December 15, 2011, AREVA NP provided Supplement 6 to provide a complete and final response to 6 questions.

The attached file, "RAI 505 Supplement 7 Response US EPR DC.pdf" provides technically correct and complete final responses to 2 of the remaining 24 questions. Appended to this file are affected pages of the U.S. EPR Final Safety Analysis Report in redline-strikeout format which support the response to RAI 505 Question 07.08-48.

The following table indicates the respective pages in the response document, "RAI 505 Supplement 7 Response US EPR DC.pdf," that contain AREVA NP's response to the subject questions.

Question #	Start Page	End Page
RAI 505 — 07.08-44	2	3
RAI 505 — 07.08-48	4	5

The schedule for a technically correct and complete response to the remaining 22 questions has changed as provided below. The preliminary schedule for the response to Question 07.01-33 is being reevaluated and a new supplement with a revised schedule will be transmitted by January 25, 2012.

Question #	Response Date
RAI 505 — 07.01-33	January 25, 2012
RAI 505 — 07.01-34	April 5, 2012
RAI 505 — 07.01-35	April 26, 2012
RAI 505 — 07.01-36	February 9, 2012
RAI 505 — 07.01-37	March 8, 2012
RAI 505 — 07.01-38	February 9, 2012
RAI 505 — 07.01-39	February 9, 2012
RAI 505 — 07.01-40	February 9, 2012
RAI 505 — 07.01-41	February 9, 2012
RAI 505 — 07.01-42	February 9, 2012
RAI 505 — 07.01-44	February 9, 2012
RAI 505 — 07.01-45	April 26, 2012
RAI 505 — 07.01-46	April 26, 2012
RAI 505 — 07.01-47	February 9, 2012
RAI 505 — 07.01-48	February 9, 2012
RAI 505 — 07.01-49	February 9, 2012
RAI 505 — 07.01-50	April 26, 2012
RAI 505 — 07.01-51	February 9, 2012
RAI 505 — 07.03-38	April 26, 2012
RAI 505 — 07.05-10	March 8, 2012
RAI 505 — 07.08-47	April 26, 2012
RAI 505 — 07.09-71	April 5, 2012

Sincerely,

Dennis Williford, P.E.
U.S. EPR Design Certification Licensing Manager
AREVA NP Inc.

7207 IBM Drive, Mail Code CLT 2B
Charlotte, NC 28262
Phone: 704-805-2223
Email: Dennis.Williford@areva.com

From: WILLIFORD Dennis (RS/NB)
Sent: Thursday, December 15, 2011 1:49 PM
To: Getachew.Tesfaye@nrc.gov
Cc: BENNETT Kathy (RS/NB); DELANO Karen (RS/NB); ROMINE Judy (RS/NB); RYAN Tom (RS/NB)
Subject: Response to U.S. EPR Design Certification Application RAI No. 505 (5902,5735,5869,5754,5803,5950,5744), FSAR Ch. 7, Supplement 6

Getachew,

On September 29, 2011, AREVA NP Inc. provided a schedule for technically correct and complete responses to the 34 questions in RAI 505. In Supplement 1 sent on October 27, 2011, and Supplement 2 sent on November 17, 2011, AREVA NP provided a revised schedule for technically correct and complete responses

to 33 questions and a preliminary revised schedule for Question 07.01-33. AREVA NP provided Supplement 3 on November 22, 2011 to provide a final response to 4 questions. On December 9, 2011, AREVA NP provided Supplement 4 to revise the schedule for 7 questions. On December 14, 2011, AREVA NP provided Supplement 5 to revise the schedule for 5 questions.

The attached file, "RAI 505 Supplement 6 Response US EPR DC.pdf" provides technically correct and complete responses to 6 of the remaining 30 questions. Appended to this file are affected pages of the U.S. EPR Final Safety Analysis Report in redline-strikeout format which support the responses. Also appended to this file are affected pages of Technical Reports ANP-10304 and ANP-10309P. Revisions to these Technical Reports will be submitted by separate letter after completion of all responses to RAI 505.

The following table indicates the respective pages in the response document, "RAI 505 Supplement 6 Response US EPR DC.pdf," that contain AREVA NP's response to the subject questions.

Question #	Start Page	End Page
RAI 505 — 07.03-37	2	3
RAI 505 — 07.04-15	4	5
RAI 505 — 07.05-11	6	6
RAI 505 — 07.08-43	7	8
RAI 505 — 07.08-45	9	10
RAI 505 — 07.08-49	11	12

The schedule for a technically correct and complete response to the remaining 24 questions remains unchanged. The preliminary schedule for the response to Question 07.01-33 is being reevaluated and a new supplement with a revised schedule will be transmitted by January 25, 2012.

Question #	Response Date
RAI 505 — 07.01-33	January 25, 2012
RAI 505 — 07.01-34	January 10, 2012
RAI 505 — 07.01-35	February 9, 2012
RAI 505 — 07.01-36	January 10, 2012
RAI 505 — 07.01-37	January 19, 2012
RAI 505 — 07.01-38	January 10, 2012
RAI 505 — 07.01-39	January 10, 2012
RAI 505 — 07.01-40	January 10, 2012
RAI 505 — 07.01-41	January 10, 2012
RAI 505 — 07.01-42	January 10, 2012
RAI 505 — 07.01-44	January 10, 2012
RAI 505 — 07.01-45	February 9, 2012
RAI 505 — 07.01-46	February 9, 2012
RAI 505 — 07.01-47	January 10, 2012
RAI 505 — 07.01-48	January 10, 2012
RAI 505 — 07.01-49	January 10, 2012
RAI 505 — 07.01-50	January 10, 2012
RAI 505 — 07.01-51	January 10, 2012
RAI 505 — 07.03-38	February 9, 2012

RAI 505 — 07.05-10	January 19, 2012
RAI 505 — 07.08-44	January 10, 2012
RAI 505 — 07.08-47	January 10, 2012
RAI 505 — 07.08-48	January 10, 2012
RAI 505 — 07.09-71	January 10, 2012

Sincerely,

Dennis Williford, P.E.
U.S. EPR Design Certification Licensing Manager
AREVA NP Inc.

7207 IBM Drive, Mail Code CLT 2B
Charlotte, NC 28262
Phone: 704-805-2223
Email: Dennis.Williford@areva.com

From: WILLIFORD Dennis (RS/NB)
Sent: Wednesday, December 14, 2011 11:30 AM
To: Getachew.Tesfaye@nrc.gov
Cc: BENNETT Kathy (RS/NB); DELANO Karen (RS/NB); ROMINE Judy (RS/NB); RYAN Tom (RS/NB)
Subject: Response to U.S. EPR Design Certification Application RAI No. 505 (5902,5735,5869,5754,5803,5950,5744), FSAR Ch. 7, Supplement 5

Getachew,

On September 29, 2011, AREVA NP Inc. provided a schedule for technically correct and complete responses to the 34 questions in RAI 505. In Supplement 1 sent on October 27, 2011, and Supplement 2 sent on November 17, 2011, AREVA NP provided a revised schedule for technically correct and complete responses to 33 questions and a preliminary revised schedule for Question 07.01-33. AREVA NP provided Supplement 3 on November 22, 2011 to provide a final response to 4 questions. On December 9, 2011, AREVA NP provided a revised schedule for 7 questions.

The schedule for the response to four questions (Questions 7.1-35, 7.1-45, 7.1-46, and 7.3-38) is being changed, as indicated in bold below. In addition, the preliminary schedule for the response to Question 07.01-33 has been revised as indicated. This schedule is being reevaluated and a new supplement with a revised schedule will be transmitted by January 25, 2012. The schedule for a technically correct and complete response to the remaining 25 questions remains unchanged.

Question #	Response Date
RAI 505 — 07.01-33	January 25, 2012
RAI 505 — 07.01-34	January 10, 2012
RAI 505 — 07.01-35	February 9, 2012
RAI 505 — 07.01-36	January 10, 2012
RAI 505 — 07.01-37	January 19, 2012
RAI 505 — 07.01-38	January 10, 2012
RAI 505 — 07.01-39	January 10, 2012
RAI 505 — 07.01-40	January 10, 2012

RAI 505 — 07.01-41	January 10, 2012
RAI 505 — 07.01-42	January 10, 2012
RAI 505 — 07.01-44	January 10, 2012
RAI 505 — 07.01-45	February 9, 2012
RAI 505 — 07.01-46	February 9, 2012
RAI 505 — 07.01-47	January 10, 2012
RAI 505 — 07.01-48	January 10, 2012
RAI 505 — 07.01-49	January 10, 2012
RAI 505 — 07.01-50	January 10, 2012
RAI 505 — 07.01-51	January 10, 2012
RAI 505 — 07.03-37	January 19, 2012
RAI 505 — 07.03-38	February 9, 2012
RAI 505 — 07.04-15	January 19, 2012
RAI 505 — 07.05-10	January 19, 2012
RAI 505 — 07.05-11	January 19, 2012
RAI 505 — 07.08-43	January 19, 2012
RAI 505 — 07.08-44	January 10, 2012
RAI 505 — 07.08-45	January 10, 2012
RAI 505 — 07.08-47	January 10, 2012
RAI 505 — 07.08-48	January 10, 2012
RAI 505 — 07.08-49	January 19, 2012
RAI 505 — 07.09-71	January 10, 2012

Sincerely,

Dennis Williford, P.E.

U.S. EPR Design Certification Licensing Manager

AREVA NP Inc.

7207 IBM Drive, Mail Code CLT 2B

Charlotte, NC 28262

Phone: 704-805-2223

Email: Dennis.Williford@areva.com

From: RYAN Tom (RS/NB)

Sent: Friday, December 09, 2011 8:35 AM

To: Getachew.Tesfaye@nrc.gov

Cc: BENNETT Kathy (RS/NB); DELANO Karen (RS/NB); ROMINE Judy (RS/NB); RYAN Tom (RS/NB); WILLIFORD Dennis (RS/NB)

Subject: Response to U.S. EPR Design Certification Application RAI No. 505 (5902,5735,5869,5754,5803,5950,5744), FSAR Ch. 7, Supplement 4

Getachew,

On September 29, 2011, AREVA NP Inc. provided a schedule for technically correct and complete responses to the 34 questions in RAI 505. On October 27, 2011, and November 17, 2011, AREVA NP provided a revised schedule for technically correct and complete responses to 33 questions and a preliminary revised schedule for Question 07.01-33. On November 22, 2011, AREVA NP provided a final response to four questions.

The schedule for the response to the questions 7.1-37, 7.3-37, 7.4-15, 7.5-10, 7.5-11, 7.8-43, and 7.8-49 is being changed and indicated in bold below, the remaining 23 questions remains unchanged, as indicated below. In addition, the preliminary schedule for a response to Question 07.01-33 remains unchanged. The schedule for Question 07.01-33 is being reevaluated and a new supplement with a revised schedule will be transmitted by December 14, 2011.

Question #	Response Date
RAI 505 — 07.01-33	December 14, 2011
RAI 505 — 07.01-34	January 10, 2012
RAI 505 — 07.01-35	January 10, 2012
RAI 505 — 07.01-36	January 10, 2012
RAI 505 — 07.01-37	January 19, 2012
RAI 505 — 07.01-38	January 10, 2012
RAI 505 — 07.01-39	January 10, 2012
RAI 505 — 07.01-40	January 10, 2012
RAI 505 — 07.01-41	January 10, 2012
RAI 505 — 07.01-42	January 10, 2012
RAI 505 — 07.01-44	January 10, 2012
RAI 505 — 07.01-45	January 10, 2012
RAI 505 — 07.01-46	January 10, 2012
RAI 505 — 07.01-47	January 10, 2012
RAI 505 — 07.01-48	January 10, 2012
RAI 505 — 07.01-49	January 10, 2012
RAI 505 — 07.01-50	January 10, 2012
RAI 505 — 07.01-51	January 10, 2012
RAI 505 — 07.03-37	January 19, 2012
RAI 505 — 07.03-38	January 10, 2012
RAI 505 — 07.04-15	January 19, 2012
RAI 505 — 07.05-10	January 19, 2012
RAI 505 — 07.05-11	January 19, 2012
RAI 505 — 07.08-43	January 19, 2012
RAI 505 — 07.08-44	January 10, 2012
RAI 505 — 07.08-45	January 10, 2012
RAI 505 — 07.08-47	January 10, 2012
RAI 505 — 07.08-48	January 10, 2012
RAI 505 — 07.08-49	January 19, 2012
RAI 505 — 07.09-71	January 10, 2012

Sincerely,

Tom Ryan for
Dennis Williford, P.E.
U.S. EPR Design Certification Licensing Manager
AREVA NP Inc.

From: WILLIFORD Dennis (RS/NB)
Sent: Tuesday, November 22, 2011 2:51 PM
To: Getachew.Tesfaye@nrc.gov
Cc: BENNETT Kathy (RS/NB); DELANO Karen (RS/NB); ROMINE Judy (RS/NB); RYAN Tom (RS/NB)
Subject: Response to U.S. EPR Design Certification Application RAI No. 505 (5902,5735,5869,5754,5803,5950,5744), FSAR Ch. 7, Supplement 3

Getachew,

On September 29, 2011, AREVA NP Inc. provided a schedule for technically correct and complete responses to the 34 questions in RAI 505. On October 27, 2011, and November 17, 2011, AREVA NP provided a revised schedule for technically correct and complete responses to 33 questions and a preliminary revised schedule for Question 07.01-33.

After discussions with NRC staff, the attached file, "RAI 505 Supplement 3 Response US EPR DC.pdf" provides technically correct and complete responses to 4 of the 34 questions. Appended to this file are affected pages of the U.S. EPR Final Safety Analysis Report in redline-strikeout format which support the responses to RAI 505 Question 07.07-23, Question 07.08 -46 and Question 07.09.02-72.

The following table indicates the respective pages in the response document, "RAI 505 Supplement 3 Response US EPR DC.pdf," that contain AREVA NP's response to the subject questions.

Question #	Start Page	End Page
RAI 505 — 07.01-43	2	3
RAI 505 — 07.07-23	4	4
RAI 505 — 07.08-46	5	5
RAI 505 — 07.09-72	6	7

The schedule for the response to the remaining 30 questions remains unchanged, as indicated below. In addition, the preliminary revised schedule for a response to Question 07.01-33 remains unchanged. The schedule for Question 07.01-33 is being reevaluated and a new supplement with a revised schedule will be transmitted by December 14, 2011.

Question #	Response Date
RAI 505 — 07.01-33	December 14, 2011
RAI 505 — 07.01-34	January 10, 2012
RAI 505 — 07.01-35	January 10, 2012
RAI 505 — 07.01-36	January 10, 2012
RAI 505 — 07.01-37	December 11, 2011
RAI 505 — 07.01-38	January 10, 2012
RAI 505 — 07.01-39	January 10, 2012
RAI 505 — 07.01-40	January 10, 2012

RAI 505 — 07.01-41	January 10, 2012
RAI 505 — 07.01-42	January 10, 2012
RAI 505 — 07.01-44	January 10, 2012
RAI 505 — 07.01-45	January 10, 2012
RAI 505 — 07.01-46	January 10, 2012
RAI 505 — 07.01-47	January 10, 2012
RAI 505 — 07.01-48	January 10, 2012
RAI 505 — 07.01-49	January 10, 2012
RAI 505 — 07.01-50	January 10, 2012
RAI 505 — 07.01-51	January 10, 2012
RAI 505 — 07.03-37	December 11, 2011
RAI 505 — 07.03-38	January 10, 2012
RAI 505 — 07.04-15	December 11, 2011
RAI 505 — 07.05-10	December 11, 2011
RAI 505 — 07.05-11	December 11, 2011
RAI 505 — 07.08-43	December 11, 2011
RAI 505 — 07.08-44	January 10, 2012
RAI 505 — 07.08-45	January 10, 2012
RAI 505 — 07.08-47	January 10, 2012
RAI 505 — 07.08-48	January 10, 2012
RAI 505 — 07.08-49	December 11, 2011
RAI 505 — 07.09-71	January 10, 2012

Sincerely,

Dennis Williford, P.E.
U.S. EPR Design Certification Licensing Manager
AREVA NP Inc.

7207 IBM Drive, Mail Code CLT 2B
Charlotte, NC 28262
Phone: 704-805-2223
Email: Dennis.Williford@areva.com

From: WILLIFORD Dennis (RS/NB)
Sent: Thursday, November 17, 2011 5:44 PM
To: Getachew.Tesfaye@nrc.gov
Cc: BENNETT Kathy (RS/NB); DELANO Karen (RS/NB); ROMINE Judy (RS/NB); RYAN Tom (RS/NB)
Subject: Response to U.S. EPR Design Certification Application RAI No. 505 (5902,5735,5869,5754,5803,5950,5744), FSAR Ch. 7, Supplement 2

Getachew,

On September 29, 2011, AREVA NP Inc. provided a schedule for technically correct and complete responses to the 34 questions in RAI 505. On October 27, 2011, AREVA NP provided a revised schedule for technically correct and complete responses to 13 questions and a preliminary revised schedule for Question 07.01-33.

The schedule for the final responses has been revised, as indicated in bold below. In addition, the preliminary revised schedule for a response to Question 07.01-33 has been revised. The schedule for Question 07.01-33 is being reevaluated and a new supplement with a revised schedule will be transmitted by December 14, 2011.

Question #	Response Date
RAI 505 — 07.01-33	December 14, 2011
RAI 505 — 07.01-34	January 10, 2012
RAI 505 — 07.01-35	January 10, 2012
RAI 505 — 07.01-36	January 10, 2012
RAI 505 — 07.01-37	December 11, 2011
RAI 505 — 07.01-38	January 10, 2012
RAI 505 — 07.01-39	January 10, 2012
RAI 505 — 07.01-40	January 10, 2012
RAI 505 — 07.01-41	January 10, 2012
RAI 505 — 07.01-42	January 10, 2012
RAI 505 — 07.01-43	December 11, 2011
RAI 505 — 07.01-44	January 10, 2012
RAI 505 — 07.01-45	January 10, 2012
RAI 505 — 07.01-46	January 10, 2012
RAI 505 — 07.01-47	January 10, 2012
RAI 505 — 07.01-48	January 10, 2012
RAI 505 — 07.01-49	January 10, 2012
RAI 505 — 07.01-50	January 10, 2012
RAI 505 — 07.01-51	January 10, 2012
RAI 505 — 07.03-37	December 11, 2011
RAI 505 — 07.03-38	January 10, 2012
RAI 505 — 07.04-15	December 11, 2011
RAI 505 — 07.05-10	December 11, 2011
RAI 505 — 07.05-11	December 11, 2011
RAI 505 — 07.07-23	December 11, 2011
RAI 505 — 07.08-43	December 11, 2011
RAI 505 — 07.08-44	January 10, 2012
RAI 505 — 07.08-45	January 10, 2012
RAI 505 — 07.08-46	December 11, 2011
RAI 505 — 07.08-47	January 10, 2012
RAI 505 — 07.08-48	January 10, 2012
RAI 505 — 07.08-49	December 11, 2011
RAI 505 — 07.09-71	January 10, 2012
RAI 505 — 07.09-72	January 10, 2012

Sincerely,

Dennis Williford, P.E.
U.S. EPR Design Certification Licensing Manager

AREVA NP Inc.

7207 IBM Drive, Mail Code CLT 2B

Charlotte, NC 28262

Phone: 704-805-2223

Email: Dennis.Williford@areva.com

From: WILLIFORD Dennis (RS/NB)**Sent:** Thursday, October 27, 2011 11:22 AM**To:** Getachew.Tesfaye@nrc.gov**Cc:** BENNETT Kathy (RS/NB); DELANO Karen (RS/NB); ROMINE Judy (RS/NB); RYAN Tom (RS/NB)**Subject:** Response to U.S. EPR Design Certification Application RAI No. 505 (5902,5735,5869,5754,5803,5950,5744), FSAR Ch. 7, Supplement 1

Getachew,

On September 29, 2011, AREVA NP Inc. provided a schedule for a technically correct and complete response to the 34 questions in RAI 505.

The schedule for the final response to Questions 07.01-38, 07.01-44, 07.01-45, 07.01-46, 07.01-47, 07.01-48, 07.01-49, 07.01-50, 07.01-51, 07.03-38, 07.08-43, 07.08-47, 07.08-48 has been revised, as indicated in bold below. In addition, a preliminary revised schedule for a technically correct and complete response to Question 07.01-33 is provided below. The schedule for Question 07.01-33 is being reevaluated and a new supplement with a revised schedule will be transmitted by November 17, 2011.

Question #	Response Date
RAI 505 — 07.01-33	November 17, 2011
RAI 505 — 07.01-34	December 8, 2011
RAI 505 — 07.01-35	November 17, 2011
RAI 505 — 07.01-36	December 8, 2011
RAI 505 — 07.01-37	December 8, 2011
RAI 505 — 07.01-38	January 10, 2012
RAI 505 — 07.01-39	December 8, 2011
RAI 505 — 07.01-40	December 8, 2011
RAI 505 — 07.01-41	November 17, 2011
RAI 505 — 07.01-42	December 20, 2011
RAI 505 — 07.01-43	November 17, 2011
RAI 505 — 07.01-44	January 10, 2012
RAI 505 — 07.01-45	January 10, 2012
RAI 505 — 07.01-46	January 10, 2012
RAI 505 — 07.01-47	January 10, 2012
RAI 505 — 07.01-48	January 10, 2012
RAI 505 — 07.01-49	January 10, 2012
RAI 505 — 07.01-50	January 10, 2012
RAI 505 — 07.01-51	January 10, 2012
RAI 505 — 07.03-37	November 17, 2011
RAI 505 — 07.03-38	January 10, 2012
RAI 505 — 07.04-15	November 17, 2011

RAI 505 — 07.05-10	November 17, 2011
RAI 505 — 07.05-11	November 17, 2011
RAI 505 — 07.07-23	November 17, 2011
RAI 505 — 07.08-43	January 10, 2012
RAI 505 — 07.08-44	December 8, 2011
RAI 505 — 07.08-45	December 8, 2011
RAI 505 — 07.08-46	December 8, 2011
RAI 505 — 07.08-47	January 10, 2012
RAI 505 — 07.08-48	January 10, 2012
RAI 505 — 07.08-49	November 17, 2011
RAI 505 — 07.09-71	December 8, 2011
RAI 505 — 07.09-72	December 8, 2011

Sincerely,

Dennis Williford, P.E.
U.S. EPR Design Certification Licensing Manager
AREVA NP Inc.

7207 IBM Drive, Mail Code CLT 2B
Charlotte, NC 28262
Phone: 704-805-2223
Email: Dennis.Williford@areva.com

From: WILLIFORD Dennis (RS/NB)
Sent: Thursday, September 29, 2011 11:04 AM
To: Getachew.Tesfaye@nrc.gov
Cc: BENNETT Kathy (RS/NB); DELANO Karen (RS/NB); ROMINE Judy (RS/NB); RYAN Tom (RS/NB)
Subject: Response to U.S. EPR Design Certification Application RAI No. 505 (5902,5735,5869,5754,5803,5950,5744), FSAR Ch. 7

Getachew,

Attached please find AREVA NP Inc.'s response to the subject request for additional information (RAI). The attached file, "RAI 505 Response US EPR DC.pdf," provides a schedule since a technically correct and complete response to the 34 questions cannot be provided at this time.

The following table indicates the respective pages in the response document, "RAI 505 Response US EPR DC.pdf," that contain AREVA NP's response to the subject questions.

Question #	Start Page	End Page
RAI 505 — 07.01-33	2	2
RAI 505 — 07.01-34	3	3
RAI 505 — 07.01-35	4	4
RAI 505 — 07.01-36	5	5
RAI 505 — 07.01-37	6	6
RAI 505 — 07.01-38	7	7
RAI 505 — 07.01-39	8	8
RAI 505 — 07.01-40	9	9

RAI 505 — 07.01-41	10	10
RAI 505 — 07.01-42	11	11
RAI 505 — 07.01-43	12	12
RAI 505 — 07.01-44	13	13
RAI 505 — 07.01-45	14	14
RAI 505 — 07.01-46	15	15
RAI 505 — 07.01-47	16	16
RAI 505 — 07.01-48	17	18
RAI 505 — 07.01-49	19	19
RAI 505 — 07.01-50	20	20
RAI 505 — 07.01-51	21	22
RAI 505 — 07.03-37	23	23
RAI 505 — 07.03-38	24	24
RAI 505 — 07.04-15	25	25
RAI 505 — 07.05-10	26	26
RAI 505 — 07.05-11	27	27
RAI 505 — 07.07-23	28	28
RAI 505 — 07.08-43	29	29
RAI 505 — 07.08-44	30	30
RAI 505 — 07.08-45	31	31
RAI 505 — 07.08-46	32	32
RAI 505 — 07.08-47	33	33
RAI 505 — 07.08-48	34	34
RAI 505 — 07.08-49	35	35
RAI 505 — 07.09-71	36	36
RAI 505 — 07.09-72	37	37

A complete answer is not provided for the 34 questions. The schedule for a technically correct and complete response to these questions is provided below.

Please note that the date for the response to Question 07.01-33 is a commitment date to provide a final schedule for the response in a follow-up letter.

Question #	Response Date
RAI 505 — 07.01-33	October 27, 2011
RAI 505 — 07.01-34	December 8, 2011
RAI 505 — 07.01-35	November 17, 2011
RAI 505 — 07.01-36	December 8, 2011
RAI 505 — 07.01-37	December 8, 2011
RAI 505 — 07.01-38	December 20, 2011
RAI 505 — 07.01-39	December 8, 2011
RAI 505 — 07.01-40	December 8, 2011
RAI 505 — 07.01-41	November 17, 2011
RAI 505 — 07.01-42	December 20, 2011
RAI 505 — 07.01-43	November 17, 2011

RAI 505 — 07.01-44	December 20, 2011
RAI 505 — 07.01-45	December 20, 2011
RAI 505 — 07.01-46	December 20, 2011
RAI 505 — 07.01-47	December 8, 2011
RAI 505 — 07.01-48	December 20, 2011
RAI 505 — 07.01-49	December 20, 2011
RAI 505 — 07.01-50	December 20, 2011
RAI 505 — 07.01-51	December 20, 2011
RAI 505 — 07.03-37	November 17, 2011
RAI 505 — 07.03-38	December 20, 2011
RAI 505 — 07.04-15	November 17, 2011
RAI 505 — 07.05-10	November 17, 2011
RAI 505 — 07.05-11	November 17, 2011
RAI 505 — 07.07-23	November 17, 2011
RAI 505 — 07.08-43	December 20, 2011
RAI 505 — 07.08-44	December 8, 2011
RAI 505 — 07.08-45	December 8, 2011
RAI 505 — 07.08-46	December 8, 2011
RAI 505 — 07.08-47	December 20, 2011
RAI 505 — 07.08-48	December 20, 2011
RAI 505 — 07.08-49	November 17, 2011
RAI 505 — 07.09-71	December 8, 2011
RAI 505 — 07.09-72	December 8, 2011

Sincerely,

Dennis Williford, P.E.
U.S. EPR Design Certification Licensing Manager
AREVA NP Inc.

7207 IBM Drive, Mail Code CLT 2B
Charlotte, NC 28262
Phone: 704-805-2223
Email: Dennis.Williford@areva.com

From: Tesfaye, Getachew [<mailto:Getachew.Tesfaye@nrc.gov>]

Sent: Tuesday, August 30, 2011 1:23 PM

To: ZZ-DL-A-USEPR-DL

Cc: Zhang, Deanna; Morton, Wendell; Spaulding, Deirdre; Mott, Kenneth; Truong, Tung; Zhao, Jack; Mills, Daniel; Jackson, Terry; Canova, Michael; Colaccino, Joseph; ArevaEPRDCPEm Resource

Subject: U.S. EPR Design Certification Application RAI No. 505 (5902,5735,5869,5754,5803,5950,5744), FSAR Ch. 7

Attached please find the subject requests for additional information (RAI). A draft of the RAI was provided to you on August 12, 2011, and discussed with your staff on August 22 and 25, 2011. No change is made to the draft RAI as a result of those discussions. The schedule we have established for review of your application assumes technically correct and complete responses within 30 days of receipt of RAIs. For any RAIs that cannot be answered within 30 days, it is expected that a date for receipt of this information will be provided to the staff within the 30 day period so that the staff can assess how this information will impact the published schedule.

Thanks,
Getachew Tesfaye
Sr. Project Manager
NRO/DNRL/NARP
(301) 415-3361

Hearing Identifier: AREVA_EPR_DC_RAIs
Email Number: 3928

Mail Envelope Properties (2FBE1051AEB2E748A0F98DF9EEE5A5D4C81D22)

Subject: Response to U.S. EPR Design Certification Application RAI No. 505
(5902,5735,5869,5754,5803,5950,5744), FSAR Ch. 7, Supplement 21
Sent Date: 5/29/2012 11:23:26 AM
Received Date: 5/29/2012 11:24:25 AM
From: WILLIFORD Dennis (AREVA)

Created By: Dennis.Williford@areva.com

Recipients:
"BENNETT Kathy (AREVA)" <Kathy.Bennett@areva.com>
Tracking Status: None
"DELANO Karen (AREVA)" <Karen.Delano@areva.com>
Tracking Status: None
"ROMINE Judy (AREVA)" <Judy.Romine@areva.com>
Tracking Status: None
"RYAN Tom (AREVA)" <Tom.Ryan@areva.com>
Tracking Status: None
"Tsfaye, Getachew" <Getachew.Tsfaye@nrc.gov>
Tracking Status: None

Post Office: auscharm02.adom.ad.corp

Files	Size	Date & Time
MESSAGE	76892	5/29/2012 11:24:25 AM
RAI 505 Supplement 21 Response US EPR DC.pdf		540029

Options
Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received:

Response to
Request for Additional Information No. 505 (5902,5735,5869,5754,5803,5950,5744),
Revision 0, Supplement 21

8/30/2011

U. S. EPR Standard Design Certification
AREVA NP Inc.
Docket No. 52-020

SRP Section: 07.01 - Instrumentation and Controls - Introduction

SRP Section: 07.03 - Engineered Safety Features Systems

SRP Section: 07.04 - Safe Shutdown Systems

SRP Section: 07.05 - Information Systems Important to Safety

SRP Section: 07.07 - Control Systems

SRP Section: 07.08 - Diverse Instrumentation and Control Systems

SRP Section: 07.09 - Data Communication Systems

Application Section: FSAR Chapter 7

QUESTIONS for Instrumentation, Controls and Electrical Engineering 1
(AP1000/EPR Projects) (ICE1)

Question 07.01-49:**OPEN ITEM**

Provide information on how the Safety Automation System (SAS) meets the requirements of IEEE Std. 603-1998, Clauses 6.6 and 6.7.

Clause 6.6 of IEEE Std. 603-1991 requires, in part, that whenever the applicable permissive conditions are not met, a safety system shall automatically prevent the activation of an operating bypass or initiate the appropriate safety function(s). The operator may take action to prevent the unnecessary initiation of a protective action. Clause 6.7 of IEEE Std. 603-1991 requires, in part, that a safety system be able to retain the capability to accomplish its safety function while sense and command features equipment is in maintenance bypass. SRP Appendix 7.1-C provides guidance on meeting the requirements of Clause 6.6 and 6.7 of IEEE Std. 603-1991.

In response to RAI 78, RAI 78, Questions 14.03.05-3&4 (Supplement 2), operating bypass functionality for SAS is verified by ITAAC Item 4.3 in U.S. EPR FSAR, Tier 1, Table 2.4.1-7. The PS is a standby system, with limited interaction with SAS. SAS contains a significant number of continuous functions that are outside the bounds of system interaction with the PS, which would not be verified by ITAAC Item 4.3. The staff requests the applicant provide more information on how the applicant intends to verify how SAS meets the requirements of IEEE Std. 603-1998, Clause 6.6. Similarly, in the response to RAI 78, RAI 78, Questions 14.03.05-3&4 (Supplement 2), the applicant states the maintenance bypass functionality is verified by ITAAC Item 4.18 in Tier 1, Table 2.4.4-6. However, this ITAAC addresses performance of automatic functions, but does not identify maintenance bypasses.

The staff requests the applicant to describe how the maintenance bypasses are addressed with SAS.

Response to Question 07.01-49:

The SAS meets the requirements of IEEE 603-1998, Clauses 6.6 and 6.7. The only type of operating bypass in the U.S EPR design relevant to the SAS is a permissive. A permissive signal is used to enable, disable, or modify the operation of SAS functions based on plant conditions. The SAS logic diagrams specify the operating bypasses or permissives that would otherwise prevent certain modes of operation such as low head safety injection automatic trip. The operating bypasses are automatically removed when plant conditions change to an operating mode in which the protective actions are required to be operable in order to mitigate the consequences of a design basis event.

There are two SAS functions in the U.S EPR design that require an operating bypass. They are as follows:

- Safety Injection and Heat Removal System Automatic Trip of LHSI Pump (in RHR Mode) on Low ΔP_{sat} .
- Safety Injection and Heat Removal System Automatic Trip of LHSI Pump (in RHR Mode) on Low Loop Level.

Inspections, Tests, Analyses, and Acceptance Criteria (ITAAC) Item 4.23 will be added to U.S EPR FSAR Tier 1, Section 2.4.4, to verify that permissive P15 provides operating bypass capability for the corresponding SAS functions.

The SAS is put in maintenance bypass during periodic testing. Only one division at a time can be placed in maintenance bypass.

ITAAC Item 4.14 in U.S EPR FSAR Tier 1, Table 2.4.4-6, verifies that SAS is capable of performing its safety function when SAS equipment is in maintenance bypass. Bypassed SAS equipment is indicated in the MCR.

FSAR Impact:

U.S. EPR FSAR, Tier 1, Section 2.4.4, will be updated as described in the response and indicated on the enclosed markup.

U.S. EPR Final Safety Analysis Report Markups

- By introducing and varying, a substitute input of the same nature as the measured variable.
- By cross-checking between channels that bear a known relationship to each other.
- By specifying equipment that is stable and the period of time it retains its calibration during post-accident conditions.

4.16 Deleted.

4.17 Hardwired disconnects exist between the service unit (SU) and each divisional monitoring and service interface (MSI) of the SAS. The hardwired disconnects prevent the connection of the SU to more than a single division of the SAS.

4.18 The SAS performs the automatic functions listed in Table 2.4.4-5—Safety Automation System Automatic Functions.

4.19 During data communication, the SAS function processors receive only the pre-defined messages for that specific function processor. Other messages are ignored.

4.20 SAS self-test features are capable of detecting faults consistent with the requirements of the SAS.

4.21 SAS connections to the SICS are hardwired for manual grouped controls.

4.22 SAS manual grouped controls and indications are available on the SICS in the MCR.

4.23 Permissive P15 provides operating bypass capability for the following SAS functions:

- Safety Injection and Heat Removal System - Automatic Trip of LHSI Pump (in RHR Mode) on Low Delta Psat.
- Safety Injection and Heat Removal System - Automatic Trip of LHSI Pump (in RHR Mode) on Low Loop Level.

5.0 Electrical Power Design Features

5.1 ~~Class 1E SAS~~ The components designated as Class 1E in Table 2.4.4-1 are powered from a Class 1E division as listed in Table 2.4.4-1 in a normal or alternate feed condition.

6.0 Environmental Qualification

6.1 Components listed as Class 1E in Table 2.4.4-1 can perform their function under normal environmental conditions, AOOs, and accident and post-accident environmental conditions.

6.07.0 System Inspections, Tests, Analyses, and Acceptance Criteria

Table 2.4.4-6 lists the SAS ITAAC.

07.01-49

07.01-49

Table 2.4.4-6—Safety Automation System ITAAC (11 Sheets)

	Commitment Wording	Inspections, Tests, Analyses	Acceptance Criteria
4.23	<u>Permissive P15 provides operating bypass capability for the following SAS functions:</u> <ul style="list-style-type: none"> • <u>Safety Injection and Heat Removal System - Automatic Trip of LHSI Pump (in RHR Mode) on Low Delta Psat.</u> • <u>Safety Injection and Heat Removal System - Automatic Trip of LHSI Pump (in RHR Mode) on Low Loop Level.</u> 	<u>A test will be performed using test signals.</u>	<u>A report concludes that Permissive P15 provides operating bypass capability for the following SAS functions:</u> <ul style="list-style-type: none"> • <u>Safety Injection and Heat Removal System - Automatic Trip of LHSI Pump (in RHR Mode) on Low Delta Psat.</u> • <u>Safety Injection and Heat Removal System - Automatic Trip of LHSI Pump (in RHR Mode) on Low Loop Level.</u>
5.1	Class 1E SAS The components <u>designated as Class 1E in Table 2.4.4-1</u> are powered from a Class 1E division <u>as listed in Table 2.4.4-1</u> in a normal or alternate feed condition.	a. Testing will be performed for components identified as Class 1E in Table 2.4.4-1 by providing a test signal in each normally aligned division. b. Testing will be performed for components identified as Class 1E in Table 2.4.4-1 by providing a test signal in each division with the alternate feed aligned to the divisional pair.	a. The test signal provided in the normally aligned division is present at the respective Class 1E components identified in Table 2.4.4-1. b. The test signal provided in each division with the alternate feed aligned to the divisional pair is present at the respective Class 1E components identified in Table 2.4.4-1.