

## **NRR-PMDA-ECapture Resource**

---

**From:** Feintuch, Karl  
**Sent:** Thursday, May 31, 2012 1:50 PM  
**To:** 'Browning, Tony'  
**Subject:** ME8572 - LIC-109 Amendment Acceptance Review Results - acceptable

Subject: ME8572 – LIC-109 Amendment Acceptance Review Results.

In a letter dated May 1, 2012, (ADAMS Accession No. ML12122A212), NextEra Energy Duane Arnold, LLC (the licensee) requested an amendment to the Renewed Facility Operating License for the Duane Arnold Energy Center (DAEC). The request was identified as “License Amendment Request (TSCR-135): Application for One-Time Technical Specification Change Regarding Core Spray Operability during Shutdown Section Affected: 3.3.5.1.”

The proposed amendment would revise the DAEC TS on a one-time basis by adding a note to TS Table 3.3.5.1-1, Function 1 d, Modes 4 and 5, specifying that Function 1 d is not required to be met during RFO 23 in Modes 4 and 5.

For tracking purposes this project was assigned the TAC number ME8572.

The NRC staff found your May 1, 2012 application acceptable for review per the guidance of NRR Office Instruction LIC-109.

Karl Feintuch  
Project Manager  
USNRC  
301-415-3079