

CENGSM

a joint venture of



Constellation
Energy



EDF

P.O. Box 63
Lycoming, NY 13093

NINE MILE POINT NUCLEAR STATION

June 7, 2012

U.S. Nuclear Regulatory Commission
Washington, DC 20555-0001

ATTENTION: Document Control Desk

SUBJECT: Nine Mile Point Nuclear Station
Unit No. 1; Docket No. 50-220

Request to Utilize an Alternative to the Requirements of 10 CFR 50.55a(g) for the Repair of Control Rod Drive Housing Penetrations – Withdrawal of the Portion of the Request Regarding Rotary Peening (TAC No. ME5789)

- REFERENCES:**
- (a) Letter from J. E. Pacher (NMPNS) to Document Control Desk (NRC), dated March 25, 2011, Request to Utilize an Alternative to the Requirements of 10 CFR 50.55a(g) for the Repair of Control Rod Drive Housing Penetrations for the Remainder of the License Renewal Period of Extended Operation
 - (b) Letter from P. M. Swift (NMPNS) to Document Control Desk (NRC), dated September 29, 2011, Request to Utilize an Alternative to the Requirements of 10 CFR 50.55a(g) for the Repair of Control Rod Drive Housing Penetrations – Response to NRC Request for Additional Information (TAC No. ME5789)
 - (c) Letter from P. M. Swift (NMPNS) to Document Control Desk (NRC), dated April 9, 2012, Request to Utilize an Alternative to the Requirements of 10 CFR 50.55a(g) for the Repair of Control Rod Drive Housing Penetrations – Response to NRC Follow-up Request for Additional Information (TAC No. ME5789)

By letter dated March 25, 2011 (Reference a), as supplemented by letters dated September 29, 2011 (Reference b) and April 9, 2012 (Reference c), Nine Mile Point Nuclear Station, LLC (NMPNS) requested NRC approval of an alternative weld repair strategy for Nine Mile Point Unit 1 Control Rod Drive (CRD) housing penetrations. The alternative repair strategy, described in 10 CFR 50.55a Request Number ISI-004, included a variation of the CRD housing penetration welded repair geometry specified in Boiling Water Reactor Vessel and Internals Project (BWRVIP) report BWRVIP-58-A and variations

A047
NRC

from the requirements of the American Society of Mechanical Engineers (ASME) Code, Section XI, and ASME Code Case N-606-1.

Proposed Alternative No. 6 described in 10 CFR 50.55a Request Number 1ISI-004 requested relief from the restriction in ASME Code Case N-606-1 that prohibits peening of the final weld repair layer. NMPNS proposed using a rotary peening process on the final weld layer as an enhancement to decrease the susceptibility of the weld and adjacent stainless steel CRD housing base material heat affected zone to intergranular stress corrosion cracking. Interactions with the NRC staff on the rotary peening process indicate that there are questions regarding this process that cannot be readily resolved at this time. Therefore, NMPNS hereby withdraws Proposed Alternative No. 6 regarding rotary peening and requests that the NRC approve 10 CFR 50.55a Request Number 1ISI-004 without consideration of Proposed Alternative No. 6.

This letter contains no new regulatory commitments. Should you have any questions regarding the information in this submittal, please contact John J. Dosa, Director Licensing, at (315) 349-5219.

Very truly yours,



Paul M. Swift
Manager Engineering Services

PMS/DEV

cc: Regional Administrator, Region I, NRC
Project Manager, NRC
Resident Inspector, NRC