

LimerickNPEM Resource

From: Christopher.Wilson2@exeloncorp.com
Sent: Tuesday, January 10, 2012 3:50 PM
To: Kuntz, Robert
Subject: Feedback on the DRAI package and for the upcoming telecon

Rob,

I looked this package of DRAIs over and compared to the teleconference notes John Hufnagel took and had the following comments which we could discuss on the phone call on Thursday. (**Also for the call we no longer need to discuss 3.3.2.1.13-1 as we now fully understand the question.**)

Regarding **DRAI B.2.1.3-1**:

1. There were no changes to any of the words for the RPV Head Studs AMP (i.e. remove the word "nuts") is this correct?
2. Still ask us to revise the UFSAR supplement to reflect taking an exception. While it is common practice to describe enhancements in the UFSAR supplement it has not been common practice to describe exceptions. As per our first telecon where Bo Pham asked us to identify these type of issues regarding the UFSAR supplement I am doing so now.

Regarding **DRAI B.2.1.26-1 and DRAI 3.1.1.38-1 (different reviewers but related issue)**

Regarding DRAI 3.1.1.38-1, the Background and Issue discuss a topic discussed at length during the AMP Audit with Dave Pelton and Michelle Kirchline. Based on Dave Pelton's verbal acceptance of our explanation of the issue, we were not expecting this RAI. Are the questions being asked just to get our response on the docket? Anyway, DRAI B.2.1.26-1 requests revision to LRA Section B.2.1.26 and justification for the use of the Inspection of Internal Surfaces AMP for managing "loss of fracture toughness", which is added to that program only for the CASS RWCU pumps that are the subject of DRAI 3.1.1.38-1. Requests 4 and 5 in DRAI 3.1.1.38-1 are essentially redundant to DRAI B.2.1.26-1 relative to impact on the Internal Surfaces AMP and revision to the LRA. Can DRAI B.2.1.26-1 be combined with DRAI 3.1.1.38-1 to avoid cross references between the Responses relative to the LRA changes that are required by DRAI B.2.1.26?

The above two issues are more significant/complex so I thought it better to give them to you ahead of time

Thanks

Chris Wilson
Exelon Nuclear
KSQ License Renewal
610-765-5667 (office) 609-709-3249 (cell)
200 Exelon Way, KSA/2-E

From: Kuntz, Robert [<mailto:Robert.Kuntz@nrc.gov>]
Sent: Tuesday, January 10, 2012 7:16 AM
To: Wilson, Christopher D:(GenCo-Nuc)
Subject: DRAFT Request for Information

Chris,

Attached is a DRAFT Request for Information related to the Limerick Generating Station license renewal application. The attached DRAFT RAI is a revision of the draft RAI discussed in the teleconference last Wednesday. The changes are:

Deletion of DRAI 3.3.2.21-1

Revision to DRAI B.2.1.12-1

Addition of DRAI B.2.1.13-2 (this is a revision to DRAI 3.3.2.21-1 that required clarity. The staff felt that renumbering was appropriate).

If you require clarification on the attached please let me know.

Robert Kuntz

Sr. Project Manager

NRR/ADRO/DLR/RPB1

(301) 415-3733

robert.kuntz@nrc.gov

***** This e-mail and any of its attachments may contain Exelon Corporation proprietary information, which is privileged, confidential, or subject to copyright belonging to the Exelon Corporation family of Companies. This e-mail is intended solely for the use of the individual or entity to which it is addressed. If you are not the intended recipient of this e-mail, you are hereby notified that any dissemination, distribution, copying, or action taken in relation to the contents of and attachments to this e-mail is strictly prohibited and may be unlawful. If you have received this e-mail in error, please notify the sender immediately and permanently delete the original and any copy of this e-mail and any printout. Thank You. *****

Hearing Identifier: Limerick_LR_NonPublic
Email Number: 435

Mail Envelope Properties (9A15F707EB47A04D882D9FEB352EDDF8039934B6)

Subject: Feedback on the DRAI package and for the upcoming telecon
Sent Date: 1/10/2012 3:50:05 PM
Received Date: 1/10/2012 3:50:11 PM
From: Christopher.Wilson2@exeloncorp.com

Created By: Christopher.Wilson2@exeloncorp.com

Recipients:
"Kuntz, Robert" <Robert.Kuntz@nrc.gov>
Tracking Status: None

Post Office: cccmsxch12.energy.power.corp

Files	Size	Date & Time
MESSAGE	3796	1/10/2012 3:50:11 PM

Options
Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received: