



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

July 03, 2012

APPLICANT: NextEra Energy Seabrook, LLC

FACILITY: Seabrook Station

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON APRIL 19, 2012, BETWEEN THE U.S. NUCLEAR REGULATORY COMMISSION AND NEXTERA ENERGY SEABROOK, LLC, CONCERNING THE RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION PERTAINING TO THE SEABROOK STATION LICENSE RENEWAL APPLICATION (TAC NO. ME4028)

The U.S. Nuclear Regulatory Commission (NRC or the staff) and representatives of NextEra Energy Seabrook, LLC (NextEra or the applicant), held a telephone conference call on April 19, 2012, to discuss the response to a request for additional information (RAI) concerning the Seabrook Station license renewal application (LRA).

Enclosure 1 provides a listing of the participants and Enclosure 2 contains a listing of the RAIs that were discussed with the applicant, including a brief description on the status of the item.

The applicant had an opportunity to comment on this summary.

A handwritten signature in black ink, reading "Arthur Cunanan".

Arthur Cunanan, Project Manager
Projects Branch 1
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket No. 50-443

Enclosures:
As stated

cc w/encls: Distribution via Listserv

**TELEPHONE CONFERENCE CALL
SEABROOK STATION
LICENSE RENEWAL APPLICATION**

LIST OF PARTICIPANTS
April 19, 2012

PARTICIPANTS

Arthur Cunanan
Michael Marshall
Abdul Sheikh
Alice Erickson
Richard Cliche
Paul Willoughby
Ken Chew
Ed Carley

AFFILIATIONS

U.S. Nuclear Regulatory Commission (NRC)
NRC
NRC
NRC
NextEra Energy Seabrook, LLC (NextEra)
NextEra
NextEra
NextEra

**TELEPHONE CONFERENCE CALL
SEABROOK STATION
LICENSE RENEWAL APPLICATION**

The U.S. Nuclear Regulatory Commission (NRC or the staff) and representatives of NextEra Energy Seabrook, LLC (the applicant), held a telephone conference call on April 19, 2012, to discuss the response to the request for additional information (RAIs) concerning the Seabrook Station license renewal application (LRA).

RAI B.2.1.28-3 and RAI B.2.1.31-1: Related to the ASME Section XI, Subsection IWL and Structures Monitoring Programs

The staff discussed its concerns with the ASME Section XI, Subsection IWL and Structures Monitoring Programs.

The applicant understands the staff's concern and discussed submitting a plant-specific aging management program related to alkali-silica reaction (ASR) as well as submitting the engineering evaluation on the docket.

The staff will review the applicant's submittal. The staff will not send an RAI. This item is tracked as Open Item OI 3.0.3.2.18-1 in the safety evaluation report with open items.

Memorandum to NextEra Energy Seabrook, LLC from A. Cunanan dated July 03, 2012

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON APRIL 19, 2012,
BETWEEN THE U.S. NUCLEAR REGULATORY COMMISSION AND NEXTERA
ENERGY SEABROOK, LLC, CONCERNING THE RESPONSE TO REQUEST
FOR ADDITIONAL INFORMATION PERTAINING TO THE SEABROOK
STATION LICENSE RENEWAL APPLICATION (TAC NO. ME4028)

DISTRIBUTION:

HARD COPY:

DLR RF

E-MAIL:

PUBLIC

RidsNrrDlr Resource

RidsNrrDlrRpb1 Resource

RidsNrrDlrRpb2 Resource

RidsNrrDlrRarb Resource

RidsNrrDlrRapb Resource

RidsNrrDlrRasb Resource

RidsNrrDlrRerb Resource

RidsNrrDlrRpob Resource

MWentzel

ACunanan

DMorey

JLamb

DMcIntyre, OPA

EDacus, OCA

MSpencer, OGC

WRaymond, RI

DTift, RI

NMcNamara, RI

NSheehan, RI

DScrenci, RI

JJohnson, RI

ABurritt, RI

APPLICANT: NextEra Energy Seabrook, LLC

FACILITY: Seabrook Station

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON APRIL 19, 2012, BETWEEN THE U.S. NUCLEAR REGULATORY COMMISSION AND NEXTERA ENERGY SEABROOK, LLC, CONCERNING THE RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION PERTAINING TO THE SEABROOK STATION LICENSE RENEWAL APPLICATION (TAC NO. ME4028)

The U.S. Nuclear Regulatory Commission (NRC or the staff) and representatives of NextEra Energy Seabrook, LLC (NextEra or the applicant), held a telephone conference call on April 19, 2012, to discuss the response to a request for additional information (RAI) concerning the Seabrook Station license renewal application (LRA).

Enclosure 1 provides a listing of the participants and Enclosure 2 contains a listing of the RAIs that were discussed with the applicant, including a brief description on the status of the item.

The applicant had an opportunity to comment on this summary.

/RA/

Arthur Cunanan, Project Manager
Projects Branch 1
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket No. 50-443

Enclosures:
As stated

cc w/encls: Distribution via Listserv

DISTRIBUTION:
See next page

ADAMS Accession No. ML12164A759

OFFICE	LA:DLR	PM:RPB1:DLR	BC:RPB1:DLR	PM:RPB1:DLR
NAME	YEdmonds	ACunanan	DMorey	ACunanan
DATE	06/ 25 /12	06/ 25 /12	07/ 02 /12	07/ 03 /12

OFFICIAL RECORD COPY