

LimerickNPEm Resource

From: Kuntz, Robert
Sent: Wednesday, September 28, 2011 5:02 PM
To: 'Christopher.Wilson2@exeloncorp.com'
Subject: RE: Audit Week 2 Electrical scheduling requests

Is there some reason to believe that these would be the most likely to experience wetting? Without some rationale other than difficulty we would like to see all of them.

From: Christopher.Wilson2@exeloncorp.com [<mailto:Christopher.Wilson2@exeloncorp.com>]
Sent: Wednesday, September 28, 2011 4:55 PM
To: Kuntz, Robert
Subject: RE: Audit Week 2 Electrical scheduling requests

There are more manholes but these are the easiest to get to and open. The other manholes are very large and require extensive security support to open..... a very labor intensive operation to get them open

Chris Wilson
Exelon Nuclear
KSQ License Renewal
610-765-5667 (office) 609-709-3249 (cell)
200 Exelon Way, KSA/2-E

From: Kuntz, Robert [<mailto:Robert.Kuntz@nrc.gov>]
Sent: Wednesday, September 28, 2011 4:52 PM
To: Wilson, Christopher D:(GenCo-Nuc)
Subject: RE: Audit Week 2 Electrical scheduling requests

Not sure what the manhole entry means. Are there only 2 manholes that contain cables within the scope of license renewal? And your proposal is to only go to either 1 of the 2?

From: Christopher.Wilson2@exeloncorp.com [<mailto:Christopher.Wilson2@exeloncorp.com>]
Sent: Wednesday, September 28, 2011 4:50 PM
To: Kuntz, Robert
Subject: Audit Week 2 Electrical scheduling requests

Rob...input for the electrical walkdowns from engineering

Switchyards:

We need to determine the number of people. "Blue suits" are required as PPE. Additionally, do they want to see the 500 kV yard, the 220 kV yard, or both? The two switchyards are very much separated from each other.

Manholes:

We will be scheduling a walkdown of either nonsafety-related MH-001 or MH-002.

Metal enclosed bus:

The in scope 4 kv metal enclosed bus run from the safeguard transformers, outside the power block on the north side of the Turbine Building, through 239' elevation in the center of the turbine building to the 4 kV switchgear rooms. There is nothing unique/special about this walkdown.

Fuse holders:

There are two panels with in scope fuse holders/metallic clamps that are managed by the XI.E5 AMP. The Unit 2 panel was accessed, opened and photographed by us in LR. The Unit 1 panel was seen from afar, but access to open and photograph was too difficult. This walkdown is to be re-attempted during the upcoming Unit 1 refuel outage. Both panels'

contained fuse holders/metallic clamps are in scope for this AMP, and the AMP is written to address aging effects if they are from frequent manipulation or environmental stressors (i.e., moisture). Did wish to bring up that we might be limited to pointing from afar, depending on the auditors willingness to access certain areas of the reactor building. We should discuss further.

Hope this helps.

Chris

***** This e-mail and any of its attachments may contain Exelon Corporation proprietary information, which is privileged, confidential, or subject to copyright belonging to the Exelon Corporation family of Companies. This e-mail is intended solely for the use of the individual or entity to which it is addressed. If you are not the intended recipient of this e-mail, you are hereby notified that any dissemination, distribution, copying, or action taken in relation to the contents of and attachments to this e-mail is strictly prohibited and may be unlawful. If you have received this e-mail in error, please notify the sender immediately and permanently delete the original and any copy of this e-mail and any printout. Thank You. *****

***** This e-mail and any of its attachments may contain Exelon Corporation proprietary information, which is privileged, confidential, or subject to copyright belonging to the Exelon Corporation family of Companies. This e-mail is intended solely for the use of the individual or entity to which it is addressed. If you are not the intended recipient of this e-mail, you are hereby notified that any dissemination, distribution, copying, or action taken in relation to the contents of and attachments to this e-mail is strictly prohibited and may be unlawful. If you have received this e-mail in error, please notify the sender immediately and permanently delete the original and any copy of this e-mail and any printout. Thank You. *****

Hearing Identifier: Limerick_LR_NonPublic
Email Number: 1110

Mail Envelope Properties (94A2A4408AC65F42AC084527534CF41673D04ACAD7)

Subject: RE: Audit Week 2 Electrical scheduling requests
Sent Date: 9/28/2011 5:02:22 PM
Received Date: 9/28/2011 5:02:00 PM
From: Kuntz, Robert

Created By: Robert.Kuntz@nrc.gov

Recipients:
"Christopher.Wilson2@exeloncorp.com" <Christopher.Wilson2@exeloncorp.com>
Tracking Status: None

Post Office: HQCLSTR01.nrc.gov

Files	Size	Date & Time
MESSAGE	4545	9/28/2011 5:02:00 PM

Options
Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received: