

Serial: RNP-RA/12-0064

JUN 04 2012

United States Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2
DOCKET NO. 50-261/RENEWED LICENSE NO. DPR-23

RESPONSE TO NRC REQUEST FOR ADDITIONAL INFORMATION
RELATED TO RELIEF REQUESTS (RR)-2 FOR THE FIFTH TEN-YEAR
INTERVAL INSERVICE TESTING PROGRAM PLAN

Ladies and Gentlemen:

Carolina Power and Light (CP&L) Company, now doing business as Progress Energy Carolinas, Inc., submitted to NRC by letter dated May 10, 2012, its response to the May 4, 2012, NRC staff request for additional information (RAI). The RAI was discussed in a conference call on May 21, 2012, between H. B. Robinson, Unit 2 (HBRSEP), personnel and NRC Staff personnel involved in the review of these relief requests. As a result of that conference call, additional information was requested by letter dated May 24, 2012.

The response to the May 24, 2012, letter is provided in Attachment I. Attachment II provides a complete copy of the updated IST program plan. The revised relief requests are provided in Attachment 10.2 to that plan.

As stated in the letter dated March 16, 2012, the first refueling outage of the Fifth Ten-Year Interval is Refueling Outage 28 (RO-28), which is currently scheduled to begin in September of 2013. In order to support implementation of the Fifth Ten-Year Interval Inservice Testing Program, and to facilitate preparations for RO-28, CP&L requests NRC approval of the associated relief requests by July 18, 2012.

AD47
NRR

United States Nuclear Regulatory Commission
Serial: RNP-RA/12-0064
Page 2 of 2

This document contains no new Regulatory Commitments. If you have any questions concerning this matter, please contact Richard Hightower, Supervisor – Licensing/Regulatory Programs at (843) 857-1329.

Sincerely,



Sharon A. Wheeler
Manager – Support Services - Nuclear

SAW/rcw

Attachments:

- I. Response to Request for Additional Information
- II. RNP2 Fifth IST Plan Inservice Testing Program

c: Mr. V. M. McCree, NRC, Region II
Ms. A. T. Billoch-Colon, NRC Project Manager, NRR
NRC Resident Inspector, HBRSEP

United States Nuclear Regulatory Commission
Attachment I to Serial: RNP-RA/12-0064
4 Pages (including cover page)

RESPONSE TO THE REQUEST FOR ADDITIONAL INFORMATION

RELATED TO RELIEF REQUESTS (RR)-2

INSERVICE TESTING PROGRAM PLAN FOR THE FIFTH-TEN YEAR INTERVAL

REQUEST FOR ADDITIONAL INFORMATION
REGARDING H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT 2
INSERVICE TESTING PROGRAM PLAN FOR THE FIFTH-TEN YEAR INTERVAL
DOCKET NO. 50-261

By letter to the U.S. Nuclear Regulatory Commission (NRC) dated March 16, 2012 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML 110310012), Carolina Power & Light Company, doing business as Progress Energy Carolinas, Inc., (PEC) submitted Relief Requests (RR)-1, RR-2, and RR-3 for the Inservice Testing Program (IST) Plan for the Fifth 10-Year Interval for the H. B. Robinson Steam Electric Plant, Unit 2 (HBRSEP). By letter dated May 10, 2012 (ADAMS Accession No. ML 12138A041), PEC submitted its response to the NRC's staff request for additional information (RAI), which was sent on May 4, 2012. On May 24, 2012, a second RAI was issued by NRC staff. The response to that request is provided below.

IST-RR-2: "Required Instrumentation Accuracy"

RAI -1:

For the eight pumps in the alternative request, provide the number of times in the current 10-year inservice test interval that non-calibrated flow instrumentation was used during the inservice tests.

CP&L Response

Below is the number of times in the current 10-year inservice test interval that the non-calibrated flow instrumentation was used for the eight pumps:

*SW Pump 'A' – Two times from July 2009 until January 2010

*SW Pump 'B' – Five times from July 2009 until January 2010

SI Pump 'C' – Once

CCW Pumps – None

*H. B. Robinson Steam Electric Plant, Unit 2, (HBRSEP) was not using ultrasonic flow rate measurement to assess SW Pump 'A' & 'B' performance when it became evident that the relatively new permanent flow meter was not measuring flow accurately. Once this became certain, two new calibrated ultrasonic flow meters were purchased and the vendor was brought in to assist with installation and testing. During this interim period, SW Pump 'B' was tested at an increased frequency due to high vibration, accounting for the additional tests. The new calibrated ultrasonic flow meters were received in November, 2009 and installed in December, 2009.

RAI-2:

Clarify when the new flow measurement instruments will be available for use all of the time for the inservice tests

CP&L Response

SW Pump 'A' & SW Pump 'B' utilize the same flow element which has proven to be unreliable. Two ultrasonic flow meters were procured and calibrated and are being used. It is our intent to inspect the in line flow element that failed in RO28 which occurs in the fall of 2013, prior to deciding on a permanent resolution. In the event that HBRSEP cannot return the existing permanent flow meter to service, the existing ultrasonic flow devices may be retained. If the existing permanent flow meter cannot be repaired and both ultrasonic flow meters were off-site for calibration, RR-2 would be needed if no other calibrated instrumentation could be obtained to perform the scheduled test. Consequently, this request may be required for the entire duration of the ten year inservice test interval for SW Pump 'A' & SW Pump 'B', but would only be used if calibrated instrumentation was unavailable at the time of testing.

HBRSEP intends to install a permanent flow meter to support the full flow testing of the Safety Injection Pumps by the fall of 2016. By the fall of 2016, HBRSEP would also have sufficient data to alleviate any concerns regarding the dependability of the permanent flow device recently installed to measure CCW Pump flow rate.

RAI-3:

Describe the actions you will take to minimize the use of non-calibrated flow instruments.

CP&L Response

SW Pump 'A' & SW Pump 'B' utilize the same flow meter. Two independent calibrated units have been procured, calibrated and field tested although only one is required for testing. There will be periods when one of the two meters is sent off-site for repairs and certification, leaving only one calibrated meter available.

For the SI Pumps, this relief impacts the comprehensive pump test. A calibrated meter can be procured or the original meter repaired within the nominal 25% grace period applicable for a biennial test.

A calibrated flow meter would be purchased for the CCW Pumps in the event that the permanent flow element was proven to be erroneous and beyond repair.

HBRSEP will exhibit best efforts to expedite the repair, calibration and re-installation of a meter in the event that a calibrated meter is not available.

RAI-4:

Explain if a commitment will be made to not use the non-calibrated flow instruments on sequential tests for the same pump.

CP&L Response

For the SI pumps, use of the non-calibrated flow instrument will not be necessary; however, the same assurance cannot be provided for a quarterly test, which would involve the SW Pumps 'A' and 'B' and the CCW Pumps. The meter and transducers must be removed and shipped to the vendor and the vendor must reserve time at a separate calibration facility. This time frame varies and cannot be predicted based on discussions with the vendor and previous experience. HBRSEP is uncertain that a 3 month window could be met; however, HBRSEP is confident that a calibrated meter could be available within 6 months from the date of the initial test.

RAI-5:

Provide the amount of "Acceptable Range" margin currently available for each pump.

CP&L Response

Based on most recent tests results, the following is the "Acceptable Range" margin:

SW Pump A – Approximately 450 gpm from the minimum performance requirement
SW Pump B – Approximately 650 gpm from the minimum performance requirement
CCW Pump A – Approximately 2400 gpm from the minimum performance requirement
CCW Pump B - Approximately 2400 gpm from the minimum performance requirement
CCW Pump C - Approximately 1200 gpm from the minimum performance requirement
SI Pump A – Approximately 45 gpm from the minimum performance requirement
SI Pump B – Approximately 55 gpm from the minimum performance requirement
SI Pump C – Approximately 60 gpm from the minimum performance requirement

United States Nuclear Regulatory Commission
Attachment II to Serial: RNP-RA/12-0064
230 Pages (including cover sheet)

H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2

RNP2 FIFTH IST PLAN

INSERVICE TESTING PROGRAM PLAN

H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2

PLANT OPERATING MANUAL

VOLUME 6
PART 1

RNP2 Fifth IST Plan
INSERVICE TESTING PROGRAM

SUMMARY OF CHANGES

Page	Description of Change
11	Added PD-R to denote Positive Displacement-Reciprocating for Pump Type
20	Table 8.2-3 - Added line for Reciprocating and deleted Note 3 and references to Note 3 to reflect table re-format to include reciprocating pump types.
21	Table 8.2-6 – Included reciprocating positive displacement pump for test parameters P (Pressure) & Q (Flow rate)
47-49	IST-RR-1 <ul style="list-style-type: none"> • Included new column to denote pump type • Deleted Group B pumps from request for relief (CV-SPRAY-PMP, SI-PMP) • Corrected reference from ISTB-1300 to ISTB-2000 • Removed reference to “bi-ennial” frequency for Table ISTB-3510-1, “Required Instrument Accuracy.” • Corrected title to reference ISTB-5121-1 to Centrifugal Pump Test Acceptance Criteria • Included reference and discussion to ISTB 5321-2 for Reciprocating Positive Displacement Pumps • Provided additional information in Specific Relief Requested to include references to Paragraph ISTB-5123 and ISTB-5323 and deleted two occurrences stating: “unless calibrated flow measuring instruments are not available”. Re-worded first paragraph to improve clarity and eliminated reference to HBRSEP, Unit 2. • Revised last paragraph on page 48 to reflect the deletion of Group B pumps from the request and to re-structure wording to be more concise. • Deleted reference to ISTB-3300(e)(2) on page 49 • Re-worded paragraph b (editorial)
50	IST-RR-2 <ul style="list-style-type: none"> • Included new column to denote pump type • Eliminated term “over the calibrated range”, “digital” and “pump” and simply stated Table ISTB-3510-1 requirements in the Applicable Code Requirement section. • Re-wrote the Basis for Requesting Relief to be more specific for these applications and document expectations and limitations regarding the use of this equipment.
	IST-RR-3 <ul style="list-style-type: none"> • Deleted references to ISTC-5222 and the check valve condition monitoring program • Added “spring-loaded ball type” in lead in sentence to Basis for Requesting Relief and in the Proposed Alternative sections. • Listed approximate diameters of ball and discharge port • Removed language associated with Appendix J leakage testing to preclude the perception that a leak test is conducted. • Discussed ancillary indications and devices to aid in detecting a failed open valve
91-92	Attachment 10.5 <ul style="list-style-type: none"> • Deleted reference to IST-RR-1 for Group B pumps (CV-SPRAY, SI-PMP) • Clarified pump type to PD-R for CHG-PMP-A, CHG-PMP-B & CHG-PMP-C to reflect that these pumps are positive displacement-reciprocating pumps.
102	Deleted thermal relief valve CC-791A from Attachment 10.6 Valve Table and re-located to Attachment 10.7, page 199 based on EC 84732.
199	Included CC-791A on Attachment 10.7 due to being abandoned per EC 84732.

TABLE OF CONTENTS

SECTION	PAGE
1.0 PURPOSE.....	4
2.0 REFERENCES.....	4
3.0 RESPONSIBILITIES.....	6
4.0 PREREQUISITES.....	6
5.0 PRECAUTIONS AND LIMITATIONS.....	6
6.0 SPECIAL TOOLS AND EQUIPMENT.....	6
7.0 ACCEPTANCE CRITERIA.....	6
8.0 INSTRUCTIONS.....	7
8.1 IST Program Development – General.....	7
8.2 IST Program Development – Pumps.....	11
8.3 IST Program Development – Valves.....	23
9.0 RECORDS.....	39
10.0 ATTACHMENTS.....	44
10.1 ATTACHMENT 10.1, Systems and P&IDs.....	45
10.2 ATTACHMENT 10.2, Relief Requests.....	47
10.3 ATTACHMENT 10.3, Cold Shutdown Justifications.....	55
10.4 ATTACHMENT 10.4, Refueling Shutdown Justifications.....	81
10.5 ATTACHMENT 10.5, Pump Table.....	91
10.6 ATTACHMENT 10.6, Valve Table.....	93
10.7 ATTACHMENT 10.7, Excluded Valve Table.....	190

1.0 PURPOSE

- 1.1 This procedure details the Inservice Testing (IST) Program Plan for the fifth ten year interval. This procedure identifies the components subject to test or examination, responsibilities, methods, intervals, parameters to be measured and evaluated, criteria for evaluating the results, corrective action and record keeping. These requirements apply to:
- 1.1.1 Pumps and valves that are required to perform a specific function in shutting down a reactor to the safe shutdown condition, in maintaining the safe shutdown condition, or in mitigating the consequences of an accident.
 - 1.1.2 Pressure relief devices that protect systems that are required to perform a specific function in shutting down a reactor to the safe shutdown condition, in maintaining the safe shutdown condition, or in mitigating the consequences of an accident.
 - 1.1.3 Dynamic restraints (snubbers) used in systems that are required to perform a specific function in shutting down a reactor to the safe shutdown condition, in maintaining the safe shutdown condition, or in mitigating the consequences of an accident, or to ensure the integrity of the reactor coolant boundary.
- 1.2 This procedure provides compliance with UFSAR Section 3.9.6, and Technical Specification Section 5.5.8.

2.0 REFERENCES

- 2.1 Code of Federal Regulations, Title 10, Part 50, Section 55a, and Appendix J.
- 2.2 ASME OM Code – 2004 Edition through 2006 Addenda.
- 2.3 HBRSEP Unit 2 Technical Specifications, Section 5.5.8.
- 2.4 HBR 2 Updated FSAR, Section 3.9.6, In-Service Inspection and Inservice Testing of Pumps and Valves.
- 2.5 NUREG-1482, Guidelines for Inservice Testing at Nuclear Power Plants, revision 1.
- 2.6 NUREG/CR-6396, Examples, Clarification, and Guidance on Preparing Requests for Relief from Pump and Valve Inservice Testing Requirements.
- 2.7 Federal Register 36269, dated July 19, 2011.
- 2.8 TMM-005, 10CFR50, Appendix "J" Testing Program
- 2.9 TMM-008, Check Valve Program Technical Requirements
- 2.10 TMM-009, Inservice Test Program Administration
- 2.11 EST-111, Safety, Pressure Relief & Vacuum Breaker Valve Test Selection and Verification (Refueling Shutdown and as Needed After Maintenance)
- 2.12 EST-112, Pressure, Safety, and Relief Valve Bench Testing
- 2.13 Generic Issue Document 90-181, Reactor Containment Isolation
- 2.14 PLP-037, Conduct of Infrequently Performed Tests or Evolutions and Pre-Job Briefs
- 2.15 Calculation RNP-M/MECH 1621, Containment Isolation Valves 10CFR50 Appendix J Allowable Leakage Rates

- 2.16 CAP-NGGC-0200, Condition Identification and Screening Process
- 2.17 EGR-NGGC-008, Engineering Programs
- 2.18 NAS Assessment R-ES-99-01
- 2.19 NAS Assessment RES-ES-01-01
- 2.20 ESR 95-00796, AFW Self-Cooling
- 2.21 ESR 95-00189, Flow through SI Test Line during OST-151
- 2.22 RNP-M/MECH 1802, Safety Related Pump Minimum Performance Requirements
- 2.23 ESR 97-00383, Cool Water Injection to SWBP 'B' Discharge
- 2.24 ESR 98-00295, Function of EDG Skid Mounted Check Valves
- 2.25 ESR 98-00386, Locking Manual Containment Isolation Valves
- 2.26 ESR 98-00509, North Service Water Header Piping Replacement
- 2.27 ESR 99-00176, Removing North Service Water Header From Service
- 2.28 SOER 98-01, Safety System Status Control
- 2.29 NRC Information Notice 97-16, Preconditioning of Plant Structures, Systems, and Components
- 2.30 NRC Information Notice 97-090, Use of Non Conservative Acceptance Criteria in Safety Related Pump Surveillance Tests
- 2.31 TMM-015, Inservice Repair and Replacement Program
- 2.32 EC 52357, SW South Header Flow Instrument Installation
- 2.33 EC 52753, CS/SI Pump Test Line
- 2.34 EC 51299, System Vents For RHR Piping
- 2.35 NAS Assessment R-ISI/SBO-05-01
- 2.36 ADM-NGGC-0115 , Preconditioning of Structures, Systems and Components
- 2.37 Regulatory Guide 1.192, Operation and Maintenance Code Case Acceptability, ASME OM Code
- 2.38 Regulatory Guide 1.193, ASME Code Cases Not Approved for Use
- 2.39 NCR 455255, R-ISI-11-01-F1, Established Fleet Processes Not used to Document Conditions for Evaluation
- 2.40 EGR-NGGC-0028, Engineering Evaluation
- 2.41 OPS-NGGC-1305, Operability Determinations
- 2.42 EC 80584, Seismic Qualification of the SFP / RWST Purification System

3.0 RESPONSIBILITIES

- 3.1 The Supervisor - Engineering Programs is responsible for compliance with this procedure.
- 3.2 The IST Engineer has the responsibility to monitor, analyze, trend and archive IST data obtained during performance of surveillance procedures to comply with this procedure. Additionally, the IST Engineer will report adverse trends to the Responsible or System Engineers, as applicable.
- 3.3 The IST Engineer ensures that implementing test procedures are placed on Administrative Hold, per RDC-NGGC-0002, *Document Control Program* when acceptance criteria have been revised and the existing procedure criteria is no longer valid.
- 3.4 The System Engineer is responsible for performing a component and system level review when necessary when performance parameters are outside the acceptable range (Alert, Required Action).
- 3.5 The IST and affected System or Responsible Engineer are accountable for working together to address any concerns over abnormal or unexplained findings.
- 3.6 The affected System or Responsible Engineer is responsible for providing a peer check of any acceptance limit derivation.

4.0 PREREQUISITES

N/A

5.0 PRECAUTIONS AND LIMITATIONS

N/A

6.0 SPECIAL TOOLS AND EQUIPMENT

N/A

7.0 ACCEPTANCE CRITERIA

N/A

8.0 INSTRUCTIONS

8.1 IST Program Development – General

8.1.1 Regulatory Requirements

The Code of Federal Regulations, Title 10, Part 50.55a (10CFR50.55a), paragraph (f)(5)(i) requires each licensee of pressurized water-cooled nuclear reactors to revise the IST Program to meet the requirements of 10CFR50.55a(f)(4)(ii). As a result, the IST Program must be revised at 120-month intervals to comply with the requirements of the latest edition and addenda of the Code incorporated by reference in 10CFR50.55a(b) 12 months prior to the start of the 120-month interval.

8.1.2 Interval Information

The first program interval commenced on November 7, 1977 and ended on March 7, 1981.

The second 120-month interval commenced on March 7, 1981 and ended on February 19, 1992.

The third 120-month interval commenced on February 19, 1992 and ended on February 18, 2002.

The fourth 120-month interval is applicable from February 19, 2002 through and including July 20, 2012.

The fifth 120-month interval is applicable from July 21, 2012 through and including February 18, 2022.

8.1.3 Applicable Code

In accordance with 10CFR50.55a, the code of record for the IST Program is ASME OM Code - 2004 Edition through 2006 Addenda and subject to limitations and modifications in 10CFR50.55a(b)(3).

8.1.4 Selection of Components

1. Pumps and valves are selected for inclusion in the IST Program based on a review of all plant systems. This review includes UFSAR, Technical Specifications, Plant Operating Manual procedures, design documents and Piping & Instrument Diagrams. In accordance with 10CFR50.55a(f), the components subject to OM Code requirements are limited to ASME Class 1, 2, and 3 pumps and valves.
2. Components and tests that are optionally included in this IST Program Plan are identified as follows:
 - Components optionally classified as Code Class 3 (e.g., Diesel Fuel Oil system) are identified as Augmented in the Remarks column of the Pump Table and Valve Table.
 - Components not within the Code Class 1, 2, or 3 boundaries are identified as Augmented in the Remarks column of the Pump Table and Valve Table.

- Components not in the scope of the IST Program Plan are identified as Augmented in the Remarks column of the Pump Table and Valve Table.
- Specific tests that are not necessary to meet OM Code requirements are identified with "Aug" next to the test in the Test Type column of the Valve Table.
- Relief Requests and Test Deferral Justifications are not provided for components and tests identified as Augmented.

8.1.5 Code Classification

Code classification of pumps and valves at RNP is described in UFSAR Section 3.9.6 and is shown on the Piping and Instrumentation Diagrams provided in following section.

8.1.6 Systems and Flow Diagrams

A list of systems included in the IST Program along with the associated Piping and Instrumentation Diagrams (P&ID's) that identify the Code boundaries is provided in ATTACHMENT 10.1.

8.1.7 Relief Requests

1. Specific requests for relief in accordance with 10CFR50.55a(f)(5)(iii), and 10CFR50.55a(f)(5)(iv) are provided in ATTACHMENT 10.4. Where conformance with the requirements of the Code have been determined to be impracticable, alternate testing is proposed that would provide an acceptable level of quality and safety. Where conformance with the requirements of the Code would result in hardship or unusual difficulty without a compensating increase in the level of quality and safety, alternate testing is proposed that would provide useful information to assess the operational readiness of the component tested.
2. The relief requests define the component(s) and test(s) involved the basis for relief and the proposed alternative testing.
3. Relief requests approved by the NRC shall not be altered without prior notification and approval by the NRC. The modification need not be in the form of a relief request; however, correspondence and acceptance by the NRC is required prior to implementing the revised request.
4. Relief requests are numbered in an "**IST-RR-N**" format where:
 - IST** = Designates the relief request is applicable to the IST Program Plan
 - RR** = Relief request
 - N** = Unique sequential number

8.1.8 Use of Later Editions and Addenda (NRC Regulatory Issue Summary 2004-12)

Later editions or addenda of the OM Code, incorporated by reference in paragraph (b) of 10CFR50.55a may be implemented during the course of an inspection interval subject to the limitations and modifications listed in paragraph (b) of 10CFR50.55a and provided all related requirements of the respective Code edition or addenda have been met. The voluntary update to a later Code edition or addenda of the Code referenced in paragraph (b) is not considered a relief request. Therefore, the requirements are not as stringent. A letter must be submitted to the NRC and should include a discussion of the related requirements. NRC approval is required prior to implementation. RIS 2004-12 provides clarification related to the process by which NRC approval can be obtained.

8.1.9 ASME Code Case Applicability

1. The NRC staff has developed RG 1.192 "Operation and Maintenance Code Case Acceptability, ASME OM Code" and RG 1.193 "ASME Code Cases Not Approved for Use."
2. Per revision 1 of NUREG 1482, the licensee may implement the Code cases listed in RG 1.192 without obtaining further NRC review, if the Code cases are used in their entirety, with any supplemental conditions specified in the regulatory guide (RG). RG 1.192 also lists Code cases that are conditionally acceptable.
3. Code cases that may be utilized by the inservice test program are listed in the reference section. If utilized, a brief description will be provided below.
 - a. There are currently no Code cases being implemented

8.1.10 Test Deferral Justifications

1. In accordance with paragraphs 8.3.15 and 8.3.31, certain valves are full stroke exercised during cold shutdown conditions when they cannot be exercised during normal operation. When a valve cannot be exercised during normal operation or cold shutdown conditions, then it is full stroke exercised during refueling outages. The technical justification for exercising a valve during cold shutdown or refueling outages rather than normal operation is provided in a Cold Shutdown Test Justification or Refueling Outage Test Justification.

2. Valves tested during cold shutdowns or refueling outages shall be scheduled in accordance with paragraphs 8.3.15 and 8.3.31.

3. Cold Shutdown Test Justifications and Refueling Outage Test Justifications are numbered in a "XXX-VCS-N" or "XXX-VRS-N" format where:

XXX = System Acronym

VCS = Cold Shutdown Test Justifications

VRS = Refuel Outage Justifications

N = Unique sequential number (e.g., SI-VCS-2 would be the second Cold Shutdown Test Justification for valves in the safety injection system)

4. Cold Shutdown Test Justifications are provided in ATTACHMENT 10.3 and Refueling Outage Test Justifications are provided in ATTACHMENT 10.4.

8.2 IST Program Development – Pumps

8.2.1 Pump Scope

1. Pumps included in the IST Program are those Safety Class 2 and 3 centrifugal and positive displacement pumps provided with an emergency power source that are required to:
 - Shut down the reactor to the safe shutdown condition, or
 - Maintain the reactor in the safe shutdown condition, or
 - Mitigate the consequences of an accident.
2. Excluded from the above are:
 - Drivers, except where the pump and driver form an integral unit and the pump bearings are in the driver;
 - Pumps supplied with emergency power solely for operating convenience.
 - Skid-mounted pumps and component subassemblies that are tested as part of the major component.

8.2.2 Pump Table Format

A complete list of pumps in the scope of IST Program and their associated required tests are listed (in a tabular format) in ATTACHMENT 10.5. The Pump Table is sorted alphabetically. A description of each column in the Pump Table is shown below with applicable abbreviations.

Pump	Unique alphabetical designator assigned to each pump.
Description	Descriptive name of the pump
P&ID (SHT)	P&ID in which the pump is located. A complete list of P&ID's is provided in ATTACHMENT 10.1.
Coord	Drawing coordinate of pump location on the P&ID.
Pump Group	Testing Group
A	Pumps that are operated continuously or routinely during normal operation, cold shutdown or refueling operations.
B	Pumps in standby systems that are not operated routinely except for testing.
Pump Type	Pump design
C-H	Centrifugal pump where orientation of the pump and motor shaft is in the horizontal plane
C-V	Centrifugal pump where orientation of the pump and motor shaft is in the vertical plane.
PD	Positive displacement pump.
PD-R	Positive displacement pump - Reciprocating

VLS	Centrifugal vertically suspended pump where the pump driver and pumping element are connected by a line shaft within an enclosing column which contains the pump bearings
Speed	Identifies whether the pump speed is fixed or variable. All pumps in the IST Program Plan are tested at speeds greater than 600 rpm.
Fixed	Speed is constant and is a function of the motor design.
Vari	Speed is variable.
Test Type	Parameters measured and evaluated during the pump test.
Comp.	Test types prefixed with designator comply with the requirements for Comprehensive pump tests per OM Code.
Grp A	Test types prefixed with designator comply with the requirements for Group A pump tests per OM Code.
Grp B	Test types prefixed with designator comply with the requirements for Group B pump tests per OM Code.
dP	Pump differential pressure
Q	Pump flow
N	Pump speed (variable speed pumps only).
P	Discharge pressure
V	Pump or motor bearing vibration velocity (broad band unfiltered peak in inches per second or peak to peak in mils).
Test Freq	Frequency of pump testing per OM Code
Q	Quarterly (once per 92 days)
Bi	Biennial (once per 731 days)
Relief Request	Reference to applicable relief request. Relief requests are located in ATTACHMENT 10.2.
Remarks	Applicable notes or other unique comments that provide clarification.

8.2.3 Pump Groups

Pumps are divided into groups based on their frequency of operation. These groups are then used to determine the test frequency, test parameters measured, and acceptance criteria.

- Group A Pumps – are operated continuously or routinely during normal operation, cold shutdown, or refueling.
- Group B Pumps – pumps in standby systems that are not operated routinely except for testing.

8.2.4 Testing Requirements

1. When a Group A Test is required, a Comprehensive Test may be substituted.
2. When a Group B Test is required, a Group A Test or Comprehensive Test may be substituted.
3. A Preservice Test may be substituted for any Inservice Test.

8.2.5 Preservice Tests

1. Tests are conducted during the preservice test period or before implementing inservice testing. The tests shall be conducted under conditions as near as practicable to those expected during subsequent inservice testing. Only one preservice test is required for each pump. The parameters to be measured are those identified for Group A Tests, Group B Tests, and Comprehensive Tests in Table 8.2-1.
2. For centrifugal and vertical line shaft pumps where resistance can be varied, flow rate and differential pressure shall be measured at a minimum of 5 points. A pump curve shall be established based on the measured points and at least one point shall be identified as the reference point. If practical, these points shall be from pump minimum flow to at least pump design flow. A pump curve need not be established for pumps in systems where resistance cannot be varied.
3. For positive displacement pumps, reference values shall be taken at or near pump design pressure for the parameters specified in Table 8.2-1.
4. Vibration measurements are only required to be taken at the reference point(s).

Table 8.2-1
Inservice Test Parameters

Quantity	Preservice Test	Group A Test	Group B Test	Comprehensive Test	Remarks
Speed, N	X	X	X	X	If variable speed
Differential Pressure, ΔP	X	X	X [Note (1)]	X	Centrifugal pumps, Vertical Line Shaft
Discharge Pressure, P	X	X		X	Positive Displacement, Reciprocating Positive Displacement
Flow Rate, Q	X	X	X [Note (1)]	X	
Vibration Displacement, V_d Velocity, V_v	X	X		X	Measure either V_d or V_v Peak-to-peak Peak

NOTE:

- (1) For positive displacement and reciprocating positive displacement pumps, flow rate shall be measure or determined; for all other pumps, differential pressure or flow rate shall be measured or determined.

8.2.6 Inservice Testing

Inservice testing shall commence when the pumps are required to be operable.

8.2.7 Reference Values

Reference values shall be obtained as follows:

1. Initial reference values shall be determined from the results of Preservice Tests or from the results of the first Inservice Test.
2. New or additional reference values shall be established in accordance with paragraphs 8.2.8, 8.2.9, and 8.2.10.
3. Reference values shall be established only when the pump is known to be operating acceptably.
4. Reference values shall be established at a point(s) of operation (reference point) readily duplicated during subsequent tests.
5. Reference values should be established in a region(s) of relatively stable pump flow.
 - a. Reference values should be established within $\pm 20\%$ of pump design flow rate for the comprehensive test.
 - b. Reference values should be established within $\pm 20\%$ of design flow for Group A and Group B pumps, if practical. If not practical, the reference flow rate shall be established at the highest practical flow rate.
6. All subsequent test results shall be compared to these initial reference values or to new reference values established in accordance with paragraphs 8.2.8, 8.2.9, and 8.2.10.
7. If the particular parameter being measured or determined can be significantly influenced by other related conditions, then these conditions shall be analyzed and documented in the record of test.

8.2.8 Effect of Pump Maintenance, Replacement, or Repair

1. When a reference value or set of reference values may have been affected by repair, replacement, or routine servicing of a pump, a new reference value or set of reference values shall be determined in accordance with paragraph 8.2.7 or the previous value reconfirmed by a Comprehensive or Group A test run before declaring the pump operable.
2. The Owner shall determine whether the requirements of Preservice Testing (paragraph 8.2.5), to reestablish reference values, apply.
3. Deviations between the previous values and new values shall be evaluated, and verification that the new values represent acceptable pump operation shall be placed in the record of test.

8.2.9 Establishment of Additional Set of Reference Values

If it is considered necessary or desirable, for some reason other than paragraph 8.2.8, to establish an additional set of reference values, a Group A or Comprehensive Test shall be performed at the conditions of an existing set of reference values and the results analyzed. If operation is acceptable in accordance with paragraph 8.2.29 an additional set of reference values may be established as follows.

- For centrifugal pumps, the additional set of reference values shall be determined from the pump curve established during Preservice Testing (paragraph 8.2.5). Vibration acceptance criteria shall be established by a Group A or Comprehensive test at the new reference point. If vibration data was taken at all points used in determining the pump curve, an interpolation of the new vibration reference value is acceptable.
- For positive displacement pumps, the additional set of reference values shall be established in accordance with Preservice Testing (paragraph 8.2.5).

A test shall be run to verify the new reference values before their implementation. Whenever an additional set of reference values is established, the reason for so doing shall be justified and documented in the record of test.

8.2.10 New Reference Values

In cases where the pump's test parameters are within either the alert or required action ranges, and the pump's continued use at the changed values is supported by an analysis, a new set of reference values may be established. This analysis shall include verification of the pump's operational readiness. The analysis shall include a pump level and system level evaluation of operational readiness, the cause of the change in pump performance, and an evaluation of all trends indicated by available data. The results of this analysis shall be documented in the record of test. The system level evaluation shall be performed by the applicable system engineer. Caution should be exercised if an evaluation is used to recommend pump operability when performance is in the alert or required action range. OPS-NGGC-1305, *Operability Determinations* should be consulted to determine if the process for a degraded or non-conforming condition should be followed.

8.2.11 Data Collection

8.2.12 General

1. Accuracy – Instrument accuracy shall be within the limits of Table 8.2-2. If a parameter is determined by analytical methods instead of by measurement, then the determination shall meet the requirements of the table. For individual analog instruments, the required accuracy is percent of full scale. For digital instruments, the required accuracy is over the calibrated range. For a combination of instruments, the required accuracy is loop accuracy.
2. Range
 - The full-scale range of each analog instrument shall not be greater than three times the reference value.
 - Digital instruments shall be selected such that the reference value does not exceed 90% of the calibrated range of the instrument.
 - Vibration instruments are excluded from the range requirements identified above.

Table 8.2-2
Required Instrument Accuracy

Quantity	Group A and Group B Tests	Comprehensive and Preservice Tests
Pressure	±2	±½
Flow Rate	±2	±2
Speed	±2	±2
Vibration	±5	±5
Differential Pressure	±2	±½

3. Instrument Location – The sensor location shall be established by the Owner, documented in plant records, and shall be appropriate for the parameter being measured. The same location shall be used for subsequent tests. Instruments that are position sensitive shall be either permanently mounted, or provision shall be made to duplicate their position.
4. Calibration – Instruments and instrument loops shall be calibrated in accordance with the H. B. Robinson Quality Assurance Program.
5. Fluctuations – Symmetrical dampening devices or averaging techniques may be used to reduce instrument fluctuations. Hydraulic instrument may be damped by using gage snubbers or by throttling small valves in instrument lines.
6. Frequency Response Range – The frequency response range of the vibration measuring transducers and their readout system shall be from one-third minimum pump shaft rotational speed to at least 1000 Hz.

8.2.13 Pressure

1. Gage Lines – If the presence or absence of liquid in a gage line could produce a difference of more than 0.25% in the indicated value of the measured pressure, means shall be provided to ensure or determine the presence or absence of liquid as required for the static correction used.
2. Differential Pressure – When determining differential pressure across a pump, a differential pressure gage or a differential pressure transmitter that provides direct measurement of pressure difference, or the difference between the pressure at a point in the inlet and the pressure in the outlet shall be used.

8.2.14 Rotational Speed

Rotational speed measurements of variable speed pumps shall be taken by a method that meets the requirements of paragraph 8.2.12.

8.2.15 Vibration

1. On centrifugal pumps, except vertical line shaft pumps, measurements shall be taken in a plane approximately perpendicular to the rotating shaft in two approximately orthogonal directions on each accessible pump thrust bearing housing. Measurements shall also be taken in the axial direction on each accessible pump thrust bearing housing.
2. On vertical line shaft pumps, measurements shall be taken on the upper motor-bearing housing in three approximately orthogonal directions, one of which is the axial direction.
3. On reciprocating pumps, the location shall be on the bearing housing of the crankshaft, approximately perpendicular to both the crankshaft and the line of plunger travel.
4. If a portable vibration indicator is used, the measurement points shall be clearly identified on the pump to permit subsequent duplication in both location and plane.

8.2.16 Flow Rate

When measuring flow rate, a rate or quantity meter shall be installed in the pump test circuit. If a meter does not indicate flow rate directly, the record shall include the method used to reduce data.

8.2.17 Testing Methods

Testing methods are clearly defined within the implementing procedures.

8.2.18 Frequency of tests

Group A and Group B Tests shall be performed quarterly. Comprehensive Tests shall be performed biennially.

8.2.19 Test Procedure

Implementing Group A, Group B and comprehensive pump tests are listed in ATTACHMENT 10.5.

8.2.20 Group A Test

Group A Tests shall be conducted with the pump operating at a specified reference point. The test parameters shown in Table 8.2-1 shall be determined and recorded as required by this paragraph. The test shall be conducted as follows.

1. The pump shall be operated at nominal motor speed for constant speed drives or at a speed adjusted to the reference point ($\pm 1\%$) for variable speed drives.
2. For centrifugal and vertical line shaft pumps, the resistance of the system shall be varied until the flow rate equals the reference point. The differential pressure shall then be determined and compared to its reference value. Alternatively, the flow rate may be varied until the differential pressure equals the reference point and the flow rate determined and compared to its reference value.
3. For positive displacement pumps, the resistance shall be varied until the discharge pressure equals the reference point. The flow rate shall then be determined and compared to its reference value.
4. Where resistance cannot be varied, flow rate and pressure shall be determined and compared to their respective reference values.
5. Vibration (displacement or velocity) shall be determined and compared with the reference value. Vibration measurements shall be broadband (unfiltered). If velocity measurements are used, they shall be peak. If displacement amplitudes are used, they shall be peak to peak.
6. All deviations from the reference values shall be compared with the ranges in Table 8.2-3 and Table 8.2-4 and corrective action taken as specified in paragraph 8.2.29.
7. The vibration measurements shall be compared to both the relative and absolute criteria shown in the alert and required action ranges in Table 8.2-3.

8.2.21 Group B Test

Group B tests shall be conducted with the pump operating at a specified reference point. The test parameter value identified in Table 8.2-1 shall be determined and recorded as required by this paragraph. The test shall be conducted as follows.

1. The pump shall be operated at nominal motor speed for constant speed drives or at a speed adjusted to the reference point ($\pm 1\%$) for variable speed drives.
2. For centrifugal and vertical line shaft pumps, the pressure or flow rate shall be determined and compared to its reference value.
3. For positive displacement pumps, the flow rate shall be determined and compared to its reference value.

4. System resistance may be varied as necessary to achieve the reference point.
5. All deviations from the reference values shall be compared with the ranges of Table 8.2-5 and correction action taken as specified in paragraph 8.2.29.

8.2.22 Comprehensive Tests

Comprehensive Tests shall be conducted with the pump operating at a specified reference point. The test parameters shown in Table 8.2-1 shall be determined and recorded as required by this paragraph. The test shall be conducted as follows.

1. The pump shall be operated at nominal motor speed for constant speed drives or at a speed adjusted to the reference point ($\pm 1\%$) for variable speed drives.
2. For centrifugal and vertical line shaft pumps, the resistance of the system shall be varied until the flow rate equals the reference point. The differential pressure shall then be determined and compared to its reference value. Alternatively, the flow rate may be varied until the differential pressure equals the reference point and the flow rate determined and compared to its reference value.
3. For positive displacement pumps, the resistance shall be varied until the discharge pressure equals the reference point. The flow rate shall then be determined and compared to its reference value.
4. Where resistance cannot be varied, flow rate and pressure shall be determined and compared to their respective reference values.
5. Vibration (displacement or velocity) shall be determined and compared with the reference value. Vibration measurements shall be broadband (unfiltered). If velocity measurements are used, they shall be peak. If displacement amplitudes are used, they shall be peak to peak.
6. All deviations from the reference values shall be compared with the ranges in Table 8.2-3 and Table 8.2-6 and corrective action taken as specified in paragraph 8.2.29.
7. The vibration measurements shall be compared to both the relative and absolute criteria shown in the alert and required action ranges in Table 8.2-3.

Table 8.2-3
Group A and Comprehensive Tests Vibration Acceptance Criteria

Pump Type	Pump Speed	Test Parameter	Acceptable Range	Alert Range	Required Action Range
Centrifugal, Vertical Line Shaft, Positive Displacement [Note (2)]	<600 rpm	V_d or V_v	$\leq 2.5V_r$	$>2.5V_r$ to $6V_r$ or >10.5 to 22 mils	$>6V_r$ or >22 mils
Centrifugal, Vertical Line Shaft, Positive Displacement [Note (2)]	≥ 600 rpm	V_d or V_v	$\leq 2.5V_r$	$>2.5V_r$ to $6V_r$ or >0.325 to 0.7 in./sec	$>6V_r$ or >0.7 in./sec
Reciprocating Positive Displacement		V_d or V_v	$\leq 2.5V_r$	$>2.5V_r$ to $6V_r$	$>6V_r$

GENERAL NOTE: The subscript r denotes reference value.

NOTES:

- (1) Vibration parameter is per Table 8.2-1. V_r is vibration reference value in the selected unit.
- (2) Refer to OM Code Figure ISTB 5223-1 to establish displacement limits for pumps with speeds ≥ 600 rpm or velocity limits for pumps with speeds <600 rpm.

Table 8.2-4
Group A Test Hydraulic Acceptance Criteria

Test Parameter	Acceptable Range	Alert Range	Required Action Range	
			Low	High
P (Positive Displacement, Reciprocating Positive Displacement)	0.93 to $1.10P_r$	0.90 to $<0.93P_r$	$<0.90P_r$	$>1.10P_r$
ΔP (Vertical Line Shaft)	0.95 to $1.10\Delta P_r$	0.93 to $<0.95\Delta P_r$	$<0.93\Delta P_r$	$>1.10\Delta P_r$
Q (Positive Displacement, Reciprocating Positive Displacement and Vertical Line Shaft)	0.95 to $1.10Q_r$	0.93 to $<0.95Q_r$	$<0.93Q_r$	$>1.10Q_r$
ΔP (Centrifugal)	0.90 to $1.10\Delta P_r$	none	$<0.90\Delta P_r$	$>1.10\Delta P_r$
Q (Centrifugal)	0.90 to $1.10Q_r$	none	$<0.90Q_r$	$>1.10Q_r$

GENERAL NOTE: The subscript r denotes reference value.

Table 8.2-5
Group B Test Hydraulic Acceptance Criteria

Test Parameter	Acceptable Range	Required Action Range	
		Low	High
ΔP (Centrifugal, Vertical Line Shaft), or	0.90 to $1.10\Delta P_r$	$<0.90\Delta P_r$	$>1.10\Delta P_r$
Q (All types), [See Note (1)]	0.90 to $1.10Q_r$	$<0.90Q_r$	$>1.10Q_r$

GENERAL NOTE: The subscript r denotes reference value.

NOTE: (1) Measure Q for positive displacement pumps.

Table 8.2-6
Comprehensive Test Hydraulic Acceptance Criteria

Test Parameter	Acceptable Range	Alert Range	Required Action Range	
			Low	High
P (Positive displacement, Reciprocating Positive Displacement)	$0.93 \text{ to } 1.03P_r$	$0.90 \text{ to } <0.93P_r$	$<0.90P_r$	$>1.03P_r$
ΔP (Vertical Line Shaft)	$0.95 \text{ to } 1.03\Delta P_r$	$0.93 \text{ to } <0.95\Delta P_r$	$<0.93\Delta P_r$	$>1.03\Delta P_r$
Q (Positive Displacement, Reciprocating Positive Displacement and Vertical Line Shaft)	$0.95 \text{ to } 1.03Q_r$	$0.93 \text{ to } <0.95Q_r$	$<0.93Q_r$	$>1.03Q_r$
ΔP (Centrifugal)	$0.93 \text{ to } 1.03\Delta P_r$	$0.90 \text{ to } <0.93\Delta P_r$	$<0.90\Delta P_r$	$>1.03\Delta P_r$
Q (Centrifugal)	$0.94 \text{ to } 1.03Q_r$	$0.90 \text{ to } <0.94Q_r$	$<0.90Q_r$	$>1.03Q_r$

GENERAL NOTE: The subscript r denotes reference value.

8.2.23 Pumps in Regular Use

Group A pumps that are operated more frequently than every 3 months need not be run or stopped for a test provided the plant records show the pump was operated at least once every three months at the reference conditions and quantities specified were determined, recorded, and analyzed.

8.2.24 Pumps in Systems Out of Service

For a pump in system declared inoperable or when it is not required to be operable, the test schedule need not be followed. Within 3 months before the system is placed in an operable status, the pump shall be tested and then the normal test schedule followed. Pumps that can only be tested during plant operation shall be tested within 1 week following plant startup.

8.2.25 Pumps Lacking Required Inventory

Group B pumps lacking required fluid inventory (pumps in dry sumps) shall receive a comprehensive test at least once every two years except as provided in paragraph 8.2.24. The required fluid inventory shall be provided during the test. A Group B Test is not required.

8.2.26 Duration of Tests

1. Group A Test – After pump conditions are as stable as the system permits, each pump shall be run for at least 2 minutes. At the end of this time, at least one measurement or determination of the quantities required by Table 8.2-1 shall be made and recorded.
2. Group B Test – After pump conditions are stable, at least one measurement or determination of the quantity required by Table 8.2-1 shall be made and recorded.
3. Comprehensive Test – After pump conditions are as stable as the system permits, each pump shall be run for at least 2 minutes. At the end of this time, at least one measurement or determination of the quantities required by Table 8.2-1 shall be made and recorded.

8.2.27 Analysis and Evaluation

Requirements for analysis and evaluation are defined within implementing procedures.

8.2.28 Trending

Test parameters shown in Table 8.2-1, except for fixed values shall be trended.

8.2.29 Acceptance Criteria

1. Alert Range – If the measured test parameters values fall within the alert range of Table 8.2-3, Table 8.2-4, or Table 8.2-6, as applicable, the frequency of testing specified in paragraph 8.2.18 shall be doubled until the cause of the deviation is determined and the condition is corrected.
2. Action Range – If the measured test parameter values fall within the required action range of Table 8.2-3, Table 8.2-4, or Table 8.2-6, as applicable, the pump shall be declared inoperable until the cause of the deviation is determined and the condition is corrected, or an analysis of the pump is performed and a new reference values are established in accordance with paragraph 8.2.10.
3. Systematic Error – When a test shows measured parameter values that fall outside of the acceptance range of Table 8.2-3, Table 8.2-4, Table 8.2-5, or Table 8.2-6, as applicable, and have resulted from an identified systematic error such as improper system lineup or inaccurate system instrumentation, the test shall be rerun after correcting the error.

8.3 IST Program Development - Valves

8.3.1 Valve Scope

1. Valves included in the IST Program Plan are those active or passive Safety Class 1, 2, and 3 valves that are required to perform a specific function in:
 - Shutting down the reactor to the safe shutdown condition, or
 - Maintaining the reactor in the safe shutdown condition, or
 - Mitigating the consequences of an accident.
2. Pressure relief devices included in the IST Program Plan are those Safety Class 1, 2, and 3 pressure relief devices for protecting systems or portion of systems that perform a specific function in:
 - Shutting down the reactor to the cold shutdown condition, or
 - Maintaining the reactor in the cold shutdown condition, or
 - Mitigating the consequences of an accident.
3. The following are excluded from above, provided that they are not required to perform a specific function as specified above:
 - Valves used only for operating convenience such as vent, drain, instrument, and test valves.
 - Valves used only for system control, such as pressure regulating valves.
 - Valves used only for system or component maintenance.
 - External control and protection systems responsible for sensing plant conditions and providing signals for valve operation.
 - Skid-mounted valves and component subassemblies that are tested as part of the major component.

Valves (except some vent and drain valves) that are excluded from the IST Program are listed in ATTACHMENT 10.7.

8.3.2 Valve Table Format

A complete list of valves in the scope of the IST Program and their associated required tests are listed (in a tabular format) in ATTACHMENT 10.6. The Valve Table is sorted alpha-numerically by valve number. A description of each column in the Valve Table is shown below with applicable abbreviations.

Valve Number	Unique alpha-numeric designator assigned to each valve. The valve number used in the Valve Table is taken from the P&ID's listed in ATTACHMENT 10.1.
P&ID (SHT)	P&ID in which the valve is located. A complete list of P&ID's is provided in ATTACHMENT 10.1.
Coord	Drawing coordinate of valve location on the P&ID.
Cat	Category as defined in paragraph 8.3.4.
A	Valves for which seat leakage is limited to a specific amount in the closed position for fulfillment of their required function(s).
A/C	Valves which are both self actuating and for which seat leakage is limited to a specific amount in the closed position for fulfillment of their required function(s).
B	Valves for which seat leakage in the closed position is inconsequential for fulfillment of the required function(s).
C	Valves which are self-actuating in response to some system characteristic, such as pressure (relief valves) or flow direction (check valves) for fulfillment of the required function(s).
D	Valves which are actuated by an energy source capable of only one operation such as rupture disks or explosively actuated valves. (Note: There are no Category D components at RNP.)
Act Pass	Identifies whether the valve performs an active or passive safety function as defined in paragraph 8.3.4.
Act	Active valve
Pass	Passive valve
Size	Valve size, in inches.
Valve Type	Valve design body style.
BL	Ball valve
BF	Butterfly valve
CK	Check valve
DA	Diaphragm valve
GA	Gate valve
GL	Globe valve
ND	Needle valve
SCK	Stop check valve

RV	Relief valve
TW	Three-way valve
VB	Vacuum breaker
PORV	Power Operated Relief Valve that is remotely actuated and not capacity certified under ASME Section III overpressure protection requirements
Act Type	Actuator type used to change valve obturator position.
AO	Air operator
HYD	Hydraulic operator
PNE	Pneumatic operator
M	Manual operator
MO	Motor operator
SA	Self actuated
SO	Solenoid operator
Norm Pos	Identifies the valve position during normal plant operation as defined by plant operating procedures.
C	Closed
LC	Locked Closed
LO	Locked Open
O	Open
O/C	Open and Closed
Safe Pos	Identifies the valve position required for the valve to perform its function.
C	Closed
O	Open
O/C	Open and Closed
Fail Pos	Identifies the position of the valve on loss of actuator power.
AI	As is
C	Closed
O	Open
N/A	Not applicable. Valve does not have a fail position
App J Type C	Identifies if the valve is included in the 10CFR50 Appendix J, Type C testing program.
N	No
Y	Yes
Pos Ind	Identifies if the valve is equipped with remote position indication.

N	No
Y	Yes
Test Type	Identifies the test requirements which apply to the valve.
DA	Valve will be disassembled and visually inspected in accordance with paragraph 8.3.34.3 as described in the applicable Refueling Outage Test Justification.
CV	Closure verification of a check valve to satisfy the bi-directional test requirement of paragraph 8.3.34.1.
FC	Fail stroke closed exercise valve with a fail-safe actuator to the closed position in accordance with paragraph 8.3.18.2
FF	Full stroke open exercise of Category C valves in accordance with paragraph 8.3.31.
FO	Fail stroke open exercise valve with a fail-safe actuator to the open position in accordance with paragraph 8.3.18.2.
FS	Full stroke exercise Category A or B valves to the open and closed position in accordance with paragraph 8.3.15.
FV	Functional verification of component operation (this is an Augmented test which does not satisfy OM Code requirements)
LJ	Leak test per 10CFR50 Appendix J, Type C, in accordance with paragraph 8.3.26 (containment isolation function only)
LK	Leak test in accordance with paragraph 8.3.27 (leakage rate for other than containment isolation valves)
OV	Open verification of a check valve to satisfy the bi-directional test requirement in accordance with paragraph 8.3.34.1.
PI	Valve with remote position indication verified in accordance with paragraph 8.3.12.
RF	Full stroke close exercise of Category C valves in accordance with paragraph 8.3.31.
RL	Relief valve testing in accordance with EST-112.
TM	Stroke time valve open (O) or closed (C) in accordance with paragraph 8.3.17.
Test Freq	Identifies the frequency required for valve testing as determined by OM Code:
App. I	Test frequency in accordance with EST-111 and Appendix I of the OM Code. For augmented components, the frequency may be set in accordance with the PM program.
App. II	Test frequency in accordance with the Appendix II condition monitoring program and as described in paragraph 8.3.35 and TMM-008.

- App. J** Test frequency in accordance with the 10CFR50 Appendix J program for Type C testing.
- Bi** Biennial, Once per 731 days (2 years).
- CS** Cold Shutdown, Testing performed during the cold shutdown condition (if not performed during the previous 92 days). If required, testing may be performed during the transition period between normal operation and cold shutdown
- Q** Quarterly, Once per 92 days
- R** Refueling Outage, Testing performed during the refueling outage condition. If required, testing may be performed during the transition period between normal operation and refueling

Test Deferral This field identifies, by unique number, applicable relief request (RR), cold shutdown test justification (VCS) and refueling outage test justification (VRS) for the individual component or test. These documents are located in ATTACHMENT 10.2, 10.3, and 10.4 respectively.

Remarks Applicable notes or other unique comments that provide clarification.

8.3.3 Excluded Valve Table

Valves (except vent and drain valves) that are excluded from the IST Program are listed in ATTACHMENT 10.7.

Table 8.3-1
Inservice Test Requirements

Category	Valve Function	Leakage Test Procedure	Exercise Test Procedure	Special Test Procedure [Note (1)]	Position Indication Verification
A	Active	See para. 8.3.24	See para. 8.3.13	None	See para. 8.3.12
A	Passive	See para. 8.3.24	None	None	See para. 8.3.12
B	Active	None	See para. 8.3.13	None	See para. 8.3.12
B	Passive	None	None	None	See para. 8.3.12
C (Safety and Relief) [Note (3)]	Active	None [Note (2), (3)]	See para. 8.3.27	None	See para. 8.3.12
C (Check) [Note (4)]	Active	None [Note (3)]	See para. 8.3.298	None	See para. 8.3.12
D	Active	None [Note (3)]	None	See paragraphs 8.3.39, 8.3.40	None

NOTE:

- (1) Note additional requirement for fail-safe valves, paragraph 8.3.19.
- (2) Leak test as required for Mandatory Appendix I
- (3) When more than one distinguishing category characteristic is applicable, all requirements of each of the individual categories are applicable, although duplication or repetition of common testing requirements is not necessary.
- (4) If a check valve used for a pressure relief device is capacity certified, then it shall be classified as a pressure or vacuum relief device. If a check valve used to limit pressure is not capacity certified, then it shall be classified as a check valve.

8.3.4 Valve Categories

Valves shall be placed in one or more of the following categories. When more than one distinguishing category characteristic is applicable, all requirements of each of the individual categories are applicable, although duplication or repetition of common testing requirements is not necessary.

- Category A – Valves for which seat leakage is limited to a specific maximum amount in the closed position for fulfillment of their required function.
- Category B – Valves for which seat leakage in the closed position is inconsequential for fulfillment of the required function(s).
- Category C – Valves that are self-actuating in response to some system characteristic, such as pressure (relief valves) or flow direction (check valves) for fulfillment of their function.
- Category D – Valves that are actuated by an energy source capable of only one operation, such as rupture disks or explosively actuated valves.

In addition to the valve categories described above, valves are also characterized as active or passive based on the definitions below.

- Active Valves – Valves that are required to change obturator position to accomplish their required function.
- Passive Valves – Valves that maintain obturator position and are not required to change obturator position to accomplish their required function.

8.3.5 Preservice Testing

Each valve shall be tested during the preservice period. These tests shall be conducted under conditions as near as practicable to those expected during subsequent inservice testing. Note that the Preservice Period had already passed when IST requirements were first introduced at Robinson. Only one preservice test of each valve is required with the following exceptions:

- Any valve that has undergone maintenance that could affect its performance after the preservice test shall be tested in accordance with paragraph 8.3.8;
- Safety and relief valves and non-reclosing pressure relief devices shall meet the preservice test requirements of Appendix I of the OM Code.

8.3.6 Inservice Testing

Inservice testing shall commence when the valves are required to be operable to fulfill their required function(s).

8.3.7 Reference Values

1. Reference values shall be determined from the results of preservice testing or from the results of inservice testing. These tests shall be performed under conditions as near as practicable to those expected during subsequent inservice testing.
2. Values shall be established only when the valve is known to be operating acceptably. If the particular parameter being measured can be significantly influenced by other related conditions, then these conditions shall be analyzed.

8.3.8 Effect of Valve Maintenance, Replacement, or Repair

1. When a valve or its control system has been replaced, repaired, or has undergone maintenance that could affect the valves performance, a new reference value shall be determined or the previous value shall be reconfirmed by an inservice test before it is returned to service. Deviations between the previous and new reference values shall be identified and analyzed. Verification that the new values represent acceptable operation shall be documented in the record of tests.
2. Safety and relief valves and nonreclosing pressure relief devices shall be tested as required by the replacement, repair and maintenance requirements of EST-027, EST-028, EST-068, EST 112 and EST-130. These EST's meet the requirements of OM Code, Appendix I.

8.3.9 Establishment of Additional Set of Reference Values

1. If it is necessary or desirable for some reason, other than the requirements of paragraph 8.3.8, to establish additional reference values, an inservice test shall first be run at the conditions of an existing set of reference values, or, if impractical, at the conditions for which the new reference values are required, and the results analyzed.
2. If operation is acceptable in accordance with 8.3.17.1 below, a second test shall be performed under the new conditions as soon as practicable.
3. The results of the second test shall establish the additional reference values.
4. The reasons for establishing additional reference values shall be justified and documented in plant records.

8.3.10 Inservice Testing Requirements

Active and passive Category A, B, C, and D valves shall be tested in accordance with Table 8.3-1.

NOTE: There are no ASME Code class Category D (explosive valves, rupture discs) at RNP.

8.3.11 Testing Methods

8.3.12 Valve Position Verification

Valves with remote position indicators shall be observed locally at least once every 2 years to verify that valve operation is accurately indicated.

- Where practicable, this local observation should be supplemented by other indications such as flow or pressure. These observations need not be concurrent.
- Where local indication is not possible other indications shall be used to verify valve operation.

8.3.13 Category A and B Valve Exercise Tests

8.3.14 Exercising Test Frequency

Active Category A and B valves shall be tested nominally every three months, except as provided by paragraphs 8.3.15, 8.3.20 and 8.3.21.

8.3.15 Exercising Requirements

Valves shall be tested as follows:

1. Full stroke exercising during plant operation to the position required to fulfill its function;
2. If full-stroke exercising during plant operation is not practicable, it may be limited to part-stroke exercising during plant operation and full-stroke exercising during cold shutdown;
3. If exercising is not practicable during plant operation, it may be limited to full stroke exercising during cold shutdown;
4. If exercising is not practicable during plant operation and full-stroke during cold shutdowns is also not practicable, it may be limited to part stroke during cold shutdowns, and full-stroke during refueling outages;
5. If exercising is not possible during plant operations or cold shutdowns, it may be limited to full stroke exercising during refueling outages;
6. Except as specified below, valves full-stroke exercised during cold shutdowns shall be exercised during each cold shutdown. Exercising is not required if the time period since the previous full-stroke exercise is less than 3 months.
7. Valve exercising during cold shutdown shall commence within 48 hours of achieving cold shutdown and continue until all testing is completed or the plant is ready to return to power. For extended outages, testing need not be commenced in 48 hours provided all valves required to be tested during cold shutdowns will be tested prior to plant startup and all valves that are required to perform their specified function are exercised every 3 months. However, it is not intended to keep the plant in cold shutdown to complete cold shutdown testing.
8. All valve testing required to be performed during a refueling outage shall be completed before returning the plant to operation.

8.3.16 Valve Obturator Movement

The necessary valve obturator movement shall be determined by exercising the valve while observing an appropriate indicator, such as indicating lights or observing other evidence such as changes in system pressure, flow rate, level, or temperature.

8.3.17 Power-Operated Valve Stroke Testing:

1. Limiting values of full-stroke time of each power-operated valve shall be specified;
2. The stroke time shall be measured to the nearest second;
3. Any abnormality or erratic action shall be recorded and an evaluation shall be made to determine if corrective action is required.

8.3.18 Power-Operated Control Valve Testing

1. For power-operated control valves that have only a fail-safe safety function, the requirements for valve stroke-time measurement testing, the associated stroke-time test acceptance criteria, and any corrective actions that would result from stroke-time testing need not be met. For these valves, all other applicable requirements listed below shall be met.
 - a. Stroke Testing
 - b. Position Indication Testing
 - c. Leakage Testing
 - d. Any abnormality or erratic action shall be recorded and an evaluation shall be made regarding the need for corrective action.
2. Valves with fail-safe actuators shall be tested by observing the operation of the actuator upon loss of valve actuator power in accordance with the exercising frequency of paragraph 8.3.14. Note that there are valves with fail-safe actuators where neither the actuator nor the valve has a safety function. These actuators are not included in the program.

8.3.19 Power-Operated Relief Valve Testing

1. Power-operated relief valves testing shall be performed in the following sequence or concurrently. If testing in the following sequence is impractical, it may be performed out of sequence, and a justification shall be documented in the record of tests for each test or in the test plan. Pursuant to this requirement, leakage testing of PORVs is performed on a continuous basis using installed plant indicators and daily RCS leak rate computations. These tests are performed at normal operating pressure and exceed the test pressures required by Appendix I of the OM Code for seat tightness testing. Therefore, an additional seat leakage test is not necessary. RNP power-operated relief valves are not capacity certified.

The following test requirements apply to power-operated relief valves

- a. Leakage testing
- b. Stroke testing, including stroke time
- c. Position Indication Testing
- d. Any abnormality or erratic action shall be recorded and an evaluation shall be made regarding the need for corrective action
- e. Stroke testing shall be performed during normal operating conditions for temperature and pressure

8.3.20 Valves in Regular Use

Valves that operate in the course of plant operation at a frequency that satisfies the exercising requirements need not be additionally exercised, provided that the observations otherwise required for testing are made and analyzed during operation. The results shall be recorded in the plant record at intervals no greater than specified in paragraph 8.3.14.

8.3.21 Valves in systems Out of Service

For valves in a system declared inoperable or not required to be operable, the exercising test schedule need not be followed. Valves shall be exercised within three months before placing the system in operable status and the normal test frequency resumed.

8.3.22 Power Operated Valves Stroke Time Acceptance Criteria

Test results shall be compared to the initial reference values or reference values established in accordance with paragraphs 8.3.8 or 8.3.9.

1. Motor operated valves with reference stroke times of greater than 10 seconds shall exhibit no more than $\pm 15\%$ change in stroke time when compared to the reference value.
2. Pneumatic, Hydraulic, Solenoid and Power-operated relief valves with reference stroke times of greater than 10 seconds shall exhibit no more than $\pm 25\%$ change in stroke time when compared to the reference value.
3. Motor operated valves with reference stroke times of less than or equal to 10 seconds shall not exhibit no more than $\pm 25\%$ nor ± 1 second change in stroke time, whichever is greater, when compared to the reference value.
4. Pneumatic, Hydraulic, Solenoid and Power-operated relief valves with reference stroke times of less than or equal to 10 seconds shall exhibit no more than $\pm 50\%$ change in stroke time when compared to the reference value.
5. Power operated valves that stroke in less than 2 seconds may be exempted from paragraphs 3 and 4 above. In such cases the maximum stroke time shall be 2 seconds.

8.3.23 Corrective Action for Stroke-Timed Valves

1. If a valve fails to exhibit the required change of obturator position or exceeds the limiting values of full-stroke time of paragraph 8.3.17.1, the valve shall be immediately declared inoperable.
2. Valves with measured stroke times that do not meet the acceptance criteria of paragraph 8.3.22, shall be immediately retested or declared inoperable. If the valve is retested and the second set of data also does not meet the acceptance criteria, the valve shall be declared inoperable. If the second set of data meets the acceptance criteria, the cause of the initial deviation shall be analyzed and documented in the record of tests.
3. Valves declared inoperable shall be repaired, replaced, or the data may be analyzed to determine the cause of the deviation and the valve shown to be operating acceptably.
4. Valve operability based upon analysis shall have the results recorded in the record of tests. Caution should be exercised if an evaluation is used to recommend valve operability when performance is in the alert or required action range. OPS-NGGC-1305, *Operability Determinations* should be consulted to determine if the process for a degraded or non-conforming condition should be followed.
5. Before returning a repaired or replaced valve to service, a test demonstrating satisfactory operation shall be performed.

8.3.24 Seat Leakage Tests for Category A Valves

8.3.25 Scope

Category A valves shall be leakage tested, except that valves which function in the course of plant operation in a manner that demonstrates functionally adequate seat leak tightness need not be additionally tested. In such cases, the valve record shall provide the basis for the conclusion that operational observations constitute satisfactory demonstration.

8.3.26 Containment Isolation Valves

1. Containment isolation valves with a leakage rate requirement based on an Appendix J program shall be tested in accordance with TMM-005. Procedure TMM-005 meets the requirements of 10CFR50, Appendix J
2. Containment isolation valves with a leakage requirement based on other functions shall be tested in accordance with paragraph 8.3.27.

8.3.27 Leakage Rate for other than Containment Isolation Valves

These valves shall be leakage tested to verify their leak-tight integrity. Valve closure before seat leakage testing shall be by using the valve operator with no additional closing force applied.

1. Frequency – Tests shall be conducted at least once every two years,
2. Differential Test Pressure – Differential pressure shall be applied in the same direction as when the valve is performing its function with the following exceptions:

- a. Globe valves may be tested with the pressure under the seat,
 - b. Butterfly valves may be tested in either direction, provided their seat construction is designed for sealing against pressure on either side.
 - c. Double-disk gate valves may be tested by pressurizing between the seats,
 - d. Seat leakage tests involving pressure differential lower than function pressure differentials are permitted in those valves in which service pressure will tend to diminish the overall leakage channel opening,
 - e. Valves that do not qualify for reduced pressure testing shall be tested at maximum function pressure.
3. Seat Leakage Measurement – Valve Seat leakage shall be determined by one of the following methods:
- a. Measuring leakage through a downstream telltale connection while maintaining pressure on one side of the valve, or
 - b. Maintaining feed rate required to maintain test pressure in the test volume or between two seats of a gate valve, provided the total apparent leakage rate is charged to the valve or valve combination, or
 - c. Determining leakage by measuring pressure decay in the test volume.
4. Test Medium - shall be specified in the procedure.
5. Analysis of Leakage Rates – Leakage rate measurements shall be compared with the permissible leakage rates specified by the Owner (usually identified in the implementing test procedure). The permissible leakage rate specified by the Owner should be based on specific design or operational criteria limits. When this criteria cannot be determined, then the permissible leak rate may be calculated as follows:
- a. For water, 0.5D gal/min or 5 gal/min, whichever is less, at functional differential pressure, where D equals nominal valve size.
 - b. For air, 7.5D standard ft³/day, at functional differential pressure.
6. Corrective Action – Valves or valve combinations with leakage rates exceeding the values specified by the Owner in paragraph 8.3.27.5 shall be declared inoperable and either repaired or replaced. A retest demonstrating acceptable operation shall be performed following any required corrective action before the valve is returned to service.

8.3.28 Tests for Category C Safety and Relief Valves

Tests for Category C Safety and Relief Valves are conducted in accordance with Appendix I of the OM Code.

1. Pressurizer safety valves are tested in accordance with EST-027.
2. Main Steam Safety Valves are tested in accordance with EST-028.
3. All other safety and relief valves required to be tested pursuant to ASME OM Code requirements are tested in accordance with EST-112.
4. Containment Spray Additive Tank Vacuum Breakers are tested in accordance with EST-068.
5. The CCW Surge Tank Vacuum Breaker is tested in accordance with EST-130.
6. EST-111 'Safety, Pressure Relief & Vacuum Breaker Valve Test Selection and Verification' is utilized to periodically verify that test frequencies applicable to safety valves, relief valves and vacuum breakers conform to the frequency requirements specified in Appendix I of the OM Code.

8.3.29 Exercise Tests for Category C Check Valves

8.3.30 Exercising Test Frequency

Check valves shall be exercised nominally every three months except as provided in paragraphs 8.3.31 through 8.3.36.

8.3.31 Exercising Requirements

Valves shall be exercised as follows:

1. During plant operation, valves shall be exercised or examined in a manner that verifies obturator travel by using the methods in paragraph 8.3.34.
2. Each check valve exercise test shall include open and close tests. Open and close tests need only be performed at an interval when it is practical to perform both tests. Open and close tests are not required to be performed at the same time if they are both performed within the same interval.
3. If exercising is not practicable during plant operation, it shall be performed during cold shutdowns.
4. If exercising is not practicable during plant operation and cold shutdown, it shall be performed during refueling outages.
5. Valves exercised at shutdowns shall be exercised during each shutdown, except as specified in "6" below. Such exercise is not required if the interval since the previous exercise is less than three months.
6. Valve exercising shall commence within 48 hours of achieving cold shutdown and continue until all testing is complete or the plant is ready to return to power. For extended outages, testing need not be commenced in 48 hours if all the valves required to be tested during cold shutdown will

be tested before plant startup. However it is not the intent to keep the plant in cold shutdown to complete cold shutdown testing.

7. All valve testing required to be performed during refueling outages shall be completed before returning the plant to operation.

8.3.32 Exercise Tests for Manual Valves

Manual valves shall be full stroke exercised at least once every two years, except where adverse conditions may require the valve to be tested more frequently to assure operational readiness. Any increased testing frequency shall be specified. The valve shall exhibit the required change of obturator position.

8.3.33 Valves in Regular Use

Check valves that operate in the course of plant operation, at a frequency that would satisfy the exercising requirements, need not be additionally exercised. The observations otherwise required for testing are required to be made, analyzed, and recorded in the plant records at intervals not greater than three months.

8.3.34 Valve Obturator Movement

1. The necessary valve obturator movement shall be demonstrated by performing both an open and a closed test.
 - a. Check valves that have a safety function in both the open and closed directions shall be exercised by initiating flow and observing that the obturator traveled to either the full open position, or to the position required to perform its intended function. Verification that on cessation of flow the obturator has traveled to its seat shall also be demonstrated.
 - b. Check valves that have a safety function in only the open direction shall be exercised by initiating flow and observing that the obturator has traveled to either the full open position or to the position required to perform its intended function and verify closure.
 - c. Check valves that have a safety function in only the closed direction shall be exercised by initiating flow and observing that the obturator has traveled to at least the partially open position, and verify that on cessation or reverse flow, the obturator has traveled to its seat.
2. Observations shall be made by observing a direct indicator or by other positive means such as change in system pressure, flow rate, level, temperature, seat leakage testing, or non-intrusive testing.
3. If the test methods described in paragraph 8.3.34.1 are impractical for certain check valves, or if sufficient flow cannot be achieved or verified, a sample disassembly examination program shall be used to verify valve obturator movement.
 - a. The sample disassembly program shall group valves of similar design, application, and service condition and require a periodic

examination of one valve from each group. The details and bases for the sampling program shall be documented.

- b. Grouping of check valves shall be technically justified and shall consider valve manufacturer, design, service, size, materials of construction, and orientation
- c. During the disassembly process, the full-stroke motion of the obturator shall be verified. Valves that have been disturbed prior to verifying obturator movement shall be examined to determine if a condition exists that could prevent full opening or reclosing of the obturator.
- d. At least one valve from each group shall be disassembled and examined at each refueling outage. All valves in each group shall be disassembled and inspected once every eight years.
- e. Before return to service, valves that were disassembled for examination or that received maintenance that could affect their performance shall be exercised if practicable with flow in accordance with 8.3.31.
 - 1) These valves shall also be tested for other requirements such as leak rate testing.
 - 2) Examples of check valves that can be impacted by disassembly include spring loaded check valves or check valves with the obturator supported by the bonnet.

8.3.35 Check Valve Condition Monitoring

As an alternative to the testing or examination requirements of paragraphs 8.3.30 through 8.3.34, a Condition Monitoring program may be established. The purpose of this program is both to improve valve performance and to optimize testing, examination, and preventative maintenance activities in order to maintain the continued acceptable performance of a select group of check valves.

- 1. The program may be implemented on a valve or group of similar valves.
- 2. The program is implemented in accordance with TMM-008, subject to any conditions imposed by the NRC in the Federal Register.
 - a. Each valve must be tested to both the open and closed direction (bi-directional test).
 - b. The maximum test or examination interval for a valve or group of valves is based on the following table. All valves in the group must be tested or examined within the maximum interval to be considered a valid extension.

Group Size	Maximum Interval (years)
≥ 4	16
3	12
2	12
1	10

3. TMM-008 meets the requirements of Appendix II of the OM Code and lists the tests, examinations, frequencies, recommended post maintenance tests (following disassembly to meet the Appendix II program) and groupings that are applicable to a particular valve included in the condition monitoring program.
4. If the condition-monitoring program for a valve or group of valves is discontinued, then the requirements of paragraphs 8.3.30 through 8.3.34 must be applied.
5. Valves subject to the requirements of a condition monitoring program are identified by the reference to App. II in the Test Frequency column.

8.3.36 Valves in Systems Out of Service

For valves in a system declared inoperable or not required to be operable, the exercising test schedule need not be followed. The valve shall be exercised and the schedule followed within three months of placing the system in an operable status.

8.3.37 Series Valve Pairs

If two check valves are in series configuration without provisions to verify individual reverse flow closure, and the plant safety evaluation assumes closure of either valve (not both), the valve pair may be operationally tested closed as a unit. If the plant safety evaluation assumes that a specific valve or both valves of the pair close to perform the safety function, the required valve(s) shall be tested to demonstrate individual valve closure.

8.3.38 Corrective Action for Check Valve Exercise Tests

1. If a check valve fails to exhibit the required change of obturator position, it shall be declared inoperable. A retest showing acceptable performance shall be run following any required corrective action before the valve is returned to service.
2. Check valves in a sample disassembly program that are not capable of being full stroked exercised, or have failed or have unacceptable valve internals, shall have the cause of the failure analyzed and the condition corrected. Other valves in the sample group that may also be affected shall be examined or tested during the same refueling outage.
3. Series valves tested as a unit in accordance with paragraph 8.3.37 and fail to prevent reverse flow shall be declared inoperable, and both valves shall be either repaired or replaced.

8.3.39 Tests for Category D Explosively Actuated Valves

Not applicable to RNP.

8.3.40 Tests for Category D Rupture Disks

Not applicable to RNP.

8.3.41 Tests for Dynamic Restraints (Snubbers)

Requirements, selection and methods for the testing of snubbers are defined in accordance with TMM-038, *Inservice Examination Program* and TMM-006, *Shock Suppressor (Snubber) Examination and Testing Program*.

9.0 RECORDS

9.1 Records generated as a result of this procedure (e.g., IST Evaluations) shall be reviewed, approved and forwarded to the QA Records vault for retention.

9.2 Pumps

9.2.1 Pump Records

Records shall be maintained that include the following for each pump:

- Manufacturer and manufacturer's model and serial or other identification number;
- A copy or summary of the manufacturer's acceptance test, report, if available; and
- A copy of the pump manufacturer's operating limits.

9.2.2 Inservice Test Plans

Record of test plans and procedures shall be maintained that include the following:

- Identification of pumps subject to testing;
- Category of each pump;
- Hydraulic circuit to be used;
- Location and type of measurement for the required test parameters;
- Reference Values;
- Method of determining test parameter values that are not directly measured by instrumentation.

9.2.3 Record of Test

Records of each test shall be maintained that include the following:

- Pump identification;
- Date of test;
- Reason for test (e.g., scheduled, post maintenance test, establishing new reference values);
- Values of measured parameters;
- Identification of instruments used;
- Comparisons with allowable ranges and analysis of deviations;
- Requirement for corrective action;
- Evaluation and justification for changes of reference values; and
- Signature of the person or persons responsible for conducting and analyzing the test.

ATTACHMENT 10.5 provides a list of pumps within the scope of the IST Program and their associated test procedures.

9.3 Valves

9.3.1 Valve Records

Records shall be maintained that include the following information:

- The manufacture and manufacturers model and serial or other unique identification number;
- A copy or summary of the manufacturers acceptance test report if available;
- Preservice test results;
- Limiting values of full-stroke time.

9.3.2 Inservice Test Plans

Record of test plans and procedures shall be maintained that include the following:

- Identification of valves subject to testing;
- Category of each valve;
- Tests to be performed;
- Justification for deferral of stroke (exercising) testing;
- Details and bases of the check valve sample disassembly examination program, such as grouping characteristics, frequency and justification for not performing an exercise test to at least a partially open position after reassembly or periodic exercising;
- Basis for testing series check valve pairs.

ATTACHMENTS 10.2, 10.3 and 10.4 provide the test deferral justifications. ATTACHMENT 10.6 provides a list of the valves in the scope of the IST Program.

9.3.3 Record of Test

Records of each test shall be maintained that include the following:

- Valve identification;
- Date of test;
- Reason for test (e.g., scheduled, post maintenance test, establishing new reference values);
- Values of measured parameters;
- Identification of instruments used;
- Comparison with allowable ranges and analysis of deviations;
- Requirement for corrective action;
- Signature of the person or persons responsible for conducting and analyzing the test.

9.4 Records of Corrective Action

Records of corrective action shall be maintained and shall include a summary of the correction made, the subsequent inservice tests, confirmation of operational adequacy, and the signature of the individual responsible for the corrective action and the individual responsible for verification.

9.5 Preconditioning (NRC Information Notice 97-16)

NRC IN 97-16 has been evaluated for applicability and corrective measures have been taken to address preconditioning concerns involving IST activities. Preconditioning may be defined as the alteration, variation, manipulation or adjustment of the physical condition of an SSC before Technical Specification surveillance or ASME Code testing. In some cases, the safety benefit of a preconditioning activity may outweigh the benefits of testing in the as-found condition. In the event that this condition arises, the activity should be evaluated to determine whether it constitutes acceptable or unacceptable preconditioning. The overall effect of the activity and a justification documenting the continued confidence in the capability to assess the operational readiness of the component must be considered in order to determine whether the activity constitutes acceptable pre-conditioning.

NRC Inspection Manual, Part 9900 should be consulted for additional guidance to assist in determining whether a certain activity should be considered to be preconditioning. It may also be used to provide further guidance as to the acceptability or unacceptability of the preconditioning event. Unacceptable preconditioning is to be avoided. The following are examples of acceptable and unacceptable preconditioning.

Acceptable preconditioning:

- Periodic venting of pumps, which is not routinely scheduled directly prior to testing, but may be performed occasionally prior to testing.
- Pump venting prior to testing provided that the venting operation has proper controls with a technical evaluation to establish that the amount of gas vented would not adversely affect pump operation.
- Occasional lubrication of a valve stem prior to testing a valve, where stem lubrication is not typically performed prior to testing.
- Unavoidable movement attributable to the setup and connection of test equipment.
- Improper timing of a power operated valve where the valve must be immediately retested in order to obtain a valid stroke time measurement.

Adequate assurance must be available to support the conclusion that the valve stroke time would have been below the limiting value. The deviation shall be documented in the record of test.

Unacceptable preconditioning:

- Routine lubrication of a valve stem prior to testing the valve.
- Operation of a pump or valve shortly before a test, if such operation could be avoided through plant procedures with personnel and plant safety maintained.
- Venting a pump immediately prior to testing without proper controls and scheduling.
- An activity performed to ensure that the pump or valve will meet its acceptance criteria.
- An activity performed to mask the as-found condition of the pump or valve.

ADM-NGGC-0115, *Preconditioning of Structures, Systems and Components* provides more detail on this subject.

9.6 Use of Non-conservative Acceptance Criteria (NRC information Notice 97-090)

Information regarding the minimum performance requirements for each pump tested to ASME Code requirements may be found in calculation RNP-M/MECH-1802. All surveillance test acceptance criteria are reviewed to ensure that minimum performance requirements are met.

Design engineering provides the minimum allowable pump performance. The minimum performance point shall include maximum instrument error (not uncertainty) associated with the flow rate instrument, pressure (differential pressure) instruments and speed instruments, if the pump is a variable speed pump. The performance shall be additionally compensated to account for the minimum allowable EDG frequency specified in the Plant TS. The resultant criteria shall be included in the appropriate pump performance tests used to confirm design basis requirements (reference OE 31798, Misunderstanding of Power Up-Rate Margin Application).

9.7 Program Notebook

A program notebook will be developed and maintained by IST personnel consistent with the guidelines established in EGR-NGGC-0008, *Engineering Programs*.

9.8 Background Information

A background document is maintained in the IST database. This data should be used for information only. The IST database is a tool intended to assist the user in understanding the rationale for testing or excluding certain pumps or valves from the IST program. The database shall not be used to verify design or licensing basis.

9.9 Inservice Testing Evaluation

The EVAL EC process described in EGR-NGGC-0028, *Engineering Evaluation* should be used to document component conditions or program positions noted during inservice testing activities, or during routine plant operations. The EVAL EC process may be used to evaluate component performance, establish new reference values, establish corresponding acceptance criteria, or document a response to an ASME OM Code related inquiry provided the solution:

- Is within Bounding Technical Requirements defined in EGR-NGGC-0028,
- Is technically acceptable with respect to existing design inputs,
- Conforms to existing design bases, committed standards, and regulations,
- Does not adversely affect the design function, or adversely affect the method of performing or controlling a design function,
- Does not introduce new failure modes, and
- Does not change the Licensing Basis

The determination of acceptance limits is based on multiplication tables provided in the ASME OM Code, unless truncated by a design document. The derivation of acceptance limits involves simple arithmetic and is not considered to be a calculation. These new limits shall be peer checked by the system or responsible engineer.

Component performance evaluations shall follow all requirements of the Code; however, minimum fundamental elements must be addressed when completing the evaluation.

- Is the cause of the deviation known and the impact understood?
- Are the proposed acceptance limits within design basis performance requirements? Generally, pump performance must achieve a minimum hydraulic point and power operated valves must stroke below a specified limiting value.
- For changes to pump vibration reference values, does the Vibration Engineer concur with the proposed alert and required action limits?
- Established processes shall be used to ensure that the impacted procedure has been identified and is placed on hold, if changes to acceptance limits are required.

Caution should be exercised if an evaluation is used to recommend pump operability when performance is in the alert or required action range. OPS-NGGC-1305, *Operability Determinations* should be consulted to determine if the process for a degraded or non-conforming condition should be followed. In addition:

- For pump performance in the alert or required action range, and continued performance at this range is supported by an analysis, a pump and system level evaluation of operational readiness must be performed by the applicable System Engineer.

10.0 ATTACHMENTS

10.1 Systems and P&ID's

10.2 Relief Requests

10.3 Cold Shutdown Justifications

10.4 Refueling Shutdown Justifications

10.5 Pump Table

10.6 Valve Table

10.7 Excluded Valve Table

ATTACHMENT 10.1
Page 1 of 2
Systems and P&ID's

System	P&ID (Sheet)
Primary Sampling System	5379-353 (1)
Component Cooling Water System	5379-376 (1)
Component Cooling Water System	5379-376 (2)
Component Cooling Water System	5379-376 (3)
Component Cooling Water System	5379-376 (4)
Chemical Volume and Control System	5379-685 (1)
Chemical Volume and Control System	5379-685 (2)
Chemical Volume and Control System	5379-685 (3)
Chemical Volume and Control System	5379-686 (1)
Liquid Waste Disposal System	5379-920 (3)
Gaseous Waste Disposal System	5379-921 (2)
Safety Injection System	5379-1082 (1)
Safety Injection System	5379-1082 (2)
Safety Injection System	5379-1082 (3)
Safety Injection System	5379-1082 (4)
Safety Injection System	5379-1082 (5)
Residual Heat Removal System	5379-1484 (1)
Reactor Coolant System	5379-1971 (1)
Reactor Coolant System	5379-1971 (2)
Main and Extraction Steam	G-190196 (1)
Feedwater, Condensate and Air Evacuation System	G-190197 (1)
Feedwater, Condensate and Air Evacuation System	G-190197 (4)
Service and Cooling Water System	G-190199 (1)
Service and Cooling Water System	G-190199 (2)
Service and Cooling Water System	G-190199 (4)
Service and Cooling Water System	G-190199 (5)
Service and Cooling Water System	G-190199 (6)
Service and Cooling Water System	G-190199 (7)
Service and Cooling Water System	G-190199 (9)
Service and Cooling Water System	G-190199 (10)

ATTACHMENT 10.1
Page 2 of 2
Systems and P&ID's

System	P&ID (Sheet)
Instrument and Station Air System	G-190200 (2)
Instrument and Station Air System	G-190200 (3)
Instrument and Station Air System	G-190200 (5)
Instrument and Station Air System	G-190200 (7)
Instrument and Station Air System	G-190200 (9)
Primary and Makeup Water System	G-190202 (3)
Emergency Diesel Generator System	G-190204A (2)
Emergency Diesel Generator System	G-190204A (3)
Fuel Oil System	G-190204D (1)
Fuel Oil System	G-190204D (2)
Steam Generator Blowdown and Wet Lay-up System	G-190234 (1)
Penetration Pressurization System	G-190261 (2)
Isolation Valve Seal Water System	G-190262 (1)
HVAC-Turbine, Fuel, Auxiliary and Reactor Building Systems	G-190304 (1)
Containment Vapor and Pressure Sampling System	HBR2-6490 (1)
Post Accident Containment Venting System	HBR2-6933 (1)
Fire Protection System	HBR2-8255 (2)

ATTACHMENT 10.2
Page 1 of 8
RELIEF REQUESTS
IST-RR-1

Basis for request: Pursuant to 10 CFR 50.55a(a)(3)(i), this alternative provides an acceptable level of quality and safety.

ASME Code Components Affected

Component Identification	Group	Type
BA-XFER-PMP-A, BA-XFER-PMP-B: Boric Acid Transfer Pumps	A	C-H
CCW-PMP-A, CCW-PMP-B, CCW-PMP-C: Component Cooling Water Pumps	A	C-H
CHG-PMP-A, CHG-PMP-B, CHG-PMP-C: Chemical Volume Control System Charging Pumps	A	PD-R
SWBP-A, SWBP-B: Service Water Booster Pumps	A	C-H
SW-PMP-A, SW-PMP-B, SW-PMP-C, SW-PMP-D: Service Water Pumps	A	VLS

Applicable Code Edition and Addenda

American Society of Mechanical Engineers (ASME) Operation and Maintenance (OM) Code, 2004 Edition through 2006 Addenda.

Applicable Code Requirement

ISTB-2000, "Supplemental Definitions," defines uniform criteria for designating Group A and Group B pumps.

ISTB-3000, "General Testing Requirements," and Table ISTB 3000-1, "Inservice Test Parameters," define and compare parameters (e.g., pressure flow rate, vibration) measured during Group A, Group B, and Comprehensive pump tests.

ISTB-3400 "Frequency of Inservice Tests," states that an inservice test shall be run on each pump specified in Table ISTB 3400-1. This table requires a Group A or Group B test to be performed quarterly and a Comprehensive test to be performed biennially.

Table ISTB-3510-1, "Required Instrument Accuracy," defines the required instrument accuracy for Group A, Group B and Comprehensive pump tests.

Table ISTB-5121-1, "Centrifugal Pump Test Acceptance Criteria", defines the required acceptance criteria for centrifugal pumps, when a Comprehensive test is performed in lieu of a Group A or Group B pump test.

Table ISTB-5221-1, "Vertical Line Shaft Centrifugal Pump Test Acceptance Criteria", defines the required acceptance criteria for vertical line shaft centrifugal pumps, when a Comprehensive test is performed in lieu of a Group A or Group B pump test.

Table ISTB-5321-2, "Reciprocating Positive Displacement Pump Test Acceptance Criteria", defines the required acceptance criteria for reciprocating positive displacement pumps, when a Comprehensive test is performed in lieu of a Group A or Group B pump test.

ATTACHMENT 10.2
Page 2 of 8
RELIEF REQUESTS
IST-RR-1

Specific Relief Requested

Pursuant to 10 CFR 50.55a(a)(3), relief is requested from the requirements of the ASME OM Code, 2004 Edition through 2006 Addenda, Subsection ISTB, Paragraphs ISTB-5123, 5223 & 5323 "Comprehensive Test Procedure." The basis for this request is that the proposed alternative will provide an acceptable level of quality and safety. Table ISTB-3400-1, "Inservice Test Frequency," specifies that a biennial Comprehensive Pump Test (CPT) be performed on Group A and B pumps. Paragraph ISTB-5123 describes requirements necessary to properly implement a CPT for centrifugal pumps. Paragraph ISTB-5223 describes requirements necessary to properly implement a CPT for vertical line shaft centrifugal pumps and ISTB-5323 describes requirements necessary to properly implement a CPT for positive displacement pumps. Performance of the biennial CPT on the pumps identified above is unnecessary because performance of a quarterly Group A pump test at the comprehensive test flow rate is equally sufficient when assessing operational readiness. Quarterly testing at design flow rates in accordance with the Group A test requirements provides better assessment of overall pump capability when compared to an infrequent CPT supplemented with a Group A test at reduced flow rates and supports timely detection of degrading pump performance.

The CPT utilizes a reduced upper hydraulic limit of 1.03 of the reference value. This value is overly conservative and does not take into account the aggregate impact of nominally expected test deviations and allowances for instrument accuracy. The end result is a potential overall reduction to safety system availability, a potential to increase unwarranted maintenance, and may create conflicts between surveillance tests when a Group A test and CPT are performed at identical conditions.

HBRSEP, Unit No. 2, proposes to conduct quarterly Group A testing at the CPT designated flow rate using pressure instrumentation that is accurate to 0.5 percent. In addition, the upper hydraulic performance limit will be reduced from 1.10 times the test parameter (flow, pressure, differential pressure) to a multiple of 1.06 times the test parameter.

Basis for Requesting Relief

The ASME OM ISTB committee has approved Code Case OMN-18, "Alternative Testing Requirements for Pumps Tested Quarterly within $\pm 20\%$ of Design Flow." This code case has not yet been approved for use in RG 1.192, "Operation and Maintenance Code Case Acceptability, ASME OM Code," June 2003. HBRSEP, Unit No. 2, is proposing to use this alternative; however, by conservatively reducing the upper hydraulic acceptance limit from 10% above the reference value to 6% above this value.

The use of more accurate pressure instrumentation during the performance of quarterly pump tests provides more precise and consistent trending of pump performance.

Due to the more stringent requirements proposed by this alternative, there is no added value in performing the biennial comprehensive pump test.

ATTACHMENT 10.2
Page 3 of 8
RELIEF REQUESTS
IST-RR-1

Proposed Alternative

HBRSEP, Unit No. 2, proposes that in lieu of the requirements of Table ISTB- 3400-1, Group A tests will be performed quarterly within ± 20 percent of the pump design flow rate, with instrumentation meeting the instrument accuracy requirements of Table ISTB-3510-1 for the biennial Comprehensive Test, and the Comprehensive Test will not be required.

Specifically,

- a. Pumps tested quarterly using this alternative must be tested within ± 20 percent of pump design flow rate, as is required for the biennial Comprehensive Test in ISTB-3300(e)(1).
- b. The proposed alternative requires the accuracy of instruments used during quarterly Group A tests to meet the more accurate pressure and differential pressure requirements listed for the Comprehensive Test in Table ISTB-3510-1 (an accuracy improvement from ± 2 percent to ± 0.5 percent). Consistent use of more accurate instruments during each quarterly test improves pump performance trending and evaluation.

Based on the testing strategy proposed, this alternative provides an acceptable level of quality and safety for monitoring the pumps and ensures they are capable of performing their safety function.

Implementation Schedule

This relief will be implemented during the HBRSEP, Unit No. 2, Fifth Ten-Year Inservice Testing Inspection for pumps required by ASME OM Code, 2004 Edition through 2006 Addenda, Subsection ISTB.

Precedents

The NRC granted Perry Nuclear Power Plant, Unit No. 1's Relief Request PR-3 in a safety evaluation dated October 8, 2009 (TAC NO. ME0820).

ATTACHMENT 10.2
Page 4 of 8
RELIEF REQUESTS
IST-RR-2

Basis for request: Pursuant to 10 CFR 50.55a(a)(3)(i), this alternative provides an acceptable level of quality and safety.

ASME Code Components Affected

Component Identification	Group	Type
CCW-PMP-A, CCW-PMP-B, CCW-PMP-C: Component Cooling Water Pumps	A	C-H
SI-PMP-A, SI-PMP-B, SI-PMP-C: Safety Injection Pumps	B	C-H
SW-PMP-A, SW-PMP-B: Service Water Pumps	A	VLS

Applicable Code Edition and Addenda

American Society of Mechanical Engineers (ASME) Operation and Maintenance (OM) Code, 2004 Edition through 2006 Addenda.

Applicable Code Requirement

Table ISTB-3510-1, "Required Instrument Accuracy", requires flow-rate instrument accuracy to be $\pm 2\%$.

Specific Relief Requested

Pursuant to 10 CFR 50.55a(a)(3), relief is requested from the requirements of the ASME OM Code, 2004 Edition through 2006 Addenda, Subsection ISTB, Table ISTB-3510-1, relief is requested from the $\pm 2\%$ instrument accuracy requirement over the calibrated range for ultrasonic flow measuring equipment that is used for pump testing in the Inservice Testing (IST) Program in the unlikely event that calibrated instrumentation is rendered inoperable.

Basis for Requesting Relief

Original plant design did not include flow rate measurement devices that met subsequent Code requirements. Since then, instrumentation that meets the Code requirements has been installed. However, these specific applications utilize devices that may be difficult to replace with certified instruments within the allotted limiting condition for operation (LCO). In the unlikely event that a flow rate device failed to operate properly and calibrated instrument (normally maintained for service water) is not available, an ultrasonic flow measurement device can be installed in accordance with specific instructions to ensure proper operation and provide accurate measurement of flow rate. Proper installation and operation of these devices yield an overall accuracy equivalent to, or better than the Code required accuracy.

The NRC has previously granted relief to use ultrasonic flow instruments in the third and fourth IST program intervals. NRC Safety Evaluation, transmitted in NRC letter dated September 16, 1992, accepted the use of ultrasonic flow instruments that have an intrinsic accuracy of $\pm 3\%$ on a temporary basis. Final approval was dependent on the establishment of procedures and controls that ensure measurements are sufficiently repeatable to allow detection of pump degradation. Also required, was a determination of the in-situ accuracy and repeatability in each application.

RNP2 Fifth IST Plan	Revision 1	Page 50 of 229
---------------------	------------	----------------

ATTACHMENT 10.2
Page 5 of 8
RELIEF REQUESTS
IST-RR-2

Subsequently CP&L transmitted, in a letter dated December 6, 1993, confirmation that ultrasonic flow instrumentation data taken during one cycle indicates the equipment has sufficient accuracy and repeatability to permit detection of hydraulic degradation, and supports the evaluation of results using Code allowable ranges. The NRC accepted this additional information in a letter dated, July 15, 1994. This relief request was re-submitted during the Fourth Interval Update and accepted by the NRC via letter dated June 27, 2002.

Previous experience and testing verify that non-calibrated ultrasonic flow measurements are highly accurate and consistent with published vendor literature, which states that an intrinsic accuracy of 1% to 2% of actual reading can be expected. The instruments are mounted externally, which avoids problems inherently associated with internally installed measuring devices and can be installed promptly.

Calibration of these instruments, however, cannot be performed onsite. The vendor must arrange for the use of a special test facility. Experience has shown that the expected time period associated with obtaining an emergent instrument calibration is about two to six weeks, and is largely dependent on events beyond the control of the site. All ultrasonic flow instruments are calibrated in accordance with Table ISTB 3510-1 and are verified and documented to be operating properly prior to the performance of the scheduled test. The Limiting Condition for Operation (LCO) would not be sufficient to facilitate diagnostics, instrument transport, repairs, calibration and re-installation and certification upon discovery that calibrated instruments are found to be deficient. Based on previous experience, unsatisfactory pump performance can be determined through the use of non-calibrated ultrasonic flow rate instruments when these instruments are properly installed and verified in accordance with site specific procedures. An acceptable level of quality and safety is maintained and the use of this alternative would be prudent in the unlikely event of this emergent condition.

Proposed Alternative

Non-calibrated ultrasonic flow measuring instruments may be utilized to satisfy the requirements of the OM Code for pump flow rate determinations in the unlikely event that calibrated flow measuring instruments are not available. This relief is not intended to be used repeatedly as a testing convenience. Efforts must be made to obtain an acceptable calibrated instrument for use during the next pump test. Documentation of the measures taken must be available for an onsite NRC review.

Implementation Schedule

This relief will be implemented during the HBRSEP, Unit No. 2, Fifth Ten-Year Inservice Testing Inspection for pumps required by ASME OM Code, 2004 Edition through 2006 Addenda, Subsection ISTB.

Precedents

The NRC granted relief to HBRSEP, Unit No. 2 for the Third Ten Year Interval via letter dated, July 15, 1994 and the Fourth Ten Year Interval via letter dated June 27, 2002.

ATTACHMENT 10.2
Page 6 of 8
RELIEF REQUESTS
IST-RR-3

Basis for request: Pursuant to 10 CFR 50.55a(a)(3)(i), this alternative provides an acceptable level of quality and safety.

ASME Code Components Affected

Component Identification	Category
IVSW-71, IVSW-72, IVSW-74 thru IVSW-97, IVSW 100A, IVSW-100B, and IVSW-100C	C

Applicable Code Edition and Addenda

American Society of Mechanical Engineers (ASME) Operation and Maintenance (OM) Code, 2004 Edition through 2006 Addenda.

Applicable Code Requirement

ISTC-1300, "Valve Categories" defines uniform criteria for assigning valve categories. Category C valves are defined as valves that are self actuating in response to some system characteristic, such as pressure (relief valves) or flow direction (check valves) for fulfillment of the required function(s).

ISTC-3510, "Exercising Test Frequency" requires Active Category A, Category B, and Category C check valves be exercised nominally every three months.

ISTC-3522(a), "Category C Check Valves" requires that Category C check valves be exercised or examined in a manner that verifies obturator travel by using methods in ISTC-5221. ISTC-3522(a) requires each check valve exercise test shall include open and closed tests.

ISTC-3530, "Valve Obturator Movement" states that the necessary valve obturator movement shall be determined by exercising the valve while observing an appropriate indicator, such as indicating lights that signal the required changes of obturator position, or by observing other evidence, such as changes in system pressure, flow rate, level or temperature, that reflects change of obturator position.

ISTC-5221(a), "Valve Obturator Movement" specifies that the required obturator movement during exercise testing be demonstrated by performing both an open and a close test.

ISTC-5221(a)(2), "Valve Obturator Movement" specifies that check valves that have a safety function in only the open direction shall be exercised by initiating flow and observing the obturator has traveled either to the open position or to the position required to perform its intended function(s) and verify closure.

ISTC-5221(c)(2), "Valve Obturator Movement" specifies that full stroke motion of the obturator shall be verified.

Basis for request: Pursuant to 10 CFR 50.55a(a)(3)(i), this alternative provides an acceptable level of quality and safety.

ATTACHMENT 10.2
Page 7 of 8
RELIEF REQUESTS
IST-RR-3

Specific Relief Requested

Pursuant to 10 CFR 50.55a(a)(3), relief is requested from the requirements of the ASME OM Code, 2004 Edition through 2006 Addenda, Subsection ISTC 3522(a), ISTC-3530, ISTC-5221(a), ISTC-5221(a)(2), and ISTC-5221(c)(2) that require Category C check valve exercise tests include both open and closed tests.

Specifically, relief is requested from the requirements of ISTC to verify closure. The check valves will be forward flow tested and closure verification will not be performed.

Basis for Requesting Relief

These check valves are 3/8 inch, spring-loaded ball type check valves in the Isolation Valve Seal Water System (IVSW) system have no safety function in the closed direction and are required to open in order to provide seal water to selected containment penetrations during a Design Basis Accident (DBA). The IVSW system operates to limit the release of fission products should leakage occur; however, no credit is actually taken for its operation when calculating off site accident dose. The system has been formally accepted as a qualified seal water system pursuant to 10 CFR 50 Appendix J requirements. IVSW is maintained at a minimum pressure of 1.1 times the peak accident pressure related to the design basis loss of coolant accident. As such, the design and qualification of the system eliminates the need for these valves to close during a DBA in the unlikely event that closure is required.

Disassembly to verify obturator closure or modifications to facilitate inservice testing for closure are impractical based on the large number of valves requiring verification and the insignificance associated with their failure to close. Disassembly may also lead to maintenance-induced errors associated with re-assembly. The small size and construction of these valves prohibits the ability to perform partial disassembly / inspection in a manner representative of its inservice condition (e.g., valve removal and decontamination activities could alter disc position).

IVSW is a standby system that is operated during refueling outages to facilitate testing. Based on infrequent use, the valve obturator exhibits minimal wear. Bi-directional check valve testing was adopted to counter the effects of a faulty test strategy associated with the inability to detect a detached valve disc. Specifically, a satisfactory forward flow check valve test could be completed when the valve disc is actually detached and laying in the bottom of the valve body. Based on the design and materials of construction associated with these check valves, disc failure with subsequent migration into associated systems is not likely. The size of the disc exceeds the inner diameter of the valve outlet. The nominal diameter of the ball is 5/16 of an inch, while the outlet port diameter is approximately one half that of the ball based on valve drawings.

It is likely that failure of the valve would be detected by the forward flow test method performed at refueling conditions, or by other installed indicators. The system is equipped with pressure and water level instruments that can provide indication if a check valve were to remain open while exposed to pressures that exceed IVSW system pressure.

ATTACHMENT 1C.2

Page 8 of 8

RELIEF REQUESTS

IST-RR-3

The location of these valves would make testing, inspection or examination for closure inconsistent with ALARA principles.

Based on the design and qualification of this system, compliance with the Code requirement would result in an unusual hardship without a compensating increase in the level of quality and safety. The proposed alternative provides an acceptable level of quality and safety.

Proposed Alternative

The 3/8-inch, spring-loaded ball type check valves installed in the IVSW system will be tested to the open position at refueling intervals. Closure verification will not be performed.

Implementation Schedule

This relief will be implemented during the HBRSEP, Unit No. 2, Fifth Ten-Year Inservice Testing Inspection for pumps required by ASME OM Code, 2004 Edition through 2006 Addenda, Subsection ISTC.

Precedents

The NRC granted relief to HBRSEP, Unit No. 2 for the Fourth Ten Year Interval via letter dated June 27, 2002.

ATTACHMENT 10.3
Page 1 of 26
COLD SHUTDOWN JUSTIFICATIONS
CC-VCS-1

Valve ID	Description
CC-716A	COOLING WATER INLET VALVE 'RCP CCW SUPPLY HEADER ISOLATION VALVE
CC-716B	COOLING WATER INLET VALVE 'RCP CCW SUPPLY HEADER ISOLATION VALVE

Function

Component Cooling Water supply to the Reactor Coolant Pumps.

Deferred Testing

Quarterly stroke time and full stroke exercise

Cold Shutdown Test Justification

Exercising these valves during power operation would result in a temporary loss of Component Cooling Water flow to all three Reactor Coolant Pump thermal barriers and bearing coolers. This action increases the potential for RCP damage and failure of either valve in the closed position will require that the unit be shutdown and RCPs secured. The valves are not designed to facilitate a part stroke exercise. Therefore, a partial stroke exercise test will not be performed since it may result in the same condition that would be encountered during the performance of a full stroke exercise test.

Cold Shutdown Test

Stroke time and full stroke exercise

ATTACHMENT 10.3
Page 2 of 26
COLD SHUTDOWN JUSTIFICATIONS
CC-VCS-2

Valve ID	Description
CC-730	RCP BEARING COOLING WATER OUTLET ISOLATION

Function

Allows flow through the Reactor Coolant Pump upper and lower bearing coolers

Deferred Testing

Quarterly stroke time and full stroke exercise

Cold Shutdown Test Justification

Exercising this valve during power operation would result in a temporary loss of Component Cooling Water flow through all three Reactor Coolant Pump bearing coolers. This action increases the potential for RCP damage and valve failure in the closed position will require that the unit be shutdown and RCPs secured. The valve is not designed to facilitate a part stroke exercise. Therefore, a partial stroke exercise test will not be performed since it may result in the same condition that would be encountered during the performance of a full stroke exercise test.

Cold Shutdown Test

Stroke time and full stroke exercise

ATTACHMENT 10.3
Page 3 of 26
COLD SHUTDOWN JUSTIFICATIONS
CC-VCS-3

Valve ID	Description
CC-735	RCP BEARING COOLING WATER OUTLET ISOLATION 'CIV'
FCV-626	RCP BEARING COOLING WATER OUTLET ISOLATION

Function

Allows flow through the Reactor Coolant Pump thermal barrier coolers

Deferred Testing

Quarterly stroke time and full stroke exercise

Cold Shutdown Test Justification

Exercising these valves during power operation would result in a temporary loss of Component Cooling Water flow to all three Reactor Coolant Pump thermal barrier coolers. This action increases the potential for RCP damage and failure of either valve in the closed position will require that the unit be shutdown and RCPs secured. The valves are not designed to facilitate a part stroke exercise. Therefore, a partial stroke exercise test will not be performed since it may result in the same condition that would be encountered during the performance of a full stroke exercise test.

Cold Shutdown Test

Stroke time and full stroke exercise

ATTACHMENT 10.3
Page 4 of 26
COLD SHUTDOWN JUSTIFICATIONS
CVC-VCS-1

Valve ID	Description
CVC-204A	CVC LETDOWN LINE
CVC-204B	CVC LETDOWN LINE

Function
CVCS Letdown isolation valves

Deferred Testing
Quarterly stroke time, full stroke exercise and fail safe test

Cold Shutdown Test Justification
Exercising these valves during power operation would isolate CVCS letdown causing pressurizer level to increase, charging flow to decrease and interrupt letdown flow to the regenerative heat exchanger. This would result in abnormal operating conditions and may result in a plant transient or unit trip due to pressurizer level variations, letdown line restoration events and uncontrolled positive reactivity addition as a result of cold water injection. Failure of any valve in the test position would isolate letdown. The valves are not designed to facilitate a part stroke exercise. Therefore, a partial stroke exercise test will not be performed since it may result in the same condition that would be encountered during the performance of a full stroke exercise test.

Cold Shutdown Test
Stroke time, full stroke exercise and fail safe test

ATTACHMENT 10.3
Page 5 of 26
COLD SHUTDOWN JUSTIFICATIONS
CVC-VCS-2

Valve ID	Description
CVC-381	REACTOR COOLANT PUMP SEAL WATER RETURN ISOLATION

Function

Isolation valve for the cooling water return from the Reactor Coolant Pump seals

Deferred Testing

Quarterly stroke time and full stroke exercise

Cold Shutdown Test Justification

Exercising this valve during power operation would cause a loss of seal water return and probable damage to the Reactor Coolant Pump seals. This would require that the unit be shutdown and RCPs secured. Valve failure in the test position would result in a complete loss of the seal water return flow path and would result in a unit shutdown and potential RCP damage. The valve is not designed to facilitate a part stroke exercise. Therefore, a partial stroke exercise test will not be performed since it may result in the same condition that would be encountered during the performance of a full stroke exercise test.

Cold Shutdown Test

Stroke time and full stroke exercise

ATTACHMENT 10.3
Page 6 of 26
COLD SHUTDOWN JUSTIFICATIONS
CVC-VCS-3

Valve ID Description

CVC-310A CHARGING TO LOOP 'A' HOT LEG ISOLATION

Function

Air operated valve required to open and provide an alternate boration flow pathway to RCS loop "A" hot leg in the event that the normal boration pathway is not available

Deferred Testing

Quarterly stroke time, full stroke exercise and fail safe test

Cold Shutdown Test Justification

Exercising this normally closed valve to the required test position will result in temporary changes in flow to the RCP seals and may induce additional thermal stresses. Due to the passive status related to this section of piping, opening CVC-310A may lead to uncontrolled reactivity additions when this volume of water is injected into the RCS. When restoring the plant to the desired configuration, CVC-310B must be reopened resulting in additional RCP seal perturbation before CVC-310A can be closed. Failure of the valve in the test position would require that the alternate pathway for boron injection remain in service and is not desired.

The valve is not designed to facilitate a part stroke exercise. Therefore, a partial stroke exercise test will not be performed since it may result in the same condition that would be encountered during the performance of a full stroke exercise test.

Cold Shutdown Test

Stroke time, full stroke exercise and fail safe test

ATTACHMENT 10.3
Page 7 of 26
COLD SHUTDOWN JUSTIFICATIONS
CVC-VCS-4

Valve ID	Description
CVC-387	EXCESS LETDOWN LINE STOP

Function

To isolate flow through the excess letdown heat exchanger

Deferred Testing

Quarterly stroke time, full stroke exercise and fail safe test

Cold Shutdown Test Justification

Testing of this valve while in MODEs 1, 2, 3, or 4 will result in the temporary reduction to the RCS pressure barrier to systems outside of containment. Valve failure in the open position would result in a more permanent adverse condition, and is not desired. Testing in any condition other than MODE 5 or MODE 6 would create unnecessary risks associated with testing a system that is only in service when normal letdown is not available. The valve is not designed to facilitate a part stroke exercise. Therefore, a partial stroke exercise test will not be performed since it may result in the same condition that would be encountered during the performance of a full stroke exercise test.

Cold Shutdown Test

Stroke time, full stroke exercise and fail safe test

ATTACHMENT 10.3
Page 8 of 26
COLD SHUTDOWN JUSTIFICATIONS
CVC-VCS-5

Valve ID	Description
CVC-200A	CVC LETDOWN ORIFICE ISOLATION
CVC-200B	CVC LETDOWN ORIFICE ISOLATION
CVC-200C	CVC LETDOWN ORIFICE ISOLATION

Function

Close on demand to provide containment isolation for letdown line

Deferred Testing

Quarterly stroke time, full stroke exercise and fail safe test

Cold Shutdown Test Justification

Operation of these valves during power operations will create temporary disturbances to the letdown flow control system, resulting in a potential challenge to letdown line relief valves, CVC-203A or CVC-203B, in the event of orifice isolation valve problems, switch mis-position events, or controller PCV-145 response errors. These events could lead to an inadvertent relief valve lift, and possible failure to re-close, resulting in an uncontrolled loss of primary coolant. In addition, cycling of these components could lead to temporary pressurizer level perturbations which may invalidate the transient analysis assumptions of UFSAR Chapter 15 as well as unnecessary changes to RCP seal injection flows. Although orifice isolation valve / relief valve discrepancies are not anticipated, the risk involved with exercising these valves is not warranted when performed with the sole purpose of satisfying IST requirements for normally scheduled on line surveillance activities. The valves are not designed to facilitate a part stroke exercise. Therefore, a partial stroke exercise test will not be performed since it may result in the same condition that would be encountered during the performance of a full stroke exercise test.

Cold Shutdown Test

Stroke time, full stroke exercise and fail safe test

ATTACHMENT 10.3
Page 9 of 26
COLD SHUTDOWN JUSTIFICATIONS
FW-VCS-1

Valve ID	Description
FCV-478	FEEDWATER REGULATING VALVE 'A'
FCV-479	FEEDWATER REGULATING BYPASS VALVE 'A'
FCV-488	FEEDWATER REGULATING VALVE 'B'
FCV-489	FEEDWATER REGULATING BYPASS VALVE 'B'
FCV-498	FEEDWATER REGULATING VALVE 'C'
FCV-499	FEEDWATER REGULATING BYPASS VALVE 'C'
FW-V2-6A	FEEDWATER HEADER SECTION VALVE 'A'
FW-V2-6B	FEEDWATER HEADER SECTION VALVE 'B'
FW-V2-6C	FEEDWATER HEADER SECTION VALVE 'C'

Function

Normal feed water supply to the Steam Generators

Deferred Testing

Quarterly stroke time, full stroke exercise and fail safe test (FCV-478 through FCV-499)
Quarterly stroke time and full stroke exercise (FW-V2-6A, FW-V2-6B, FW-V2-6C)

Cold Shutdown Test Justification

Exercising the Feed water Regulating or Feed water Header Section valves in MODE 1 will cause a loss of feed water and subsequent steam generator level transient which may result in a unit trip. Failure of these valves in the test position will result in a plant trip. The Feed water Regulating Bypass valves are normally in the required safety position at power, except during plant start up or shut down. Operation of the Bypass valves will induce temporary changes to the feed water flow rate and increase the risk of a plant transient or unit trip. Operation of these valves to complete testing is not consistent with the bases of Technical Specifications as stated in ITS SR 3.7.3.1. The valves are not designed to facilitate a part stroke exercise. Therefore, a partial stroke exercise test will not be performed since it may result in the same condition that would be encountered during the performance of a full stroke exercise test.

Cold Shutdown Test

Stroke time, full stroke exercise and fail safe test (FCV-478 through FCV-499)
Stroke time and full stroke exercise (FW-V2-6A, FW-V2-6B, FW-V2-6C)

ATTACHMENT 10.3
Page 10 of 26
COLD SHUTDOWN JUSTIFICATIONS
FW-VCS-2

Valve ID	Description
AFW-105	STEAM DRIVEN AUX FEEDWATER PUMP SUCTION VALVE FROM CONDENSATE STORAGE TANK

Function

Open to admit flow to the Steam Driven Auxiliary Feed water pump. Valve closure is required to maintain the vertical loop of piping water solid when pump operation is terminated.

Deferred Testing

Quarterly full stroke exercise open and closed.

Cold Shutdown Test Justification

A full flow exercise test of this valve may result in unwarranted cyclic stresses to the Auxiliary Feed water nozzles, induce SG level transients, require a power reduction, and may lead to a plant transient or unit trip. Performance of a forward flow test at a less frequent interval (e.g., cold shutdowns or reduced power proceeding to or transiting from shutdown) will not impose similar concerns and may be performed in conjunction with the associated comprehensive pump test, which is performed bi-ennially. Reverse flow testing requires that normally locked open valve AFW-4 be unlocked and closed for the duration of this test rendering the SDAFW Pump inoperable. The closure test requires the installation of a test gage, removal of pipe plugs, installation and flush of hoses and cross connection of systems. The net effect of these actions results in unwarranted safety system unavailability for a component that is the only immediate available emergency source of auxiliary feed water to mitigate a station blackout event. Reverse flow testing of the valve when the pump is not required to be Operable at cold Shut down conditions is appropriate.

Cold Shutdown Test

Full stroke exercise open and closed

ATTACHMENT 10.3
Page 11 of 26
COLD SHUTDOWN JUSTIFICATIONS
FW-VCS-3

Valve ID	Description
AFW-9A	STEAM DRIVEN AUX FEEDWATER PUMP RECIRC CHECK

Function

Close to prevent flow from the MDAFW Pumps, the S/G Blow down / Wet Layup Pumps, and / or the condensate hot well Letdown into the discharge of the SDAFW Pump via the recirculation line, as required. Open to provide a recirculation flow path for the SDAFW pump.

Deferred Testing

Quarterly full stroke exercise open and closed

Cold Shutdown Test Justification

Due to limitations in design, quarterly reverse flow testing of this component requires the SDAFW Pump to be taken out of service, installation of test hoses, and manipulation of manual valves. Reverse flow testing cannot be performed on-line using installed plant equipment because the presence of two flow orifices reduce MDAFW pump discharge flow and pressure to values which are inadequate to properly seat the valve. NUREG-1482, Section 4.1.4 states, "...The NRC has determined that the need to install test equipment is adequate justification to defer backflow testing until a refueling outage..." Although NUREG-1482 allows deferral of the reverse flow test to a refueling outage frequency, this test may be performed at a cold shutdown frequency for the convenience of scheduling with other auxiliary feed water tests that are normally performed during cold shutdown. Note: Although forward flow testing is performed at a nominal 92 day frequency, bi-directional test requirements cannot be met until both positions have been verified within the same interval.

Cold Shutdown Test

Full stroke exercise open and closed

ATTACHMENT 10.3
Page 12 of 26
COLD SHUTDOWN JUSTIFICATIONS
HVA-VCS-1

Valve ID	Description
V12-12	CONTAINMENT VACUUM RELIEF
V12-13	CONTAINMENT VACUUM RELIEF

Function

Open to relieve vacuum inside containment.

Deferred Testing

Quarterly stroke time, full stroke exercise and fail safe test

Cold Shutdown Test Justification

Exercising these valves during power operation would result in an unnecessary containment release since there is a positive pressure inside containment. The valves are not designed to facilitate a part stroke exercise. Therefore, a partial stroke exercise test will not be performed since it may result in the same condition that would be encountered during the performance of a full stroke exercise test.

Cold Shutdown Test

Stroke time, full stroke exercise and fail safe test

ATTACHMENT 10.3
Page 13 of 26
COLD SHUTDOWN JUSTIFICATIONS
HVA-VCS-2

Valve ID	Description
V12-6	CONTAINMENT PURGE SUPPLY
V12-7	CONTAINMENT PURGE SUPPLY
V12-8	CONTAINMENT PURGE EXHAUST
V12-9	CONTAINMENT PURGE EXHAUST

Function

Close to isolate the affected containment penetration.

Deferred Testing

Quarterly stroke time, full stroke exercise and fail safe test

Cold Shutdown Test Justification

These valves are normally closed to provide containment integrity. Therefore, the valves are already in the position required to mitigate the consequences of an accident. Opening of the affected component for the sole purpose of performing closure tests to satisfy quarterly testing requirements is not warranted as stated in Technical Specification Bases ITS SR 3.6.3.4. The valves are not designed to facilitate a part stroke exercise. Therefore, a partial stroke exercise test will not be performed since it may result in the same condition that would be encountered during the performance of a full stroke exercise test.

Cold Shutdown Test

Stroke time, full stroke exercise and fail safe test. ITS SR 3.6.3.4 requires these valves to be tested prior to use if not tested in the previous 92 days.

ATTACHMENT 10.3
Page 14 of 26
COLD SHUTDOWN JUSTIFICATIONS
MS-VCS-1

Valve ID	Description
IA-3744	INSTRUMENT AIR TO MAIN STEAM 'A' CHECK
IA-3743	INSTRUMENT AIR TO MAIN STEAM 'B' CHECK
IA-3742	INSTRUMENT AIR TO MAIN STEAM 'C' CHECK

Function

Contain air pressure within the MSIV accumulators

Deferred Testing

Quarterly full stroke exercise open and closed

Cold Shutdown Test Justification

Reverse exercising of these valves would require isolating and venting the associated instrument air supply header and stroking the MSIV since pressure indication is not provided for the accumulators. The MSIVs cannot be exercised in MODE 1 since closure would induce a steam flow / feed flow transient and result in a plant trip.

Cold Shutdown Test

Full stroke exercise open and closed

ATTACHMENT 10.3
Page 15 of 26
COLD SHUTDOWN JUSTIFICATIONS
MS-VCS-2

Valve ID	Description
MS-V1-3A	MAIN STEAM ISOLATION VALVE 'A'
MS-V1-3B	MAIN STEAM ISOLATION VALVE 'B'
MS-V1-3C	MAIN STEAM ISOLATION VALVE 'C'

Function

Close to limit the reactor coolant system cool down rate following a main steam line break

Deferred Testing

Quarterly stroke time, full stroke exercise and fail safe test

Cold Shutdown Test Justification

Closing these valves in MODE 1 will induce a Steam Generator steam flow / feed flow mismatch and result in a plant trip. A partial stroke exercise test will not be performed since it may lead to the same condition encountered during the performance of a full stroke exercise test if valve failure were to occur during the performance of the partial stroke exercise.

Cold Shutdown Test

Stroke time, full stroke exercise and fail safe test

ATTACHMENT 10.3
Page 16 of 26
COLD SHUTDOWN JUSTIFICATIONS
PAV-VCS-1

Valve ID	Description
V12-14	CONTAINMENT HYDROGEN EXHAUST 'A'
V12-15	H ₂ PURGE PCV 'A' INLET VALVE
V12-18	CONTAINMENT HYDROGEN EXHAUST 'B'
V12-19	H ₂ PURGE PCV 'B' INLET VALVE

Function

Close to provide containment isolation. Open to vent containment during post accident conditions

Deferred Testing

Quarterly stroke time, full stroke exercise and fail safe test

Cold Shutdown Test Justification

Exercising these valves during power operation would require defeating administrative controls put in place to prevent inadvertent operation of these components. The valves are normally closed to provide containment isolation for their respective penetrations. The components are re-positioned approximately 54 days following the onset of a DBA. In order to operate these valves, an administratively controlled key must be obtained in order to operate the control panel. In addition, cycling the inboard valves (V12-14, V12-18) requires that two locked closed manual valves in series must be opened which, effectively removes a separate containment penetration from service. The valves are not designed to facilitate a part stroke exercise. Therefore, a partial stroke exercise test will not be performed since it may result in the same condition that would be encountered during the performance of a full stroke exercise test.

Cold Shutdown Test

Stroke time, full stroke exercise and fail safe test

ATTACHMENT 10.3
Page 17 of 26
COLD SHUTDOWN JUSTIFICATIONS
RCS-VCS-1

Valve ID	Description
PCV-455C	PRESSURIZER POWER OPERATED RELIEF VALVE
PCV-456	PRESSURIZER POWER OPERATED RELIEF VALVE

Function

Open to provide overpressure protection when the RCS is at low temperature conditions

Deferred Testing

Quarterly stroke time, full stroke exercise and fail safe test

Cold Shutdown Test Justification

These valves are not needed for overpressure protection during power operation. The safety function of these valves is to protect the reactor vessel and the Reactor Coolant System from low temperature overpressure conditions. During power operations, the valves are closed to provide an RCS barrier. Operation of these valves quarterly will reduce the RCS barrier protection when opened and may lead to excessive RCS leakage if the upstream valve is mis-positioned or leaking by. The valves are not designed to facilitate a part stroke exercise. Therefore, a partial stroke exercise test will not be performed since it may result in the same condition that would be encountered during the performance of a full stroke exercise test.

Cold Shutdown Test

Stroke time, full stroke exercise and fail safe test

ATTACHMENT 10.3
Page 18 of 26
COLD SHUTDOWN JUSTIFICATIONS
RCS-VCS-2

Valve ID	Description
RC-567	REACTOR HEAD VENT SOLENOID ISOLATION
RC-568	REACTOR HEAD VENT SOLENOID ISOLATION
RC-569	REACTOR HEAD VENT SOLENOID ISOLATION
RC-570	PRESSURIZER VENT SOLENOID ISOLATION
RC-571	PRESSURIZER VENT SOLENOID ISOLATION
RC-572	CV ATMOSPHERE SOLENOID ISOLATION

Function

Opens to vent non-condensable gases from the RCS.

Deferred Testing

Quarterly stroke time, full stroke exercise and fail safe test

Cold Shutdown Test Justification

Technical Requirements Manual Specification (TRMS) 3.2 requires RC-567, RC-568, RC-569, and RC-570 be closed and power removed when above MODE 4. TRMS 3.2 requires RC-571 and RC-572 be closed unless needed to depressurize the RCS vent system in case of leakage past RC-567, RC-568, RC-569, or RC-570. During power operations, the valves are closed to provide an RCS barrier to the PRT or containment atmosphere. Opening these valves reduces RCS boundary integrity. The valves are not designed to facilitate a part stroke exercise. Therefore, a partial stroke exercise test will not be performed since it may result in the same condition that would be encountered during the performance of a full stroke exercise test.

Cold Shutdown Test

Stroke time, full stroke exercise and fail safe test

ATTACHMENT 10.3
Page 19 of 26
COLD SHUTDOWN JUSTIFICATIONS
SI-VCS-1

Valve ID	Description
SI-845A	SAT DISCHARGE
SI-845B	SAT DISCHARGE

Function

Open to admit sodium hydroxide injection during containment spray system actuation

Deferred Testing

Quarterly stroke time and full stroke exercise

Cold Shutdown Test Justification

Exercising these valves during power operation would introduce sodium hydroxide into the safety injection system resulting in unacceptable water chemistry. The closing of other valves in the system to allow quarterly cycling of SI-845A and SI-845B would isolate all Sodium Hydroxide injection flow paths. Therefore, a partial stroke exercise test will not be performed since it may result in the same condition that would be encountered during the performance of a full stroke exercise test.

Cold Shutdown Test

Stroke time and full stroke exercise

ATTACHMENT 10.3
Page 20 of 26
COLD SHUTDOWN JUSTIFICATIONS
SI-VCS-2

Valve ID	Description
SI-862A	RHR LOOP RWST ISOLATION
SI-862B	RHR LOOP RWST ISOLATION
SI-864A	RWST DISCHARGE
SI-864B	RWST DISCHARGE

Function

Open to allow suction from the RWST to the RHR pumps. Close to provide post-accident long-term recirculation cooling capability.

Deferred Testing

Quarterly stroke time and full stroke exercise

Cold Shutdown Test Justification

Exercising these valves during power operation would result in losing suction from the RWST to both trains of residual heat removal system. The failure of one valve in the non-conservative direction would result in a total loss of system function. In addition, ITS SR 3.5.2.1 requires AC control power be removed from these valves in MODES 1, 2, and 3. The valves are not designed to facilitate a part stroke exercise. Therefore, a partial stroke exercise test will not be performed since it may result in the same condition that would be encountered during the performance of a full stroke exercise test.

Cold Shutdown Test

Stroke time and full stroke exercise

ATTACHMENT 10.3
Page 21 of 26
COLD SHUTDOWN JUSTIFICATIONS
SI-VCS-3

Valve ID	Description
SI-863A	RHR LOOP RECIRC
SI-863B	RHR LOOP RECIRC
SI-865A	SI ACCUMULATOR 'A' DISCHARGE
SI-865B	SI ACCUMULATOR 'B' DISCHARGE
SI-865C	SI ACCUMULATOR 'C' DISCHARGE
SI-866A	LOOP 'C' HOT LEG INJECTION ISOLATION
SI-866B	LOOP 'B' HOT LEG INJECTION ISOLATION
SI-878A	SI PUMP DISCHARGE HEADER CROSS-CONNECT ISOLATION
SI-878B	SI PUMP DISCHARGE HEADER CROSS-CONNECT ISOLATION

Function

Safety Injection Isolation Valves

Deferred Testing

Quarterly stroke time and full stroke exercise

Cold Shutdown Test Justification

ITS SR 3.5.1.5 for SI-865A, B, and C and ITS SR 3.5.2.1 for the remainder of applicable valves requires that AC control power be removed from these valves when in MODE 1, 2, or 3 with pressurizer pressure > 1000 psig (SI-865A, B, and C) or when in MODE 1, 2, or 3 (SI-863A and B, SI-866A and B, and SI-878A and B). The valves are not designed to facilitate a part stroke exercise. Therefore, a partial stroke exercise test will not be performed since it may result in the same condition that would be encountered during the performance of a full stroke exercise test.

Cold Shutdown Test

Stroke time and full stroke exercise

ATTACHMENT 10.3
Page 22 of 26
COLD SHUTDOWN JUSTIFICATIONS
SI-VCS-4

Valve ID	Description
SI-889A	CV SPRAY EDUCTOR FEED CHECK
SI-889B	CV SPRAY EDUCTOR FEED CHECK

Function

Open to admit sodium hydroxide injection during Containment Spray system actuation. Closes to prevent flow from the Containment Spray Pump minimum flow line from entering the Spray Additive Tank

Deferred Testing

Quarterly full stroke exercise open and closed

Cold Shutdown Test Justification

Reverse flow exercising these valves during power operation would render the entire Spray Additive System inoperable. Forward flow exercising of these valves requires isolation of the Spray Additive Tank in order to perform a line flush if the desired chemistry requirements are not met, as well as imposing additional risk associated with contamination of the RWST with NaOH. The sample and flush alignment renders the Spray Additive System inoperable, and would require manual operator action involving multiple valve operations to restore this essential feature. Forward flow testing of either component renders the Spray Additive System inoperable once SI-892D (manual eductor test line isolation) is opened to facilitate the flow path necessary to open these valves. Additional test equipment set - up is required to complete the test.

Cold Shutdown Test

Full stroke exercise open and closed

ATTACHMENT 10.3
Page 23 of 26
COLD SHUTDOWN JUSTIFICATIONS
SI-VCS-5

Valve ID	Description
SI-856A	SI PUMP RECIRC
SI-856B	SI PUMP RECIRC

Function

Open to provide a mini-flow path back to RWST. Close during the transition from the injection mode of SIS operation to the recirculation mode of operation to prevent the discharge of containment sump water to the RWST and the potential release of activity through the RWST vent line when the SI Pumps are used during the recirculation mode.

Deferred Testing

Quarterly stroke time, full stroke exercise and fail safe test

Cold Shutdown Test Justification

Exercising these valves during power operations with the SI Pumps racked in creates the potential for a pump start and run without a minimum flow path available. This condition increases the potential for possible pump damage and safety system unavailability. Failure in a non-conservative direction will result in total loss of system function. The valves are not designed to facilitate a part stroke exercise. Therefore, a partial stroke exercise test will not be performed since it may result in the same condition that would be encountered during the performance of a full stroke exercise test.

Cold Shutdown Test

Stroke time, full stroke exercise and fail safe test

ATTACHMENT 10.3
Page 24 of 26
COLD SHUTDOWN JUSTIFICATIONS
SI-VCS-6

Valve ID	Description
SI-851A	SI ACCUMULATOR 'A' MAKE-UP VALVE ACCUMULATOR LIQUID FILL LINE ISOLATION
SI-851B	SI ACCUMULATOR 'B' MAKE-UP VALVE ACCUMULATOR LIQUID FILL LINE ISOLATION
SI-851C	SI ACCUMULATOR 'C' MAKE-UP VALVE ACCUMULATOR LIQUID FILL LINE ISOLATION

Function

Closed to prevent the diversion of Safety Injection flow during hot leg injection

Deferred Testing

Quarterly stroke time, full stroke exercise and fail safe test

Cold Shutdown Test Justification

Exercising these valves while at power creates the potential for valve failure in the non-conservative direction, which would cause a loss of system function during a large break loss of coolant accident as a result of the diversion of flow from the core to the affected Safety Injection accumulator. The valves are not designed to facilitate a partial stroke exercise. Therefore, a partial stroke exercise test will not be performed since it may result in the same condition that would be encountered during the performance of a full stroke exercise test.

Cold Shutdown Test

Stroke time, full stroke exercise and fail safe test

ATTACHMENT 10.3
Page 25 of 26
COLD SHUTDOWN JUSTIFICATIONS
SI-VCS-7

Valve ID	Description
SI-861A	CV SUMP RECIRC SUCTION
SI-861B	CV SUMP RECIRC SUCTION

Function

Open to provide flow path for recirculation phase of RHR. SI-861A closes to provide containment isolation capability for containment penetration P-46 and SI-861B closes to provide containment isolation capability for containment penetration P-47

Deferred Testing

Quarterly stroke time and full stroke exercise

Cold Shutdown Test Justification

Routine cycling of these valves results in fluid being directed to the ECCS sump. When the sump level is above the watertight construction joints, water may flow into the construction joints through cracks or possibly degraded areas that have lost seal integrity. The borated water then flows along the joint at the bottom of the crane wall until other possibly degraded areas of the joint are encountered. At these locations, the borated water flows out onto the floor in the annulus area and follows the path of least resistance to the lowest point of gravity. The typical flow path from the joint at the bottom of the crane wall is along floor construction joints, which originate at the bottom of the crane wall and terminate at the outer CV wall.

Cold Shutdown Test

Stroke time and full stroke exercise

ATTACHMENT 10.3
Page 26 of 26
COLD SHUTDOWN JUSTIFICATIONS
SW-VCS-1

Valve ID	Description
V6-16C	SERVICE WATER ISOLATION TO TURBINE BUILDING

Function

Close to isolate service water header from turbine building

Deferred Testing

Quarterly stroke time and full stroke exercise

Cold Shutdown Test Justification

Exercising this valve during power operation would temporarily isolate service water to all components in the turbine building and may result in damage to major plant equipment and a plant trip. Valve failure in the test position would require a plant shutdown or trip and may result in damage to plant equipment. The valve is not designed to facilitate a part stroke exercise. Therefore, a partial stroke exercise test will not be performed since it may result in the same condition that would be encountered during the performance of a full stroke exercise test.

Cold Shutdown Test

Stroke time and full stroke exercise

ATTACHMENT 10.4
Page 1 of 10
REFUELING SHUTDOWN JUSTIFICATIONS
CC-VRS-1

Valve ID	Description
CC-731	REACTOR COOLANT PUMP BEARING COOLING WATER OUTLET CHECK

Function

Close to prevent emptying the cooling water surge tank upon accident, coincident with failure of upstream containment isolation valve CC-730 to close automatically on phase 'B' containment isolation signal

Deferred Testing

Quarterly and cold shutdown full stroke exercise open and closed

Refueling Shutdown Test Justification

Reverse flow testing of this valve is impractical at power or during cold shutdown. The valve is located in the return flow path from the reactor coolant pumps motor bearing coolers. The inspection cannot be performed unless this section of piping is depressurized and drained. CCW is not isolated to the RCPs unless maintenance is required and is normally conducted during refueling outages. The disassembly of this valve is performed in conjunction with Appendix J local leak rate testing in order to provide a required vent path for testing. The coordination of these two activities minimizes radiation dose and maximizes equipment availability and personnel efficiency. The disassembly of this check valve at a refueling interval is consistent with the requirements of ISTC 4.5.4(c)(3).

Refueling Shutdown Test

Disassembly and examination to verify valve obturator movement to the open and closed positions (full stroke exercise).

ATTACHMENT 10.4
Page 2 of 10
REFUELING SHUTDOWN JUSTIFICATIONS
CVC-VRS-1

Valve ID	Description
CVC-266	VCT TO CHRГ PMPS SUCT HDR CHK VLV
LCV-115C	VOLUME CONTROL TANK OUTLET

Function

LCV-115C is a normally open MOV which directs flow from the volume control tank (VCT) to the CVCS charging pump suction and automatically isolates the VCT on a low level signal. CVC-266 is a check valve that is normally open to provide a flow path from the VCT to the charging pumps suction. This component is required to close in the event that it becomes necessary to establish an alternate source from the refueling water storage tank (RWST) or boric acid transfer pumps to the charging pumps suction. Closure of this component prevents backflow into the VCT to ensure that the flow of boric acid is properly directed to the charging pumps

Deferred Testing

CVC-266 - Quarterly and cold shutdown full stroke exercise open and closed

LCV-115C - Quarterly and cold shutdown stroke time and full stroke exercise

Refueling Shutdown Test Justification

Exercising LCV-115C and reverse flow testing of CVC-266 would interrupt the normal flow path from the VCT to the suction of the charging pumps. A suction supply to the charging pumps is required to maintain an adequate pressurizer level and the required RCP seal injection flow. In order to perform this test, the charging pump suction would be redirected to the refueling water storage tank (RWST). The high boron concentration in the RWST would require a reduction in power to maintain core parameters within programmed bands and would deplete the available RWST inventory required for accident mitigation. Failure of either valve in the test position would result in a complete loss of the normal flow path and would result in a unit shutdown. LCV-115C is not designed to facilitate a part stroke exercise. Therefore, a partial stroke exercise test will not be performed since it may result in the same condition that would be encountered during the performance of a full stroke exercise test. The conduct of either test at cold shutdown intervals may challenge the proper seating and operation of the Reactor Coolant Pump (RCP) seals and should be performed in a refueling outage when a similar challenge to the RCP seals can be avoided.

Refueling Shutdown Test

CVC-266 - Full stroke exercise open and closed

LCV-115C - Stroke time and full stroke exercise

ATTACHMENT 10.4
Page 3 of 10
REFUELING SHUTDOWN JUSTIFICATIONS
CVC-VRS-2

Valve ID	Description
CVC-351	BORIC ACID TO CHARGING PUMP SUCTION ISOLATION CHECK
CVC-357	RWST TO CHARGING PUMPS SUCTION CHECK

Function

The function of CVC-351 is to open and allow flow from the Boric Acid Pumps for emergency boration. CVC-357 opens to allow flow from the RWST for emergency boration.

Deferred Testing

Quarterly and cold shutdown full stroke exercise open and closed

Refueling Shutdown Test Justification

Exercising these valves during power operation will cause undesirable RCS temperature and/or boron concentration changes which may result in an uncontrolled reactivity excursion, plant transient or trip. Operating a charging pump at full flow during cold shutdown with the reactor vessel head in place could result in a low temperature over pressurization of the RCS. For CVC-351, a flow rate of 60 gpm would be required to satisfy the full stroke open position verification. For CVC-357, a flow rate of 138 gpm would be required to satisfy the full stroke open position verification. The valves are not credited for closure to mitigate a design basis accident; however, are tested for this attribute to satisfy check valve bi-directional testing requirements. The reverse flow test of CVC-351 requires that all charging pumps, boric acid pumps and primary water pumps to be secured and all suction paths on the suction side of the charging pumps to be isolated. This results in a loss of seal injection to the RCPs and a loss of make-up capability that would be necessary to maintain an adequate level in the pressurizer. The reverse flow test of CVC-357 requires that LCV-115B, EMERGENCY MAKEUP TO CHARGING PUMP SUCTION CONTROL valve be opened a sufficient period of time to facilitate a proper assessment of closure. This action would result in excessive boration of the RCS.

Refueling Shutdown Test

Full stroke exercise open and closed

ATTACHMENT 10.4
Page 4 of 10
REFUELING SHUTDOWN JUSTIFICATIONS
FW-VRS-1

Valve ID	Description
FW-8A	STEAM GENERATOR 'A' INLET STOP CHECK
FW-8B	STEAM GENERATOR 'B' INLET STOP CHECK
FW-8C	STEAM GENERATOR 'C' INLET STOP CHECK

Function

Close to isolate the main feedwater system, as required.

Deferred Testing

Quarterly and cold shutdown full stroke exercise open and closed

Refueling Shutdown Test Justification

These valves are normally open at power. The check valves cannot be exercised closed during power operation without isolating the main feedwater flow to the Steam Generators, which would result in a plant trip. Reverse flow testing during cold shutdown is impractical. In order to perform the test, the steam generators must be filled, main feedwater system must be re-aligned and portions of the system opened and depressurized. Arranging for special processes would be impractical during cold shutdowns based on the complexity of the test and large size of the valves. Although these valves are open as demonstrated by routine power operations, bi-directional testing of check valves cannot be considered complete until both safety positions have been verified. Both tests must be performed within the same interval.

Refueling Shutdown Test

Full stroke exercise open and closed

ATTACHMENT 10.4
Page 5 of 10
REFUELING SHUTDOWN JUSTIFICATIONS
IA-VRS-1

Valve ID	Description
IA-525	AIR DRYER TO INSTRUMENT AIR LOOP CHECK VALVE ISOLATION
PCV-1716	INSTRUMENT AIR ISOLATION TO CV

Function

Close to provide containment isolation per 10CFR50, Appendix J.

Deferred Testing

IA-525 - Quarterly and cold shutdown full stroke exercise open and closed
PCV-1716 - Quarterly and cold shutdown stroke time, full stroke exercise and fail safe test

Refueling Shutdown Test Justification:

These valves are normally open to provide instrument air to components located in containment. Exercising these valves during power operation or cold shutdown would isolate instrument air from components inside containment which could result in a plant trip or reduce the level of safety in order to maintain stable plant operation. The valves are tested closed via seat leakage measurement to meet the requirements of 10 CFR 50, Appendix J. Additionally, IA-525 must be proven to close and open in order to fulfill the bi-directional test requirements of the Code. These tests must be performed within the same interval. The leak rate test for this valve is performed at a refueling interval; therefore, the bi-directional test requirement of the Code for testing within the same interval is more appropriate at a refueling interval. Additional tests to verify closure for IA-525 quarterly or at cold shutdown intervals would involve tests that are considered to be impractical since it would involve complex test lineups or non intrusive measures. PCV-1716 is not designed to facilitate a part stroke exercise. Therefore, a partial stroke exercise test will not be performed since it may result in the same condition that would be encountered during the performance of a full stroke exercise test.

Refueling Shutdown Test

IA-525 - Full stroke exercise open and closed
PCV-1716 - Stroke time, full stroke exercise and fail safe test

ATTACHMENT 10.4
Page 6 of 10
REFUELING SHUTDOWN JUSTIFICATIONS
RHR-VRS-1

Valve ID	Description
RHR-750	LOOP 'B' HOT LEG TO RHR SYSTEM
RHR-751	LOOP 'B' HOT LEG TO RHR SYSTEM

Function

RHR shutdown cooling suction line from RCS loop "B" hot leg to the RHR pumps suction and reactor coolant pressure boundary isolation.

Deferred Testing

Quarterly and cold shutdown full stroke exercise and stroke time

Refueling Shutdown Test Justification

These valves cannot be stroked quarterly because they are interlocked to prevent operation when Reactor Coolant System pressure is greater than 474 psig. RCS pressure during plant operation is approximately 2235 psig; therefore, these valves cannot be exercised unless interlocks are defeated. Control power is removed from RHR-751 prior to entering MODE 3 to provide increased assurance related to RCS barrier integrity. Operation of either valve with fuel in the vessel will remove the entire RHR system from service when the system is required for operation and failure of either one of these valve to re-open would cause a loss of shutdown cooling and is not desired. The valves are not designed to facilitate a part stroke exercise. Therefore, a partial stroke exercise test will not be performed since it may result in the same condition that would be encountered during the performance of a full stroke exercise test. The valves will be tested in refueling conditions when RHR cooling is not required.

Refueling Shutdown Test

Full stroke exercise and stroke time

ATTACHMENT 10.4
Page 7 of 10
REFUELING SHUTDOWN JUSTIFICATIONS
SI-VRS-1

Valve ID	Description
SI-909	SI ACCUMULATORS N ₂ SUPPLY CHECK

Function

Closes to prevent a backflow of Nitrogen from the SI Accumulators and provides isolation of the associated containment penetration per 10CFR50, Appendix J.

Deferred Testing

Quarterly and cold shutdown full stroke exercise open and closed

Refueling Shutdown Test Justification

Testing of this valve would require the isolation of the nitrogen supply to the Safety Injection Accumulators. This would represent a challenge to safety equipment to perform its intended function. Although this valve is an active component, it is normally closed and opened only when it is necessary to re-pressurize the SI accumulators. The valve is tested closed via seat leakage measurement to meet the requirements of 10 CFR 50, Appendix J. Additionally, the valve must be proven to close and open in order to fulfill the bi-directional test requirements of the Code. These tests must be performed within the same interval. The use of radiography to verify closure requires the use of outside services in order to complete the task. Due to the expense and limitations associated with performance of this examination, it is not warranted at a quarterly interval. In addition, system realignment to perform inservice testing or radiography is not warranted at a cold shutdown interval when a more definitive test can be performed at a refueling interval. Forward flow testing of the valve is normally completed in refueling outages when preparing to restore the SI accumulators to standby service. The leak rate test for this valve is performed at a refueling interval; therefore, the bi-directional test requirement of the Code for testing within the same interval is more appropriate at a refueling interval

Refueling Shutdown Test

Full stroke exercise open and closed

ATTACHMENT 10.4
Page 8 of 10
REFUELING SHUTDOWN JUSTIFICATIONS
SI-VRS-2

Valve ID	Description
SI-879A	SI PUMP 'A' DISCHARGE CHECK
SI-879B	SI PUMP 'B' DISCHARGE CHECK
SI-879C	SI PUMP 'C' DISCHARGE CHECK

Function

Open to permit full flow from the respective Safety Injection pump to the cold leg or hot leg injection pathways. Close to prevent the diversion of flow through an idle pump.

Deferred Testing

Quarterly and cold shutdown full stroke exercise open and closed

Refueling Shutdown Test Justification

Quarterly testing (forward flow) is not practical since the RCS pressure exceeds the discharge pressure of the Safety Injection pumps. Full flow testing at cold shutdown conditions is not practical due to the increased probability of a low temperature over pressurization event; therefore, testing at a refueling interval with the reactor vessel head removed is appropriate. Although reverse flow testing is performed at a quarterly test interval, check valve bi-directional test requirements cannot be considered completed until both positions have been verified within the same interval.

Refueling Shutdown Test

Full stroke exercise open and closed

ATTACHMENT 10.4
Page 9 of 10
REFUELING SHUTDOWN JUSTIFICATIONS.
SI-VRS-3

Valve ID Description

SI-873A	BORON INJECTION TO RCS CHECK
SI-873D	BORON INJECTION TO RCS CHECK
SI-873E	BORON INJECTION TO RCS CHECK
SI-873F	BORON INJECTION TO RCS CHECK

Function

Close to provide isolation of high pressure RCS from a lower pressure rated safety injection system.

Deferred Testing

Quarterly and cold shutdown full stroke exercise open and closed

Refueling Shutdown Test Justification

Forward flow testing of these valves can only be performed by injecting water into the RCS utilizing the RWST as the supply source. The SI pumps discharge pressure cannot overcome normal RCS system pressure; therefore, the forward flow testing cannot be performed unless the reactor coolant system is depressurized and vented. Injecting with the RCS depressurized and not vented may result in a low temperature over pressurization of the RCS due to the small expansion volume. For this reason, the full flow test is conducted when filling or draining the refueling canal in conjunction with refueling outages.

Reverse flow testing of these valves requires the cold leg injection flow paths to be isolated one at a time. In addition to reducing safety system availability, the closure test requires that manual valves inside the Class 1 and 2 pressure boundaries be opened in order to provide a flow path for any seat leakage. This is an undesirable practice since the RCS pressure boundary is normally maintained by closed valves or valves capable of automatic closure. This evolution requires entry into containment and into Locked High Radiation Areas, increasing personnel exposure and the potential for personnel contamination. The activity is scheduled during critical plant evolutions based on the conditions necessary to facilitate testing. Portable testing equipment (pumps, hoses, fittings, containers, etc.) is required. Staging and installation of portable test equipment (hoses, fittings, gages, containers, etc.) inside containment to perform this test increases the probability for incidents to occur due to activities performed on hot, pressurized systems.

Check valve tests must be performed by verifying the open and closed positions. The tests are to be performed at an interval when it is practicable to perform both tests. These components are required to be leak rate tested IAW ITS SR 3.4.14.1 at cold shutdowns of greater than 48 hours in duration, provided the test has not been completed in the previous 9 months (276 days). The leak test satisfies the requirement for closure verification. The forward flow test is performed at a refueling interval. The combination of these two activities satisfies the OM Code requirement for bi-directional testing and the interval extension to refueling is warranted.

ATTACHMENT 10.4
Page 10 of 10
REFUELING SHUTDOWN JUSTIFICATIONS

Refueling Shutdown Test

Full flow exercise at refueling intervals and reverse flow verification via seat leakage testing at cold shutdown intervals - greater than 48 hours in duration and prior to entering MODE 2 whenever the unit has been in MODE 5 for 7 days or more, if leakage testing has not been performed in the previous 9 months and within 24 hours following valve actuation due to automatic or manual action or flow through the valve.

ATTACHMENT 10.5

Page 1 of 2

PUMP TABLE

Pump	P&ID (SHT)	Coord	Group	Type	Speed	Test Type	Test Freq	OST	Notes
AFW-PMP-A	G-190197 (4)	C-3	B	C-H	Fixed	Comp. – Q, dP, V	Bi	207	
						Group B – Q, Dp	Q	201-1	
AFW-PMP-B	G-190197 (4)	A-3	B	C-H	Fixed	Comp. – Q, dP, V	Bi	207	
						Group B – Q, Dp	Q	201-2	
SDAFW-PMP	G-190197 (4)	D-2	B	C-H	Variable	Comp. – N, Q, dP, V	Bi	206	
						Group B – N, Q, Dp	Q	202	
BA-XFER-PMP-A	5379-685 (3)	B-6	A	C-H	Fixed	Comp. – Q, dP, V	Bi	108-3	IST-RR-1
						Group A – Q, Dp, V	Q	108-1	
BA-XFER-PMP-B	5379-685 (3)	B-5	A	C-H	Fixed	Comp. – Q, dP, V	Bi	108-4	IST-RR-1
						Group A – Q, Dp, V	Q	108-2	
CCW-PMP-A	5379-376 (1)	D-7	A	C-H	Fixed	Comp. – Q, dP, V	Bi	908-1	IST-RR-1 IST-RR-2
						Group A – Q, Dp, V	Q	908	
CCW-PMP-B	5379-376 (1)	C-7	A	C-H	Fixed	Comp. – Q, dP, V	Bi	908-1	IST-RR-1 IST-RR-2
						Group A – Q, Dp, V	Q	908	
CCW-PMP-C	5379-376 (1)	A-7	A	C-H	Fixed	Comp. – Q, dP, V	Bi	908-1	IST-RR-1 IST-RR-2
						Group A – Q, Dp, V	Q	908	
CV-SPRAY-PMP-A	5379-1082 (3)	C-3	B	C-H	Fixed	Comp. – Q, dP, V	Bi	352-3	
						Group B – Q, Dp	Q	352-1	
CV-SPRAY-PMP-B	5379-1082 (3)	E-3	B	C-H	Fixed	Comp. – Q, dP, V	Bi	352-4	
						Group B – Q, Dp	Q	352-2	
CHG-PMP-A	5379-685 (2)	B-7	A	PD-R	Variable	Comp. – N, Q, P, V	Bi	101-6	IST-RR-1
						Group A – N, Q, P, V	Q	101-1	
CHG-PMP-B	5379-685 (2)	C-7	A	PD-R	Variable	Comp. – N, Q, P, V	Bi	101-7	IST-RR-1
						Group A – N, Q, P, V	Q	101-2	
CHG-PMP-C	5379-685 (2)	C-7	A	PD-R	Variable	Comp. – N, Q, P, V	Bi	101-8	IST-RR-1
						Group A – N, Q, P, V	Q	101-3	

ATTACHMENT 10.5

Page 2 of 2

PUMP TABLE

Pump	P&ID (SHT)	Coord	Group	Type	Speed	Test Type	Test Freq	OST	Notes
FO-XFER-PMP-A	G-190204D (2)	D-7	A	PD	Fixed	Aug. – Q, P, V	Q	402-1	Augmented
FO-XFER-PMP-B	G-190204D (2)	D-8	A	PD	Fixed	Aug. – Q, P, V	Q	402-2	Augmented
RHR-PMP-A	5379-1484 (1)	D-4	A	C-V	Fixed	Comp. – Q, dP, V	Bi	253	
						Group A – Q, Dp, V	Q	251-1	
RHR-PMP-B	5379-1484 (1)	F-4	A	C-V	Fixed	Comp. – Q, dP, V	Bi	253	
						Group A – Q, Dp, V	Q	251-2	
SI-PMP-A	5379-1082 (2)	C-6	B	C-H	Fixed	Comp. – Q, dP, V	Bi	151-4	IST-RR-2
						Group B – Q, Dp	Q	151-1	
SI-PMP-B	5379-1082 (2)	E-6	B	C-H	Fixed	Comp. – Q, dP, V	Bi	151-5	Normally OOS IST-RR-2
						Group B – Q, Dp	Q	151-2	
SI-PMP-C	5379-1082 (2)	F-6	B	C-H	Fixed	Comp. – Q, dP, V	Bi	151-6	IST-RR-2
						Group B – Q, Dp	Q	151-3	
SW-PMP-A	G-190199 (2)	B-7	A	VLS	Fixed	Comp. – Q, dP, V	Bi	302-3	IST-RR-1 IST-RR-2
						Group A – Q, Dp, V	Q	302-1	
SW-PMP-B	G-190199 (2)	B-7	A	VLS	Fixed	Comp. – Q, dP, V	Bi	302-3	IST-RR-1 IST-RR-2
						Group A – Q, Dp, V	Q	302-1	
SW-PMP-C	G-190199 (2)	B-6	A	VLS	Fixed	Comp. – Q, dP, V	Bi	302-4	IST-RR-1
						Group A – Q, Dp, V	Q	302-2	
SW-PMP-D	G-190199 (2)	B-6	A	VLS	Fixed	Comp. – Q, dP, V	Bi	302-4	IST-RR-1
						Group A – Q, Dp, V	Q	302-2	
SWBP-A	G-190199 (7)	E-6	A	C-H	Fixed	Comp. – Q, dP, V	Bi	303-3	IST-RR-1
						Group A – Q, Dp, V	Q	303-1	
SWBP-B	G-190199 (7)	F-6	A	C-H	Fixed	Comp. – Q, dP, V	Bi	303-4	IST-RR-1
						Group A – Q, Dp, V	Q	303-2	

Attachment 10.6
Page 1 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos.	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
A TURBO CHARGER INLET	G-190204A (1) AUG Skid mounted	C-6	C	Act	20	CK	SA	N	C	O/C	NA	N	N	FF	Q		OST-401-1 OST-409-1 OST-410 OST-401-1 OST-409-1 OST-410
AFW-1	G-190197 (1)	B-7	B	Act	6	GA	M	N	LO	O/C	N/A	N	N	FS	Bi		OST-702-3
AFW-104	G-190197 (1)	B-7	B	Act	6	GA	M	N	LO	O/C	N/A	N	N	FS	Bi		OST-702-3
AFW-105	G-190197 (4)	C-3	C	Act	6	CK	SA	N	C	O/C	N/A	N	N	FF	CS	FW-VCS-2	CM-134 OST-206 PM-302
														RF	CS	FW-VCS-2	CM-134 OST-702-3 PM-302
AFW-13	G-190197 (4)	D-2	C	Act	1	RV	SA	N	C	O	N/A	N	N	RL	App. I		EST-112
AFW-24	G-190197 (4)	B-2	B	Act	6	GA	M	N	LC	O	N/A	N	N	FS	Bi		OST-701-6
AFW-24A	G-190197 (4) AUG	B-2	B	Act	1	GL	M	N	O	C	N/A	N	N	FS AUG	Bi		OST-701-6

Attachment 10.6
Page 2 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
AFW-32	G-190197 (4)	C-3	C	Act	1	RV	SA	N	C	O	N/A	N	N	RL	App. I		EST-112
AFW-33	G-190197 (4)	B-3	C	Act	1	RV	SA	N	C	O	N/A	N	N	RL	App. I		EST-112
AFW-40	G-190197 (4)	C-4	C	Act	4	CK	SA	N	C	O/C	N/A	N	N	RF	App. II		CM-140 OST-202 OST-207 PM-307
														FF	App. II		CM-140 OST-207 PM-307
AFW-41	G-190197 (4)	B-4	C	Act	4	CK	SA	N	C	O/C	N/A	N	N	RF	App. II		CM-140 OST-202 OST-207 PM-307
														FF	App. II		CM-140 OST-207 PM-307
AFW-68	G-190197 (4)	B-6	C	Act	4	CK	SA	N	C	O/C	N/A	N	N	FF	App. II		CM-140 OST-207 PM-307
														RF	App. II		CM-140 OST-201-1 OST-207 PM-307

Attachment 10.6
Page 3 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
AFW-69	G-190197 (4)	C-6	C	Act	4	CK	SA	N	C	O/C	N/A	N	N	FF	App. II		CM-140 OST-207 PM-307
														RF	App. II		CM-140 OST-201-1 OST-207 PM-307
AFW-70	G-190197 (4)	B-6	C	Act	4	CK	SA	N	C	O/C	N/A	N	N	FF	App. II		CM-140 OST-207 PM-307
														RF	App. II		CM-140 OST-201-1 OST-207 PM-307
AFW-79	G-190197 (4)	D-2	C	Act	1	RV	SA	N	C	O	N/A	N	N	RL	App. I		EST-112
AFW-8	G-190197 (4)	D-2	C	Act	1	RV	SA	N	C	O	N/A	N	N	RL	App. I		EST-112
AFW-84	G-190197 (4)	D-4	C	Act	6	CK	SA	N	C	O/C	N/A	N	N	FF	App. II		OST-206 PM-307
														RF	App. II		OST-202 OST-206 PM-307
AFW-9	G-190197 (4)	C-2	C	Act	2	CK	SA	N	C	C	N/A	N	N	OV	App. II		CM-139 PM-304
														RF	App. II		CM-139 OST-202 OST-206 PM-304

Attachment 10.6
Page 4 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
AFW-9A	G-190197 (4)	D-4	C	Act	2	CK	SA	N	C	O/C	N/A	N	N	RF	CS	FW-VCS-3	CM-149 OST-201-1 OST-702-3 PM-320
														FF	CS	FW-VCS-3	CM-149 OST-202 OST-206 PM-320
AFW-V2-14A	G-190197 (4) GL 89-10, GL 96-05	G-4	B	Act	4	GA	MO	N	C	O/C	AI	N	Y	FS	Q		OST-202 OST-206
														TM (O)	Q		OST-202 OST-206
														TM (C)	Q		OST-202 OST-206
														PI	Bi		OST-206
AFW-V2-14B	G-190197 (4) GL 89-10, GL 96-05	F-4	B	Act	4	GA	MO	N	C	O/C	AI	N	Y	FS	Q		OST-202 OST-206
														TM (O)	Q		OST-202 OST-206
														TM (C)	Q		OST-202 OST-206
														PI	Bi		OST-206
AFW-V2-14C	G-190197 (4) GL 89-10, GL 96-05	E-4	B	Act	4	GA	MO	N	C	O/C	AI	N	Y	FS	Q		OST-202 OST-206
														TM (O)	Q		OST-202 OST-206
														TM (C)	Q		OST-202 OST-206
														PI	Bi		OST-206

Attachment 10.6
Page 5 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
AFW-V2-16A	G-190197 (4)	B-5	B	Act	4	GA	MO	N	C	O/C	AI	N	Y	FS	Q		OST-201-1 OST-207
	GL 89-10, GL 96-05													TM (O)	Q		OST-201-1 OST-207
														TM (C)	Q		OST-201-1 OST-207
														PI	Bi		OST-207
AFW-V2-16B	G-190197 (4)	C-5	B	Act	4	GA	MO	N	C	O/C	AI	N	Y	FS	Q		OST-201-1 OST-207
	GL 89-10, GL 96-05													TM (O)	Q		OST-201-1 OST-207
														TM (C)	Q		OST-201-1 OST-207
														PI	Bi		OST-207
AFW-V2-16C	G-190197 (4)	B-5	B	Act	4	GA	MO	N	C	O/C	AI	N	Y	FS	Q		OST-201-1 OST-207
	GL 89-10, GL 96-05													TM (O)	Q		OST-201-1 OST-207
														TM (C)	Q		OST-201-1 OST-207
														PI	Bi		OST-207
AFW-V2-20A	G-190197 (4)	C-5	B	Act	4	GA	MO	N	O	C	AI	N	Y	FS	Q		OST-201-1 OST-207
	Full stroke exercise and stroke time measurement are augmented tests													TM (C)	Q		OST-201-1 OST-207
														PI	Bi		OST-207
AFW-V2-20B	G-190197 (4)	B-5	B	Act	4	GA	MO	N	O	C	AI	N	Y	FS	Q		OST-201-1 OST-207
	Full stroke exercise and stroke time measurement are augmented tests													TM (C)	Q		OST-201-1 OST-207
														PI	Bi		OST-207

Attachment 10.6

Page 6 of 97

Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
B TURBO CHARGER INLET	G-190204A (1) AUG Skid mounted	F-6	C	Act	20	CK	SA	N	C	O/C	N/A	N	N	FF	Q		OST-401-2 OST-409-2 OST-411 OST-401-2 OST-409-2 OST-411
C-411	G-190197 (1) AUG	B-7	B	Act	6	GA	M	N	O	C	N/A	N	N	FS AUG	Bi		OST-701-6
CC-702A	5379-376 (1)	D-6	C	Act	16	CK	SA	N	O/C	O/C	N/A	N	N	FF	Q		OST-908 OST-908-1 OST-908 OST-908-1
CC-702B	5379-376 (1)	C-6	C	Act	16	CK	SA	N	O/C	O/C	N/A	N	N	FF	Q		OST-908 OST-908-1 OST-908 OST-908-1
CC-702C	5379-376 (1)	B-6	C	Act	16	CK	SA	N	O/C	O/C	N/A	N	N	FF	Q		OST-908 OST-908-1 OST-908 OST-908-1
CC-707	5379-376 (1)	G-7	C	Act	3	RV	SA	N	C	O	C	N	N	RL	App. I		EST-112

Attachment 10.6
Page 7 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
CC-715	5379-376 (3)	B-2	C	Act	3	RV	SA	N	C	O/C	N/A	N	N	RL	App. I		EST-112
CC-716A	5379-376 (3) Full stroke exercise and stroke time measurement are augmented tests	D-8	B	Act	6	GA	MO	N	O	C	AI	N	Y	FS	CS	CC-VCS-1	OST-703-4
														TM (C)	CS	CC-VCS-1	OST-703-4
														PI	Bi		OST-703-4
CC-716B	5379-376 (3) GL 89-10, GL 96-05	D-8	A	Act	6	GA	MO	N	O	C	AI	Y	Y	FS	CS	CC-VCS-1	OST-703-4
														TM (C)	CS	CC-VCS-1	OST-703-4
														PI	Bi		OST-703-4
														LJ	App. J		OST-933-26
CC-721A	5379-376 (3)	C-6	C	Act	1.5	CK	SA	N	O	C	N/A	N	N	OV	App. II		CM-143 EST-152 PM-312
														RF	App. II		CM-143 PM-312
CC-721B	5379-376 (3)	F-6	C	Act	1.5	CK	SA	N	O	C	N/A	N	N	OV	App. II		CM-143 EST-152 PM-312
														RF	App. II		CM-143 PM-312
CC-721C	5379-376 (3)	D-6	C	Act	1.5	CK	SA	N	O	C	N/A	N	N	OV	App. II		CM-143 EST-152 PM-312
														RF	App. II		CM-143 PM-312

Attachment 10.6

Page 8 of 97

Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
CC-722A	5379-376 (3)	B-5	C	Act	0.75	RV	SA	N	C	O/C	N/A	N	N	RL	App. I		EST-112
CC-722B	5379-376 (3)	E-5	C	Act	0.75	RV	SA	N	C	O/C	N/A	N	N	RL	App. I		EST-112
CC-722C	5379-376 (3)	D-5	C	Act	0.75	RV	SA	N	C	O/C	N/A	N	N	RL	App. I		EST-112
CC-729	5379-376 (3)	F-2	C	Act	3	RV	SA	N	C	O/C	N/A	N	N	RL	App. I		EST-112
CC-730	5379-376 (3) GL 89-10, GL 96-05	F-1	A	Act	6	GL	MO	N	O	C	AI	Y	Y	FS	CS	CC-VCS-2	OST-703-4
														TM (C)	CS	CC-VCS-2	OST-703-4
														PI	Bi		OST-703-4
														LJ	App. J		OST-933-27
CC-731	5379-376 (2)	C-6	C	Act	6	CK	SA	N	O	C	N/A	N	N	DA	R	CC-VRS-1	EST-132
CC-735	5379-376 (2) GL 89-10, GL 96-05	C-5	A	Act	3	GA	MO	N	O	C	AI	Y	Y	FS	CS	CC-VCS-3	OST-703-4
														TM (C)	CS	CC-VCS-3	OST-703-4
														PI	Bi		OST-703-4
														LJ	App. J		OST-933-9

Attachment 10.6
Page 9 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
CC-736	5379-376 (2) AUG	C-5	B	Pass	3	GA	M	N	O	O	N/A	N	N	FS AUG	Bi		OST-933-9
CC-737A	5379-376 (3)	B-8	B	Act	3	GA	M	N	O	C	N/A	N	N	FS	Bi		OST-701-6
CC-738	5379-376 (3)	B-7	C	Act	3	CK	SA	N	O	C	N/A	N	N	OV	App. II		CM-131 EST-132 EST-152 PM-308
														RF	App. II		CM-131 EST-132 PM-308
CC-739	5379-376 (3)	B-1	B	Act	3	GA	AO	N	O	C	C	N	Y	FS	Q		OST-701-3
														FC	Q		OST-701-3
														TM (C)	Q		OST-701-3
														PI	Bi		OST-707-3
CC-747A	5379-376 (2) Thermal Relief Valve - Code Case OMN-2	F-6	C	Act	1	RV	SA	N	C	N/A	N/A	N	N	RL	App. I		
CC-747B	5379-376 (2) Thermal Relief Valve - Code Case OMN-2	F-5	C	Act	1	RV	SA	N	C	N/A	N/A	N	N	RL	App. I		

Attachment 10.6
Page 10 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
CC-749A	5379-376 (2)	E-7	B	Act	16	GA	MO	N	C	O	AI	N	Y	FS	Q		OST-252-1
	GL 89-10, GL 96-05													TM (O)	Q		OST-252-1
														PI	Bi		OST-258-1
CC-749B	5379-376 (2)	E-5	B	Act	16	GA	MO	N	C	O	AI	N	Y	FS	Q		OST-252-2
	GL 89-10, GL 96-05													TM (O)	Q		OST-252-2
														PI	Bi		OST-258-2
CC-774	5379-376 (4) Thermal Relief Valve - Code Case OMN-2	C-1	B	Act	.75	RV	SA	N	C	N/A	N/A	N	N	RL	App. I		
CC-791B	5379-376 (2) Thermal Relief Valve - Code Case OMN-2. This valve is listed as part of a system that is removed from service and will not be used to support plant operation. OP-305-2 and OP-306, attachment 10.2 require that Code required testing be determined prior to placing the system into service.	B-3	C	Act	0.75	RV	SA	N	C	O	N/A	N	N	RL	App. I		EST-112
CC-791C	5379-376 (2) Thermal Relief Valve - Code Case OMN-2	F-2	C	Act	.75	RV	SA	N	C	N/A	N/A	N	N	RL	App. I		
CC-791D	5379-376 (4) Thermal Relief Valve - Code Case OMN-2	B-4	C	Act	0.75	RV	SA	N	C	O	N/A	N	N	RL	App. I		EST-112
CC-791E	5379-376 (2) Thermal Relief Valve - Code Case OMN-2. This valve is listed as part of a system that is removed from service and will not be used to support plant operation. OP-305-2 and OP-306, attachment 10.2 require that Code required testing be determined prior to placing the system into service.	C-3	C	Act	.75	RV	SA	N	C	O	N/A	N	N	RL	App. I		EST-112

Attachment 10.6
Page 11 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
CC-791F	5379-376 (2) Thermal Relief Valve - Code Case OMN-2. This valve is listed as part of a system that is removed from service and will not be used to support plant operation. OP-305-2 and OP-306, attachment 10.2 require that Code required testing be determined prior to placing the system into service.	C-3	C	Act	.75	RV	SA	N	C	N/A	N/A	N	N	RL	App. I		EST-112
CC-791G	5379-376 (1) Thermal Relief Valve - Code Case OMN-2	E-1	C	Act	.75	RV	SA	N	C	N/A	N/A	N	N	RL	App. I		
CC-791H	5379-376 (2) Thermal Relief Valve - Code Case OMN-2	E-2	C	Act	.75	RV	SA	N	C	N/A	N/A	N	N	RL	App. I		
CC-791J	5379-376 (4) Thermal Relief Valve - Code Case OMN-2. This valve is listed as part of a system that is removed from service and will not be used to support plant operation. OP-305-2 and OP-306, attachment 10.2 require that Code required testing be determined prior to placing the system into service.	G-6	C	Act	0.75	RV	SA	N	C	O	N/A	N	N	RL	App. I		EST-112
CC-791K	5379-376 (4) Thermal Relief Valve - Code Case OMN-2. This valve is listed as part of a system that is removed from service and will not be used to support plant operation. OP-305-2 and OP-306, attachment 10.2 require that Code required testing be determined prior to placing the system into service.	F-6	C	Act	0.75	RV	SA	N	C	O	N/A	N	N	RL	App. I		EST-112
CC-791L	5379-376 (4) Thermal Relief Valve - Code Case OMN-2	C-4	C	Act	0.75	RV	SA	N	C	O	N/A	N	N	RL	App. I		EST-112
CC-832	5379-376 (1)	F-8	B	Pass	3	GL	MO	N	C	C	AI	N	Y	PI	Bi		OST-707-3

Attachment 10.6
Page 12 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
CC-926	5379-376 (4)	F-4	C	Act	0.75	CK	SA	N	O	O/C	N/A	N	N	FF	App. II		CM-149 EST-152 PM-320
														RF	App. II		CM-149 PM-320
CC-927	5379-376 (4)	C-2	B	Act	1	GL	M	N	O	O/C	N/A	N	N	FS	Bi		OST-701-6A
CC-928	5379-376 (4)	C-2	B	Act	1	GL	M	N	O	O/C	N/A	N	N	FS	Bi		OST-701-6B
CC-931	5379-376 (4)	E-4	C	Act	0.75	CK	SA	N	O	O/C	N/A	N	N	FF	App. II		CM-149 EST-152 PM-320
														RF	App. II		CM-149 PM-320
CC-932	5379-376 (2)	B-6	A	Pass	3	GA	M	N	LC	LC	N/A	N	N	LJ	App. J		OST-933-9
CC-948	5379-376 (1)	G-8	C	Act	1	VB	SA	N	C	O	N/A	N	N	RL	App. I		EST-130
CDR-78	HBR2-09005 SH00004 AUG	D-7	B	Act	4	BF	M	N	O	C	N/A	N	N	FS AUG	Bi		OST-701-6

Attachment 10.6
Page 13 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
CDR-86	G-190197 SH00001 AUG	C-8	B	Act	2	GA	M	N	C	O	N/A	N	N	FS AUG	Bi		OST-701-6
CVC-1118A	5379-686 (1) AUG	G-6	C	Act	2	RV	SA	N	C	O	N/A	N	N	RL	App. I		EST-112
CVC-1118B	5379-686 (1) AUG	E-6	C	Act	2	RV	SA	N	C	O	N/A	N	N	RL	App. I		EST-112
CVC-1118C	5379-686 (1) AUG	C-6	C	Act	2	RV	SA	N	C	O	N/A	N	N	RL	App. I		EST-112
CVC-200A	5379-685 (1)	F-6	B	Act	2	GL	AO	N	O/C	C	C	N	Y	FS FC TM (C) PI	CS CS CS Bi	CVC-VCS-5 CVC-VCS-5 CVC-VCS-5	OST-703-5 OST-703-5 OST-703-5 OST-703-5
CVC-200B	5379-685 (1)	G-6	B	Act	2	GL	AO	N	O/C	C	C	N	Y	FS FC TM (C) PI	CS CS CS Bi	CVC-VCS-5 CVC-VCS-5 CVC-VCS-5	OST-703-5 OST-703-5 OST-703-5 OST-703-5
CVC-200C	5379-685 (1)	G-6	B	Act	2	GL	AO	N	O/C	C	C	N	Y	FS FC TM (C) PI	CS CS CS Bi	CVC-VCS-5 CVC-VCS-5 CVC-VCS-5	OST-703-5 OST-703-5 OST-703-5 OST-703-5

Attachment 10.6
Page 14 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
CVC-202A	5379-685 (1)	F-4	A	Act	3	GA	M	N	O	C	N/A	Y	N	FS LJ	Bi App. J		OST-933-2 OST-933-2
CVC-203A	5379-685 (1)	G-5	C	Act	1	RV	SA	N	C	O	N/A	N	N	RL	App. I		EST-112
CVC-203B	5379-685 (1)	G-5	C	Act	2	RV	SA	N	C	O	N/A	N	N	RL	App. I		EST-112
CVC-204A	5379-685 (1)	G-4	A	Act	2	GL	AO	N	O	C	C	Y	Y	FS FC TM (C) PI LJ	CS CS CS Bi App. J	CVC-VCS-1 CVC-VCS-1 CVC-VCS-1	OST-703-5 OST-703-5 OST-703-5 OST-703-5 OST-933-20
CVC-204B	5379-685 (1)	G-4	A	Act	2	GL	AO	N	O	C	C	Y	Y	FS FC TM (C) PI LJ	CS CS CS Bi App. J	CVC-VCS-1 CVC-VCS-1 CVC-VCS-1	OST-703-5 OST-703-5 OST-703-5 OST-703-5 OST-933-20
CVC-2080	5379-685 (2)	B-5	C	Act	0.75	RV	SA	N	C	O	N/A	N	N	RL	App. I		EST-112
CVC-2081	5379-685 (2)	C-5	C	Act	0.75	RV	SA	N	C	O	N/A	N	N	RL	App. I		EST-112

Attachment 10.6
Page 15 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
CVC-2082	5379-685 (2)	D-6	C	Act	0.75	RV	SA	N	C	O	N/A	N	N	RL	App. I		EST-112
CVC-209	5379-685 (2)	G-4	C	Act	2	RV	SA	N	C	O	N/A	N	N	RL	App. I		EST-112
CVC-239A	5379-685 (2)	F-4	C	Act	2	CK	SA	N	O	C	N/A	N	N	OV	App. II		CM-143 EST-152 PM-312
														RF	App. II		CM-143 EST-153 PM-312
CVC-257	5379-685 (2)	F-5	C	Act	2	RV	SA	N	C	O	N/A	N	N	RL	App. I		EST-112
CVC-258	5379-685 (2)	F-7	B	Pass	0.375	GL	SO	N	C	C	C	N	Y	PI	Bi		OP-918
CVC-263	5379-685 (2)	E-5	C	Act	1	CK	SA	N	O/C	C	N/A	N	N	OV	App. II		CM-143 EST-152 PM-312
														RF	App. II		CM-143 EST-153 PM-312

Attachment 10.6
Page 16 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
CVC-266	5379-685 (2)	D-5	C	Act	4	CK	SA	N	O	C	N/A	N	N	OV	R	CVC-VRS-1	OST-101-1 OST-101-6
														RF	R	CVC-VRS-1	OST-109
CVC-282	5379-685 (1)	F-4	A	Act	3	GL	M	N	O	C	N/A	Y	N	FS	Bi		OST-933-2
														LJ	App. J		OST-933-2
CVC-283A	5379-685 (2)	D-7	C	Act	0.75	RV	SA	N	C	O	N/A	N	N	RL	App. I		EST-112
CVC-283B	5379-685 (2)	C-7	C	Act	0.75	RV	SA	N	C	O	N/A	N	N	RL	App. I		EST-112
CVC-283C	5379-685 (2)	B-7	C	Act	0.75	RV	SA	N	C	O	N/A	N	N	RL	App. I		EST-112
CVC-292A	5379-685 (1)	A-2	B	Act	0.75	GL	M	N	O	C	N/A	N	N	FS	Bi		OST-933-3
CVC-293A	5379-685 (1)	C-3	A	Act	2	GL	M	N	O/C	O/C	N/A	Y	N	FS	Bi		OST-933-3
														LJ	App. J		OST-933-3

Attachment 10.6
Page 17 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
CVC-293C	5379-685 (1)	B-3	A	Act	2	GL	M	N	O/C	O/C	N/A	Y	N	FS	Bi		OST-933-3
														LJ	App. J		OST-933-3
CVC-295	5379-685 (1)	A-2	A	Pass	3	GA	M	N	C	C	N/A	Y	N	LJ	App. J		OST-933-3
CVC-295A	5379-685 (1)	A-3	A	Pass	0.75	GL	M	N	LC	C	N/A	Y	N	LJ	App. J		OST-933-3
CVC-297A	5379-685 (1)	B-8	A	Act	1	ND	M	N	O	O/C	N/A	Y	N	FS	Bi		OST-933-3
														LJ	App. J		OST-933-3
CVC-297B	5379-685 (1)	B-6	A	Act	1	ND	M	N	O	O/C	N/A	Y	N	FS	Bi		OST-933-3
														LJ	App. J		OST-933-3
CVC-297C	5379-685 (1)	B-5	A	Act	1	ND	M	N	O	O/C	N/A	Y	N	FS	Bi		OST-933-3
														LJ	App. J		OST-933-3
CVC-298A	5379-685 (1)	C-8	C	Act	2	CK	SA	N	O	O/C	N/A	N	N	FF	App. II		CM-143 OST-101-1 OST-101-6 PM-312
														RF	App. II		CM-143 OST-112-1 PM-312

Attachment 10.6
Page 18 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
CVC-298B	5379-685 (1)	C-6	C	Act	2	CK	SA	N	O	O/C	N/A	N	N	FF	App. II		CM-143 OST-101-1 OST-101-6 PM-312
														RF	App. II		CM-143 OST-112-2 PM-312
CVC-298C	5379-685 (1)	C-5	C	Act	2	CK	SA	N	O	O/C	N/A	N	N	FF	App. II		CM-143 OST-101-1 OST-101-6 PM-312
														RF	App. II		CM-143 OST-112-3 PM-312
CVC-298D	5379-685 (1)	B-8	C	Act	2	CK	SA	N	O	O/C	N/A	N	N	FF	App. II		CM-143 OST-101-1 OST-101-6 PM-312
														RF	App. II		CM-143 OST-112-1 PM-312
CVC-298E	5379-685 (1)	B-6	C	Act	2	CK	SA	N	O	O/C	N/A	N	N	FF	App. II		CM-143 OST-101-1 OST-101-6 PM-312
														RF	App. II		CM-143 OST-112-2 PM-312
CVC-298F	5379-685 (1)	B-5	C	Act	2	CK	SA	N	O	O/C	N/A	N	N	FF	App. II		CM-143 OST-101-1 OST-101-6 PM-312
														RF	App. II		CM-143 OST-112-3 PM-312

Attachment 10.6
Page 19 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
CVC-307	5379-685 (1)	E-3	B	Pass	.75	GL	AO	N	C	N/A	C	N	N	FS AUG	R		OST-933-10
	AUG													FC AUG	R		OST-933-10
CVC-309A	5379-685 (1)	F-3	A	Pass	2	GL	M	N	C	C	N/A	Y	N	LJ	App. J		OST-933-2
														FS AUG	Bi		OST-933-2
CVC-310A	5379-685 (1)	F-7	B	Act	3	GL	AO	N	C	O	O	N	Y	FS	CS	CVC-VCS-3	OST-703-5
														FO	CS	CVC-VCS-3	OST-703-5
														TM (O)	CS	CVC-VCS-3	OST-703-5
														PI	Bi		OST-703-5
CVC-310B	5379-685 (1)	F-7	B	Pass	3	GL	AO	N	O	O	O	N	Y	PI	Bi		OST-703-5
														FO AUG	Bi		OST-703-5
														TM (C) AUG	Bi		OST-703-5
														FS AUG	Bi		OST-703-5
CVC-311	5379-685 (1)	E-7	B	Pass	2	GL	AO	N	C	N/A	C	N	N	FS AUG	R		OST-933-2
	AUG													FC AUG	R		OST-933-2
CVC-312A	5379-685 (1)	F-8	C	Act	3	CK	SA	N	C	O/C	N/A	N	N	FF	App. II		CM-135 OST-101-5 PM-310
														RF	App. II		CM-135 OST-167-3 PM-310

Attachment 10.6
Page 20 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
CVC-312B	5379-685 (1)	F-8	C	Act	3	CK	SA	N	O/C	O/C	N/A	N	N	FF	App. II		CM-135 OST-101-5 PM-310
														RF	App. II		CM-135 OST-167-4 PM-310
CVC-312C	5379-685 (1)	F-6	C	Act	3	CK	SA	N	O	O/C	N/A	N	N	FF	App. II		CM-131 OST-101-5 PM-301
														RF	App. II		CM-143 OST-112-4 PM-312
CVC-313	5379-685 (1)	F-8	C	Pass	2	CK	SA	N	C	C	N/A	N	N	OV	App. II		CM-143 GP-007 PM-312
														RF	App. II		CM-143 OST-167-5 PM-312
CVC-341	5379-685 (3)	C-5	B	Act	2	DA	M	N	O/C	O/C	N/A	N	N	FS	Bi		OST-108-4
CVC-342	5379-685 (3)	B-6	B	Act	2	DA	M	N	O/C	O/C	N/A	N	N	FS	Bi		OST-108-3
CVC-351	5379-685 (2)	B-2	C	Act	2	CK	SA	N	C	O	N/A	N	N	FF	R	CVC-VRS-2	GP-007
														CV	R	CVC-VRS-2	OST-109

Attachment 10.6
Page 21 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
CVC-357	5379-685 (2)	C-4	C	Act	4	CK	SA	N	C	O	N/A	N	N	FF	R	CVC-VRS-2	GP-009
														CV	R	CVC-VRS-2	OST-109
CVC-358	5379-685 (2)	C-5	B	Act	4	BF	M	N	C	O	N/A	N	N	FS	Bi		OST-701-6
CVC-365A	5379-685 (2) AUG	D-3	B	Pass	2	DA	M	N	C	C	N/A	N	N	FS	Bi		OST-703-5
CVC-365B	5379-685 (2) AUG	D-2	B	Pass	2	DA	M	N	C	C	N/A	N	N	FS	Bi		OST-703-5
CVC-381	5379-685 (1) GL 89-10, GL 96-05	E-2	A	Act	3	GA	MO	N	O	C	AI	Y	Y	FS	CS	CVC-VCS-2	OST-703-5
														TM (C)	CS	CVC-VCS-2	OST-703-5
														PI	Bi		OST-703-5
														LJ	App. J		OST-933-10
CVC-382	5379-685 (1)	E-3	C	Act	2	RV	SA	N	C	O	N/A	N	N	RL	App. I		EST-112
CVC-387	5379-685 (1)	E-7	B	Act	0.75	GL	AQ	N	O/C	C	C	N	Y	FS	CS	CVC-VCS-4	OST-703-5
														FC	CS	CVC-VCS-4	OST-703-5
														PI	Bi		OST-703-5
														TM (C)	CS	CVC-VCS-4	OST-703-5

Attachment 10.6

Page 22 of 97

Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
CVC-397A	5379-685 (3)	B-5	C	Act	2	CK	SA	N	C	O	N/A	N	N	FF	Q		OST-108-1 OST-108-3
														CV	Q		OST-108-2 OST-108-4
CVC-397B	5379-685 (3)	B-5	C	Act	2	CK	SA	N	C	O	N/A	N	N	FF	Q		OST-108-2 OST-108-4
														CV	Q		OST-108-1 OST-108-3
CVC-454	5379-685 (1)	B-7		Act	.75	CK	SA	N	O	N/A	N/A	N	N	OV	R		OST-167-6
	AUG													CV	R		OST-167-6
DA-11A	G-190204A (1)	B-4	C	Act	0.5	RV	SA	N	C	O	N/A	N	N	RL	App. I		EST-112
	AUG																
DA-11B	G-190204A (1)	E-4	C	Act	0.5	RV	SA	N	C	O	N/A	N	N	RL	App. I		EST-112
	AUG																
DA-19A	G-190204A (1)	B-6	B	Act	1.5	TW	SO	N	C	O	O	N	N	FS	Q		OP-604 OST-401-1 OST-409-1 OST-410
	AUG Skid mounted													FO	Q		OP-604 OST-401-1 OST-409-1 OST-410

Attachment 10.6
Page 23 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
DA-19B	G-190204A (1) AUG Skid mounted	E-6	B	Act	1.5	TW	SO	N	C	O	O	N	N	FS	Q		OP-604 OST-401-2 OST-409-2 OST-411 OP-604 OST-401-2 OST-409-2 OST-411
DA-23A	G-190204A (1) AUG Skid mounted	B-6	B	Act	1.5	TW	SO	N	C	O	O	N	N	FS	Q		OP-604 OST-401-1 OST-409-1 OST-410 OP-604 OST-401-1 OST-409-1 OST-410
DA-23B	G-190204A (1) AUG Skid mounted	E-6	B	Act	1.5	TW	SO	N	C	O	O	N	N	FS	Q		OP-604 OST-401-2 OST-409-2 OST-411 OP-604 OST-401-2 OST-409-2 OST-411
DA-33A	G-190204A (1) AUG DA-9A and DA-33A are tested as a unit	C-4	C	Act	0.75	CK	SA	N	O/C	C	N/A	N	N	RF	Q		OST-701-4
DA-33B	G-190204A (1) AUG DA-9B and DA-33B are tested as a unit	E-4	C	Act	0.75	CK	SA	N	O/C	C	N/A	N	N	RF	Q		OST-701-4

Attachment 10.6
Page 24 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
DA-9A	G-190204A (1) AUG DA-9A and DA-33A are tested as a unit	B-4	C	Act	0.75	CK	SA	N	O/C	C	N/A	N	N	RF	Q		OST-701-4
DA-9B	G-190204A (1) AUG DA-9B and DA-33B are tested as a unit	E-4	C	Act	0.75	CK	SA	N	O/C	C	N/A	N	N	RF	Q		OST-701-4
DG-20A	G-190204A (2) AUG Skid mounted	E-5	C	Act	1.5	CK	SA	N	C	C	N/A	N	N	RF	Q		OST-401-1 OST-409-1 OST-410
DG-20B	G-190204A (3) AUG Skid mounted	E-5	C	Act	1.5	CK	SA	N	C	C	N/A	N	N	RF	Q		OST-401-2 OST-409-2 OST-411
DG-24A	G-190204A (2) AUG Skid mounted	B-5	C	Act	4	CK	SA	N	C	O/C	N/A	N	N	FF	Q		OST-401-1 OST-409-1 OST-410
DG-24B	G-190204A (3) AUG Skid mounted	B-5	C	Act	4	CK	SA	N	C	O/C	N/A	N	N	FF	Q		OST-401-2 OST-409-2 OST-411

Attachment 10.6
Page 25 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type	Pos C Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
DG-32A	G-190204A (2) AUG Skid mounted	E-4	C	Act	1	RV	SA	N	C	N/A	N/A	N	N	FV	Q		OST-401-1 OST-409-1 OST-410
DG-32B	G-190204A (2) AUG Skid mounted	E-4	C	Act	1	RV	SA	N	C	N/A	N/A	N	N	FV	Q		OST-401-2 OST-409-2 OST-411
DG-45A	G-190204A (2) AUG Skid mounted	D-6	C	Act	0.75	CK	SA	N	C	O/C	N/A	N	N	FF	Q		OST-401-1 OST-409-1 OST-410 OST-401-1 OST-409-1 OST-410
DG-45B	G-190204A (3) AUG Skid mounted	D-6	C	Act	0.75	CK	SA	N	C	O/C	N/A	N	N	FF	Q		OST-401-2 OST-409-2 OST-411 OST-401-2 OST-409-2 OST-411
DG-46A	G-190204A (2) AUG Skid mounted	E-4	C	Act	0.5	RV	SA	N	C	N/A	N/A	N	N	FV	Q		OST-401-1 OST-409-1 OST-410

Attachment 10.6
Page 26 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
DG-46B	G-190204A (3) AUG Skid mounted	D-6	C	Act	0.5	RV	SA	N	C	N/A	N/A	N	N	FV	Q		OST-401-2 OST-409-2 OST-411
DG-4A	G-190204A (2) AUG Skid mounted	F-2	C	Act	5	CK	SA	N	C	O/C	N/A	N	N	FF	Q		OST-401-1 OST-409-1 OST-410 OST-401-1 OST-409-1 OST-410
DG-4B	G-190204A (3) AUG Skid mounted	F-2	C	Act	5	CK	SA	N	C	O/C	N/A	N	N	FF	Q		OST-401-2 OST-409-2 OST-411 OST-401-2 OST-409-2 OST-411
DG-5A	G-190204A (2) AUG Skid mounted	F-2	C	Act	5	CK	SA	N	C	O	N/A	N	N	FF	Q		OST-401-1 OST-409-1 OST-410
DG-5B	G-190204A (3) AUG Skid mounted	F-2	C	Act	5	CK	SA	N	C	O	N/A	N	N	FF	Q		OST-401-2 OST-409-2 OST-411
DW-19	G-190202 (3) AUG	H-3	B	Act	6	GA	M	N	LC	O	N/A	N	N	FS	Bi		OST-701-6

Attachment 10.6
Page 27 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type	Pos C Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
DW-20	G-190202 SH00003 AUG	H-3	B	Act	0.5	GL	M	N	O	C	N/A	N	N	FS AUG	Bi		OST-701-6
DW-21	G-190202 (3)	H-3	B	Act	6	GA	M	N	LC	O	N/A	N	N	FS	Bi		OST-701-6
DW-22	G-190202 SH00003 AUG	G-4	B	Act	6	GA	M	N	O	C	N/A	N	N	FS AUG	Bi		OST-701-6
DW-27	G-190202 SH00003 AUG	H-4	B	Act	2	GL	M	N	C	O	N/A	N	N	FS AUG	Bi		OST-701-6
EV-1963A-1	G-190204D (2) AUG	C-5	B	Act	1	GL	SO	Y	C	O	C	N	N	FS	Q		OST-402-1
														FC	Q		OST-402-1
EV-1963A-2	G-190204D (2) AUG	C-5	B	Act	1	GL	SO	Y	C	O	C	N	N	FS	Q		OST-402-1
														FC	Q		OST-402-1
EV-1963B-1	G-190204D (2) AUG	B-5	B	Act	1	GL	SO	Y	C	O	C	N	N	FS	Q		OST-402-2
														FC	Q		OST-402-2

Attachment 10.6

Page 28 of 97

Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
EV-1963B-2	G-190204D (2)	B-5	B	Act	1	GL	SO	Y	C	O	C	N	N	FS	Q		OST-402-2
	AUG													FC	Q		OST-402-2
FCV-113B	5379-685 (2)	D-4	B	Act	2	DA	AO	N	O/C	C	C	N	Y	FS	Q		OST-102
														FC	Q		OST-102
														TM (C)	Q		OST-102
														PI	Bi		OST-111
FCV-1424	G-190197 (4)	C-4	B	Act	4	GL	HYD	N	C	O	C	N	Y	FS	Q		OST-201-1 OST-207
														FC	Q		OST-201-1 OST-207
														TM (O)	Q		OST-201-1 OST-207
														PI	Bi		OST-207
FCV-1425	G-190197 (4)	B-4	B	Act	4	GL	HYD	N	C	O	C	N	Y	FS	Q		OST-201-2 OST-207
														FC	Q		OST-201-2 OST-207
														TM (O)	Q		OST-201-2 OST-207
														PI	Bi		OST-207
FCV-1608A	G-190199 (2)	E-7	B	Act	3	BL	AO	N	O/C	C	C	N	N	FS	Q		OST-302-1 OST-302-3
	AUG													FC	Q		OST-302-1 OST-302-3
														TM (C)	Q		OST-302-1 OST-302-3

Attachment 10.6
Page 29 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
FCV-1608B	G-190199 (2)	E-6	B	Act	3	BL	AO	N	O/C	C	C	N	N	FS	Q		OST-302-2 OST-302-4
	AUG													FC	Q		OST-302-2 OST-302-4
														TM (C)	Q		OST-302-2 OST-302-4
FCV-1625A	G-190199 (1)	B-2	B	Act	3	GA	SO	N	O/C	C	C	N	N	FS	Q		OST-302-1 OST-302-3
	AUG													FC	Q		OST-302-1 OST-302-3
														TM (C)	Q		OST-302-1 OST-302-3
FCV-1625B	G-190199 (1)	D-2	B	Act	3	GA	SO	N	O/C	C	C	N	N	FS	Q		OST-302-1 OST-302-3
	AUG													FC	Q		OST-302-1 OST-302-3
														TM (C)	Q		OST-302-1 OST-302-3
FCV-1625C	G-190199 (1)	F-2	B	Act	3	GA	SO	N	O/C	C	C	N	N	FS	Q		OST-302-1 OST-302-3
	AUG													FC	Q		OST-302-1 OST-302-3
														TM (C)	Q		OST-302-1 OST-302-3
FCV-1930A	G-190234 (1)	F-7	A	Act	3	GA	AO	N	O	C	C	Y	Y	FS	Q		OST-701-9
														FC	Q		OST-701-9
														TM (C)	Q		OST-701-9
														PI	Bi		OST-707-9
														LJ	App. J		OST-933-19

Attachment 10.6
Page 30 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
FCV-1930B	G-190234 (1)	F-7	A	Act	3	GA	AO	N	O	C	C	Y	Y	FS	Q		OST-701-9
														FC	Q		OST-701-9
														TM (C)	Q		OST-701-9
														PI	Bi		OST-707-9
														LJ	App. J		OST-933-19
FCV-1931A	G-190234 (1)	D-7	A	Act	3	GA	AO	N	O	C	C	Y	Y	FS	Q		OST-701-9
														FC	Q		OST-701-9
														TM (C)	Q		OST-701-9
														PI	Bi		OST-707-9
														LJ	App. J		OST-933-17
FCV-1931B	G-190234 (1)	D-7	A	Act	3	GA	AO	N	O	C	C	Y	Y	FS	Q		OST-701-9
														FC	Q		OST-701-9
														TM (C)	Q		OST-701-9
														PI	Bi		OST-707-9
														LJ	App. J		OST-933-17
FCV-1932A	G-190234 (1)	C-7	A	Act	3	GA	AO	N	O	C	C	Y	Y	FS	Q		OST-701-9
														FC	Q		OST-701-9
														TM (C)	Q		OST-701-9
														PI	Bi		OST-707-9
														LJ	App. J		OST-933-18
FCV-1932B	G-190234 (1)	C-7	A	Act	3	GA	AO	N	O	C	C	Y	Y	FS	Q		OST-701-9
														FC	Q		OST-701-9
														TM (C)	Q		OST-701-9
														PI	Bi		OST-707-9
														LJ	App. J		OST-933-18

Attachment 10.6
Page 31 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type	Pos C	Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
FCV-1933A	G-190234 (1)	F-7	A	Act	0.75	GL	AO	N	O	C	C	Y	Y		FS	Q		OST-701-9
															FC	Q		OST-701-9
															TM (C)	Q		OST-701-9
															PI	Bi		OST-707-9
															LJ	App. J		OST-933-21
FCV-1933B	G-190234 (1)	F-7	A	Act	0.75	GL	AO	N	O	C	C	Y	Y		FS	Q		OST-701-9
															FC	Q		OST-701-9
															TM (C)	Q		OST-701-9
															PI	Bi		OST-707-9
															LJ	App. J		OST-933-21
FCV-1934A	G-190234 (1)	D-7	A	Act	0.75	GL	AO	N	O	C	C	Y	Y		FS	Q		OST-701-9
															FC	Q		OST-701-9
															TM (C)	Q		OST-701-9
															PI	Bi		OST-707-9
															LJ	App. J		OST-933-23
FCV-1934B	G-190234 (1)	D-7	A	Act	0.75	GL	AO	N	O	C	C	Y	Y		FS	Q		OST-701-9
															FC	Q		OST-701-9
															TM (C)	Q		OST-701-9
															PI	Bi		OST-707-9
															LJ	App. J		OST-933-23
FCV-1935A	G-190234 (1)	B-7	A	Act	0.75	GL	AO	N	O	C	C	Y	Y		FS	Q		OST-701-9
															FC	Q		OST-701-9
															TM (C)	Q		OST-701-9
															PI	Bi		OST-707-9
															LJ	App. J		OST-933-22

Attachment 10.6
Page 32 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
FCV-1935B	G-190234 (1)	B-7	A	Act	0.75	GL	AO	N	O	C	C	Y	Y	FS	Q		OST-701-9
														FC	Q		OST-701-9
														TM (C)	Q		OST-701-9
														PI	Bi		OST-707-9
														LJ	App. J		OST-933-22
FCV-478	G-190197 (4)	G-3	B	Act	12	GL	AO	N	O	C	C	N	Y	FS	CS	FW-VCS-1	OST-702-2
														FC	CS	FW-VCS-1	OST-702-2
														TM (C)	CS	FW-VCS-1	OST-702-2
														PI	Bi		OST-702-2
FCV-479	G-190197 (4)	G-3	B	Act	4	GL	AO	N	O/C	C	C	N	Y	FS	CS	FW-VCS-1	OST-702-2
														FC	CS	FW-VCS-1	OST-702-2
														TM (C)	CS	FW-VCS-1	OST-702-2
														PI	Bi		OST-702-2
FCV-488	G-190197 (4)	F-3	B	Act	12	GL	AO	N	O	C	C	N	Y	FS	CS	FW-VCS-1	OST-702-2
														FC	CS	FW-VCS-1	OST-702-2
														TM (C)	CS	FW-VCS-1	OST-702-2
														PI	Bi		OST-702-2
FCV-489	G-190197 (4)	F-3	B	Act	4	GL	AO	N	O/C	C	C	N	Y	FS	CS	FW-VCS-1	OST-702-2
														FC	CS	FW-VCS-1	OST-702-2
														TM (C)	CS	FW-VCS-1	OST-702-2
														PI	Bi		OST-702-2
FCV-498	G-190197 (4)	E-3	B	Act	12	GL	AO	N	O	C	C	N	Y	FS	CS	FW-VCS-1	OST-702-2
														FC	CS	FW-VCS-1	OST-702-2
														TM (C)	CS	FW-VCS-1	OST-702-2
														PI	Bi		OST-702-2

Attachment 10.6
Page 33 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
FCV-499	G-190197 (4)	E-3	B	Act	4	GL	AO	N	O/C	C	C	N	Y	FS	CS	FW-VCS-1	OST-702-2
														FC	CS	FW-VCS-1	OST-702-2
														TM (C)	CS	FW-VCS-1	OST-702-2
														PI	Bi		OST-702-2
FCV-605	5379-1484 (1)	D-7	B	Pass	12	BF	AO	N	C	C	C	N	Y	PI	Bi		GP-007
FCV-626	5379-376 (3) GL 89-10, GL 96-05	D-1	A	Act	3	GA	MO	N	O	C	AI	Y	Y	FS	CS	CC-VCS-3	OST-703-4
														TM (C)	CS	CC-VCS-3	OST-703-4
														PI	Bi		OST-703-4
														LJ	App. J		OST-933-9
FCV-6416	G-190197 (4) Control Valve	D-4	B	Pass	6	GA	HYD	N	O	O	O	N	Y	FS AUG	Q		OST-202 OST-206
														FO	Q		OST-202 OST-206
														PI AUG	Bi		OST-206
FO-182A	G-190204D (2) AUG Skid mounted	E-6	C	Act	0.625	CK	SA	N	C	O/C	N/A	N	N	FF	Q		OST-401-1 OST-409-1 OST-410
														RF	Q		OST-401-1 OST-409-1 OST-410
FO-182B	G-190204D (2) AUG Skid mounted	E-4	C	Act	0.625	CK	SA	N	C	O/C	N/A	N	N	FF	Q		OST-401-2 OST-409-2 OST-411
														RF	Q		OST-401-2 OST-409-2 OST-411

Attachment 10.6
Page 34 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
FO-183A	G-190204D (2) AUG Skid mounted	D-5	C	Act	1	CK	SA	N	C	O	N/A	N	N	FF	Q		OST-401-1 OST-409-1 OST-410
FO-183B	G-190204D (2) AUG Skid mounted	D-3	C	Act	1	CK	SA	N	C	O	N/A	N	N	FF	Q		OST-401-2 OST-409-2 OST-411
FO-22A	G-190204D (2) AUG	C-7	B	Act	2	GL	M	N	O	O/C	N/A	N	N	FS	Bi		OST-402-1
FO-22B	G-190204D (2) AUG	C-8	B	Act	2	GL	M	N	O	O/C	N/A	N	N	FS	Bi		OST-402-2
FO-32A	G-190204D (2) AUG Skid mounted	E-5	C	Act	0.5	RV	SA	N	C	O/C	N/A	N	N	FV	Q		OST-401-1 OST-409-1 OST-410
FO-32B	G-190204D (2) AUG Skid mounted	E-3	C	Act	0.5	RV	SA	N	C	O/C	N/A	N	N	FV	Q		OST-401-2 OST-409-2 OST-411

Attachment 10.6
Page 35 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
FO-33A	G-190204D (2) AUG Skid mounted	E-5	C	Act	0.625	CK	SA	N	C	C	N/A	N	N	RF	Q		OST-401-1 OST-409-1 OST-410
FO-33B	G-190204D (2) AUG Skid mounted	E-4	C	Act	0.625	CK	SA	N	C	C	N/A	N	N	RF	Q		OST-401-2 OST-409-2 OST-411
FP-248	HBR2-8255 (2) GL 89-10, GL 96-05	E-7	A	Act	4	GA	MO	N	O	C	AI	Y	Y	FS	Q		OST-701-10
														TM (C)	Q		OST-701-10
														PI	Bi		OST-707-10
														LJ	App. J		EST-063
FP-249	HBR2-8255 (2) GL 89-10, GL 96-05	E-7	A	Act	4	GA	MO	N	O	C	AI	Y	Y	FS	Q		OST-701-10
														TM (C)	Q		OST-701-10
														PI	Bi		OST-707-10
														LJ	App. J		EST-063
FP-256	HBR2-8255 (2) GL 89-10, GL 96-05	F-7	A	Act	4	GA	MO	N	O	C	AI	Y	Y	FS	Q		OST-701-10
														TM (C)	Q		OST-701-10
														PI	Bi		OST-707-10
														LJ	App. J		EST-063
FP-258	HBR2-8255 (2) GL 89-10, GL 96-05	F-7	A	Act	4	GA	MO	N	O	C	AI	Y	Y	FS	Q		OST-701-10
														TM (C)	Q		OST-701-10
														PI	Bi		OST-707-10
														LJ	App. J		EST-063

Attachment 10.6
Page 36 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
FW-8A	G-190197 (4)	G-6	C	Act	16	SCK	SA	N	O	C	N/A	N	N	RF	R	FW-VRS-1	OST-928
														OV	R	FW-VRS-1	EST-152
FW-8B	G-190197 (4)	E-6	C	Act	16	SCK	SA	N	O	C	N/A	N	N	RF	R	FW-VRS-1	OST-928
														OV	R	FW-VRS-1	EST-152
FW-8C	G-190197 (4)	D-6	C	Act	16	SCK	SA	N	O	C	N/A	N	N	RF	R	FW-VRS-1	OST-928
														OV	R	FW-VRS-1	EST-152
FW-V2-6A	G-190197 (4) GL 89-10, GL 96-05	G-2	B	Act	16	GA	MO	N	O	C	AI	N	Y	FS	CS	FW-VCS-1	OST-702-2
														TM (C)	CS	FW-VCS-1	OST-702-2
														PI	BI		OST-702-2
FW-V2-6B	G-190197 (4) GL 89-10, GL 96-05	F-2	B	Act	16	GA	MO	N	O	C	AI	N	Y	FS	CS	FW-VCS-1	OST-702-2
														TM (C)	CS	FW-VCS-1	OST-702-2
														PI	Bi		OST-702-2
FW-V2-6C	G-190197 (4) GL 89-10, GL 96-05	E-2	B	Act	16	GA	MO	N	O	C	AI	N	Y	FS	CS	FW-VCS-1	OST-702-2
														TM (C)	CS	FW-VCS-1	OST-702-2
														PI	Bi		OST-702-2
HCV-105	5379-685 (3) Control Valve	C-5	B	Act	2	GL	AO	N	O/C	C	C	N	N	FC	Q		OST-108-2 OST-108-4
														FS	Q		OST-108-2 OST-108-4

Attachment 10.6
Page 37 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
HCV-110	5379-685 (3) Control Valve	C-6	B	Act	2	GL	AO	N	O/C	C	C	N	N	FC	Q		OST-108-1 OST-108-3 OST-108-1 OST-108-3
														FS	Q		
HCV-758	5379-1484 (1)	E-8	B	Pass	12	BF	AO	N	C	C	C	N	Y	PI	Bi		GP-007
IA-297	G-190200 (5) AUG	C-5	B	Act	2	GL	M	N	O	C	N/A	N	N	FS AUG	Bi		OST-906
IA-3742	G-190200 (5)	C-4	C	Act	0.25	CK	SA	N	O	C	N/A	N	N	RF	CS	MS-VCS-1	EST-134
														OV	CS	MS-VCS-1	EST-134
IA-3743	G-190200 (5)	C-4	C	Act	0.25	CK	SA	N	O	C	N/A	N	N	RF	CS	MS-VCS-1	EST-134
														OV	CS	MS-VCS-1	EST-134
IA-3744	G-190200 (5)	C-4	C	Act	0.25	CK	SA	N	O	C	N/A	N	N	RF	CS	MS-VCS-1	EST-134
														OV	CS	MS-VCS-1	EST-134
IA-423	HBR2-8606 (2) AUG	F-4	B	Act	.75	GL	M	N	LC	O	N/A	N	N	FS AUG	Bi		OST-906

Attachment 10.6

Page 38 of 97

Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
IA-525	G-190200 (2)	G-7	A/C	Act	2	CK	SA	N	O	C	N/A	Y	N	RF	R	IA-VRS-1	EST-062
														OV	R	IA-VRS-1	OST-703-7
														LJ	App. J		EST-062
IVSW-100A	G-190262 (1)	D-7	C	Act	0.375	CK	SA	N	C	O	N/A	N	N	FF	R	IST-RR-3	OST-933-19
IVSW-100B	G-190262 (1)	D-6	C	Act	0.375	CK	SA	N	C	O	N/A	N	N	FF	R	IST-RR-3	OST-933-17
IVSW-100C	G-190262 (1)	D-7	C	Act	0.375	CK	SA	N	C	O	N/A	N	N	FF	R	IST-RR-3	OST-933-18
IVSW-11	G-190262 (1)	F-4	C	Act	0.75	RV	SA	N	C	O	N/A	N	N	RL	App. I		EST-112
	AUG																
IVSW-14	G-190262 (1)	B-1	C	Act	0.375	RV	SA	N	C	O	N/A	N	N	RL	App. I		EST-112
	AUG																
IVSW-16	G-190262 (1)	C-2	B	Act	0.5	GL	M	N	C	O	N/A	N	N	FS	Bi		OST-933-2
	AUG																

Attachment 10.6
Page 39 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
IVSW-16A	G-190262 (1) AUG	C-2	B	Act	0.5	GL	M	N	C	O	N/A	N	N	FS	Bi		OST-933-3
IVSW-16E	G-190262 (1) AUG	B-2	B	Act	0.5	GL	M	N	C	O	N/A	N	N	FS	Bi		OST-933-5
IVSW-16F	G-190262 (1) AUG	B-2	B	Act	0.5	GL	M	N	C	O	N/A	N	N	FS	Bi		OST-933-6
IVSW-23	G-190262 (1) AUG	B-4	C	Act	0.375	RV	SA	N	C	O	N/A	N	N	RL	App. I		EST-112
IVSW-27	G-190262 (1) AUG	B-7	C	Act	0.375	RV	SA	N	C	O	N/A	N	N	RL	App. I		EST-112
IVSW-31	G-190262 (1) AUG	E-7	C	Act	0.375	RV	SA	N	C	O	N/A	N	N	RL	App. I		EST-112
IVSW-66A	G-190262 (1) AUG	F-2	C	Act	0.375	CK	SA	N	O	C	N/A	N	N	DA	R		OST-933-1

Attachment 10.6
Page 40 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
IVSW-66B	G-190262 (1) AUG	F-2	C	Act	0.375	CK	SA	N	O	C	N/A	N	N	RF	R		OST-933-1
IVSW-68A	G-190262 (1) AUG	F-2	C	Act	0.375	CK	SA	N	C	O	N/A	N	N	FF	R		OST-933-1
IVSW-68B	G-190262 (1) AUG	F-2	C	Act	0.375	CK	SA	N	C	O	N/A	N	N	FF	R		OST-933-1
IVSW-68C	G-190262 (1) AUG	F-3	C	Act	0.375	CK	SA	N	C	O	N/A	N	N	FF	R		OST-933-1
IVSW-68D	G-190262 (1) AUG	F-3	C	Act	0.375	CK	SA	N	C	O	N/A	N	N	FF	R		OST-933-1
IVSW-71	G-190262 (1)	C-2	C	Act	0.375	CK	SA	N	C	O	N/A	N	N	FF	R	IST-RR-3	OST-933-2
IVSW-72	G-190262 (1)	C-2	C	Act	0.375	CK	SA	N	C	O	N/A	N	N	FF	R	IST-RR-3	OST-933-3

Attachment 10.6
Page 41 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
IVSW-74	G-190262 (1)	B-2	C	Act	0.375	CK	SA	N	C	O	N/A	N	N	FF	R	IST-RR-3	OST-933-5
IVSW-75	G-190262 (1)	B-2	C	Act	0.375	CK	SA	N	C	O	N/A	N	N	FF	R	IST-RR-3	OST-933-6
IVSW-76	G-190262 (1)	C-4	C	Act	0.375	CK	SA	N	C	O	N/A	N	N	FF	R	IST-RR-3	OST-933-8
IVSW-77	G-190262 (1)	C-4	C	Act	0.375	CK	SA	N	C	O	N/A	N	N	FF	R	IST-RR-3	OST-933-9
IVSW-78	G-190262 (1)	C-4	C	Act	0.375	CK	SA	N	C	O	N/A	N	N	FF	R	IST-RR-3	OST-933-10
IVSW-79	G-190262 (1)	C-4	C	Act	0.375	CK	SA	N	C	O	N/A	N	N	FF	R	IST-RR-3	OST-933-11
IVSW-80	G-190262 (1)	B-4	C	Act	0.375	CK	SA	N	C	O	N/A	N	N	FF	R	IST-RR-3	OST-933-12

Attachment 10.6
Page 42 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
IVSW-81	G-190262 (1)	B-4	C	Act	0.375	CK	SA	N	C	O	N/A	N	N	FF	R	IST-RR-3	OST-933-13
IVSW-82	G-190262 (1)	E-7	C	Act	0.375	CK	SA	N	C	O	N/A	N	N	FF	R	IST-RR-3	OST-933-14
IVSW-83	G-190262 (1)	E-7	C	Act	0.375	CK	SA	N	C	O	N/A	N	N	FF	R	IST-RR-3	OST-933-15
IVSW-84	G-190262 (1)	D-7	C	Act	0.375	CK	SA	N	C	O	N/A	N	N	FF	R	IST-RR-3	OST-933-16
IVSW-85	G-190262 (1)	D-7	C	Act	0.375	CK	SA	N	C	O	N/A	N	N	FF	R	IST-RR-3	OST-933-19
IVSW-86	G-190262 (1)	D-7	C	Act	0.375	CK	SA	N	C	O	N/A	N	N	FF	R	IST-RR-3	OST-933-17
IVSW-87	G-190262 (1)	D-7	C	Act	0.375	CK	SA	N	C	O	N/A	N	N	FF	R	IST-RR-3	OST-933-18

Attachment 10.6
Page 43 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
IVSW-88	G-190262 (1)	C-7	C	Act	0.75	CK	SA	N	C	O	N/A	N	N	FF	R	IST-RR-3	OST-933-20
IVSW-89	G-190262 (1)	C-7	C	Act	0.375	CK	SA	N	C	O	N/A	N	N	FF	R	IST-RR-3	OST-933-24
IVSW-90	G-190262 (1)	C-7	C	Act	0.375	CK	SA	N	C	O	N/A	N	N	FF	R	IST-RR-3	OST-933-21
IVSW-91	G-190262 (1)	C-7	C	Act	0.375	CK	SA	N	C	O	N/A	N	N	FF	R	IST-RR-3	OST-933-23
IVSW-92	G-190262 (1)	B-7	C	Act	0.375	CK	SA	N	C	O	N/A	N	N	FF	R	IST-RR-3	OST-933-22
IVSW-93	G-190262 (1)	F-7	C	Act	0.375	CK	SA	N	C	O	N/A	N	N	FF	R	IST-RR-3	OST-933-25
IVSW-94	G-190262 (1)	F-7	C	Act	0.375	CK	SA	N	C	O	N/A	N	N	FF	R	IST-RR-3	OST-933-26

Attachment 10.6
Page 44 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
IVSW-95	G-190262 (1)	F-7	C	Act	0.375	CK	SA	N	C	O	N/A	N	N	FF	R	IST-RR-3	OST-933-27
IVSW-96	G-190262 (1)	G-7	C	Act	0.375	CK	SA	N	C	O	N/A	N	N	FF	R	IST-RR-3	OST-933-28
IVSW-97	G-190262 (1)	G-7	C	Act	0.375	CK	SA	N	C	O	N/A	N	N	FF	R	IST-RR-3	OST-933-29
IVSW-99	G-190262 (1) AUG	G-2	C	Act	.25	RV	SA	N	C	O	N/A	N	N	RL	App. I		EST-112
LCV-115B	5379-685 (2)	C-5	B	Act	4	BF	AO	N	C	O	C	N	Y	FS	Q		OST-102
														FC	Q		OST-102
														TM (O)	Q		OST-102
														PI	Bi		OST-111
LCV-115C	5379-685 (2) Full stroke exercise and stroke time measurement are augmented tests	D-5	A	Act	4	GA	MO	N	O	C	AI	N	Y	FS	R	CVC-VRS-1	OST-703-5
														TM (C)	R	CVC-VRS-1	OST-703-5
														PI	Bi		OST-703-5
														LK	Bi		OST-109
MOV-350	5379-685 (2) Full stroke exercise and stroke time measurement are augmented tests	B-2	B	Act	2	GA	MO	N	C	O	AI	N	Y	FS	Q		OST-102
														TM (O)	Q		OST-102
														PI	Bi		OST-111

Attachment 10.6
Page 45 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
MS-261A	G-190196 (1)	C-4	C	Act	26	CK	SA	N	O	C	N/A	N	N	OV	App. II		DELETED EST-152 PM-314
														RF	App. II		DELETED PM-314
MS-261B	G-190196 (1)	E-4	C	Act	26	CK	SA	N	O	C	N/A	N	N	OV	App. II		DELETED EST-152 PM-314
														RF	App. II		DELETED PM-314
MS-261C	G-190196 (1)	G-4	C	Act	26	CK	SA	N	O	C	N/A	N	N	OV	App. II		DELETED EST-152 PM-314
														RF	App. II		DELETED PM-314
MS-262A	G-190196 (1)	C-5	B	Act	2	GA	M	N	LO	O/C	N/A	N	N	FS	Bi		OST-701-6
MS-262B	G-190196 (1)	E-5	B	Act	2	GA	M	N	LO	O/C	N/A	N	N	FS	Bi		OST-701-6
MS-262C	G-190196 (1)	G-5	B	Act	2	GA	M	N	LO	O/C	N/A	N	N	FS	Bi		OST-701-6

Attachment 10.6
Page 46 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
MS-263A	G-190196 (1)	C-5	C	Act	2	CK	SA	N	C	O/C	N/A	N	N	FF	App. II		CM-142 OST-202 OST-206 PM-311
														RF	App. II		CM-142 PM-311
MS-263B	G-190196 (1)	D-5	C	Act	2	CK	SA	N	C	O/C	N/A	N	N	FF	App. II		CM-142 OST-202 OST-206 PM-311
														RF	App. II		CM-142 PM-311
MS-263C	G-190196 (1)	F-5	C	Act	2	CK	SA	N	C	O/C	N/A	N	N	FF	App. II		CM-142 OST-202 OST-206 PM-311
														RF	App. II		CM-142 PM-311
MS-353A	G-190196 (1)	C-4	B	Pass	2	GA	MO	N	C	C	AI	N	Y	PI	Bi		GP-002
MS-353B	G-190196 (1)	E-4	B	Pass	2	GA	MO	N	C	C	AI	N	Y	PI	Bi		GP-002
MS-353C	G-190196 (1)	F-4	B	Pass	2	GA	MO	N	C	C	AI	N	Y	PI	Bi		GP-002

Attachment 10.6
Page 47 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
MS-V1-3A	G-190196 (1)	C-4	B	Act	26	SCK	AO	N	O	C	C	N	Y	FS	CS	MS-VCS-2	OST-702-1
														FC	CS	MS-VCS-2	OST-702-1
														TM (C)	CS	MS-VCS-2	OST-702-1
														PI	Bi		OST-702-1
MS-V1-3B	G-190196 (1)	E-4	B	Act	26	SCK	AO	N	O	C	C	N	Y	FS	CS	MS-VCS-2	OST-702-1
														FC	CS	MS-VCS-2	OST-702-1
														TM (C)	CS	MS-VCS-2	OST-702-1
														PI	Bi		OST-702-1
MS-V1-3C	G-190196 (1)	G-4	B	Act	26	SCK	AO	N	O	C	C	N	Y	FS	CS	MS-VCS-2	OST-702-1
														FC	CS	MS-VCS-2	OST-702-1
														TM (C)	CS	MS-VCS-2	OST-702-1
														PI	Bi		OST-702-1
MS-V1-8A	G-190196 (1)	B-4	B	Act	2	GA	MO	N	C	O	AI	N	Y	FS	Q		OST-202 OST-206
	GL 89-10, GL 96-05													TM (O)	Q		OST-202 OST-206
														PI	Bi		OST-206
MS-V1-8B	G-190196 (1)	D-4	B	Act	2	GA	MO	N	C	O	AI	N	Y	FS	Q		OST-202 OST-206
	GL 89-10, GL 96-05													TM (O)	Q		OST-202 OST-206
														PI	Bi		OST-206

Attachment 10.6
Page 48 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
MS-V1-8C	G-190196 (1) GL 89-10, GL 96-05	F-4	B	Act	2	GA	MO	N	C	O	AI	N	Y	FS	Q		OST-202 OST-206 OST-202 OST-206 OST-206
														TM (O)	Q		
														PI	Bi		
OPP-10	G-190200 (9) AUG	C-5	C	Act	0.5	CK	SA	N	O/C	C	N/A	N	N	RF	R		OST-930 OST-930
														FF	R		
OPP-12	G-190200 (9) AUG	C-6	C	Act	0.75	RV	SA	N	C	O	N/A	N	N	RL	App. I		EST-112
OPP-13	G-190200 (9) AUG	D-6	C	Act	0.75	RV	SA	N	C	O	N/A	N	N	RL	App. I		EST-112
OPP-14	G-190200 (9) AUG	C-4	C	Act	0.5	CK	SA	N	C	O	N/A	N	N	FF	R		OST-930
OPP-15	G-190200 (9) AUG	D-4	C	Act	0.5	CK	SA	N	C	O	N/A	N	N	FF	R		OST-930
OPP-16	G-190200 (9) AUG	C-4	C	Act	0.5	RV	SA	N	C	O	N/A	N	N	RL	App. I		EST-112

Attachment 10.6
Page 49 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
OPP-17	G-190200 (9) AUG	D-4	C	Act	0.5	RV	SA	N	C	O	N/A	N	N	RL	App. I		EST-112
OPP-32	G-190200 (9) AUG	D-4	C	Act	0.25	RV	SA	N	C	O	N/A	N	N	FV	R		OP-006
OPP-33	G-190200 (9) AUG	D-5	C	Act	0.25	RV	SA	N	C	O	N/A	N	N	FV	R		OP-006
OPP-7	G-190200 (9) AUG	D-4	C	Act	0.75	CK	SA	N	O	C	N/A	N	N	RF	R		OST-930
OPP-8	G-190200 (9) AUG	C-4	C	Act	0.75	CK	SA	N	O	C	N/A	N	N	RF	R		OST-930
OPP-9	G-190200 (9) AUG	D-5	C	Act	0.5	CK	SA	N	O/C	C	N/A	N	N	RF FF	R R		OST-930 OST-930
PAS-1	HBR2-6490 (1)	C-6	A	Pass	0.375	GL	M	N	LC	C	N/A	Y-	N	LJ FS AUG	App. J Bi		EST-046 EST-046

Attachment 10.6
Page 50 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
PAS-2	HBR2-6490 (1)	B-6	A	Pass	0.375	GL	M	N	LC	C	N/A	Y	N	LJ	App. J		EST-046
														FS AUG	Bi		EST-046
PAS-3	HBR2-6490 (1)	D-6	A	Pass	0.375	GL	M	N	LC	C	N/A	Y	N	LJ	App. J		EST-046
														FS AUG	Bi		EST-046
PAS-4	HBR2-6490 (1)	C-6	A	Pass	0.375	GL	M	N	LC	C	N/A	Y	N	LJ	App. J		EST-046
														FS AUG	Bi		EST-046
PAS-5	HBR2-6490 (1)	E-6	A	Pass	0.375	GL	M	N	LC	C	N/A	Y	N	LJ	App. J		EST-046
														FS AUG	Bi		EST-046
PAS-6	HBR2-6490 (1)	D-6	A	Pass	0.375	GL	M	N	LC	C	N/A	Y	N	LJ	App. J		EST-046
														FS AUG	Bi		EST-046
PAV-31	HBR2-6933 (1)	D-7	B	Act	0.375	GL	M	N	LC	O	N/A	N	N	FS	Bi		OST-703-7
PAV-32	HBR2-6933 (1) AUG	D-6	B	Act	0.375	GL	M	N	LC	O	N/A	N	N	FS	Bi		OST-703-7

Attachment 10.6
Page 51 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
PAV-33	HBR2-6933 (1)	B-7	B	Act	0.375	GL	M	N	LC	O	N/A	N	N	FS	Bi		OST-703-7
PAV-34	HBR2-6933 (1) AUG	B-6	B	Act	0.375	GL	M	N	LC	O	N/A	N	N	FS	Bi		OST-703-7
PAV-35	HBR2-6933 (1)	D-7	B	Act	0.375	GL	M	N	LC	O	N/A	N	N	FS	Bi		OST-703-7
PAV-36	HBR2-6933 (1) AUG	D-6	B	Act	0.375	GL	M	N	LC	O	N/A	N	N	FS	Bi		OST-703-7
PAV-37	HBR2-6933 (1)	B-7	B	Act	0.375	GL	M	N	LC	O	N/A	N	N	FS	Bi		OST-703-7
PAV-38	HBR2-6933 (1) AUG	B-6	B	Act	0.375	GL	M	N	LC	O	N/A	N	N	FS	Bi		OST-703-7
PCV-1716	G-190200 (2)	G-7	A	Act	2	GL	AO	N	O	C	C	Y	Y	FS	R	IA-VRS-1	OST-703-8
														FC	R	IA-VRS-1	OST-703-8
														TM (C)	R	IA-VRS-1	OST-703-8
														PI	Bi		OST-703-8
														LJ	App. J		EST-062

Attachment 10.6
Page 52 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
PCV-1922A	G-190262 (1) AUG	E-5	B	Act	0.375	GA	AO	Y	C	O	O	N	Y	FS	CS		OST-703-6
														FO	CS		OST-703-6
														TM (O)	CS		OST-703-6
														PI	Bi		OST-703-6
PCV-1922B	G-190262 (1) AUG	D-5	B	Act	0.375	GA	AO	Y	C	O	O	N	Y	FS	CS		OST-703-6
														FO	CS		OST-703-6
														TM (O)	CS		OST-703-6
														PI	Bi		OST-703-6
PCV-455C	5379-1971 (2) GL-90-06	F-2	B	Act	3	GL	AO	N	C	O/C	C	N	Y	FS	CS	RCS-VCS-1	OP-006 OST-930
														FC	CS	RCS-VCS-1	OP-006 OST-930
														TM (O)	CS	RCS-VCS-1	OP-006 OST-930
														TM (C)	CS	RCS-VCS-1	OP-006 OST-930
														PI	Bi		OST-930
PCV-456	5379-1971 (2) GL-90-06	F-2	B	Act	3	GL	AO	N	C	O/C	C	N	Y	FS	CS	RCS-VCS-1	OP-006 OST-930
														FC	CS	RCS-VCS-1	OP-006 OST-930
														TM (O)	CS	RCS-VCS-1	OP-006 OST-930
														TM (C)	CS	RCS-VCS-1	OP-006 OST-930
														PI	Bi		OST-930
PP-274D	G-190261 (2)	C-4	A	Pass	0.375	GL	M	N	C	C	N/A	Y	N	EJ	App. J		EST-138

Attachment 10.6
Page 53 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
PP-275D	G-190261 (2)	C-4	A	Pass	0.375	GL	M	N	C	C	N/A	Y	N	LJ	App. J		EST-138
PS-956A	5379-353 (1)	G-6	A	Pass	0.375	GL	AO	Y	C	C	C	Y	Y	PI LJ	Bi App. J		OST-707-1 OST-933-11
PS-956B	5379-353 (1)	G-6	A	Pass	0.375	GL	AO	N	C	C	C	Y	Y	PI LJ	Bi App. J		OST-707-1 OST-933-11
PS-956C	5379-353 (1)	F-6	A	Pass	0.375	GL	AO	N	C	C	C	Y	Y	PI LJ	Bi App. J		OST-707-1 OST-933-12
PS-956D	5379-353 (1)	F-6	A	Pass	0.375	GL	AO	Y	C	C	C	Y	Y	PI LJ	Bi App. J		OST-707-1 OST-933-12
PS-956E	5379-353 (1)	E-6	A	Pass	0.375	GL	AO	Y	C	C	C	Y	Y	PI LJ	Bi App. J		OST-707-1 OST-933-13
PS-956F	5379-353 (1)	E-6	A	Pass	0.375	GL	AO	N	C	C	C	Y	Y	PI LJ	Bi App. J		OST-707-1 OST-933-13

Attachment 10.6
Page 54 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
PS-956G	5379-353 (1)	E-6	A	Pass	0.375	GL	AO	Y	C	C	C	Y	Y	PI LJ	Bi App. J		OST-707-1 OST-933-29
PS-956H	5379-353 (1)	E-6	A	Pass	0.375	GL	AO	N	C	C	C	Y	Y	PI LJ	Bi App. J		OST-707-1 OST-933-29
PS-959	5379-353 (1)	D-7	B	Pass	0.375	GL	AO	N	C	C	C	N	Y	PI	Bi		OST-707-1
RC-516	5379-1971 (2)	G-8	A	Act	0.375	GL	AO	N	O/C	C	C	Y	Y	FS FC TM (C) PI LJ	Q Q Q Bi App. J		OST-701-5 OST-701-5 OST-701-5 OST-707-5 OST-933-14
RC-518	5379-1971 (2)	F-7	A/C	Act	0.75	CK	SA	N	C	C	N/A	Y	N	OV LJ RF	App. II App. J App. II		CM-143 PM-312 EST-060 EST-060
RC-519A	5379-1971 (2)	F-8	A	Act	3	DA	AO	N	O/C	C	C	Y	Y	FS FC TM (C) PI LJ	Q Q Q Bi App. J		OST-701-5 OST-701-5 OST-701-5 OST-707-5 OST-933-15

Attachment 10.6
Page 55 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
RC-519B	5379-1971 (2)	F-8	A	Act	3	DA	AO	N	O/C	C	C	Y	Y	FS	Q		OST-701-5
														FC	Q		OST-701-5
														TM (C)	Q		OST-701-5
														PI	Bi		OST-707-5
														LJ	App. J		OST-933-15
RC-535	5379-1971 (2) GL 89-10, GL 96-05	F-2	B	Act	3	GA	MO	N	O	C	AI	N	Y	FS	Q		OST-701-5
														TM (C)	Q		OST-701-5
														PI	Bi		OST-707-5
RC-536	5379-1971 (2) GL 89-10, GL 96-05	F-2	B	Act	3	GA	MO	N	O	C	AI	N	Y	FS	Q		OST-701-5
														TM (C)	Q		OST-701-5
														PI	Bi		OST-707-5
RC-550	5379-1971 (2)	F-7	A	Act	0.75	DA	AO	N	O/C	C	C	Y	Y	FS	Q		OST-701-5
														FC	Q		OST-701-5
														TM (C)	Q		OST-701-5
														PI	Bi		OST-707-5
														LJ	App. J		EST-060
RC-551A	5379-1971 (2)	G-2	C	Act	4	RV	SA	N	C	O/C	N/A	N	N	RL	App. I		EST-027
RC-551B	5379-1971 (2)	G-3	C	Act	4	RV	SA	N	C	O/C	N/A	N	N	RL	App. I		EST-027

Attachment 10.6
Page 56 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
RC-551C	5379-1971 (2)	G-4	C	Act	4	RV	SA	N	C	O/C	N/A	N	N	RL	App. I		EST-027
RC-553	5379-1971 (2)	G-8	A	Act	0.375	GL	AO	N	O/C	C	C	Y	Y	FS	Q		OST-701-5
														FC	Q		OST-701-5
														TM (C)	Q		OST-701-5
														PI	Bi		OST-707-5
														LJ	App. J		OST-933-14
RC-567	5379-1971 (1)	D-3	B	Act	1	GL	SO	Y	C	O	C	N	Y	FS	CS	RCS-VCS-2	OST-703-3
														PI	Bi		GP-001
														TM (O)	CS	RCS-VCS-2	OST-703-3
														FC	CS	RCS-VCS-2	OST-703-3
RC-568	5379-1971 (1)	C-3	B	Act	1	GL	SO	Y	C	O	C	N	Y	FS	CS	RCS-VCS-2	OST-703-3
														PI	Bi		GP-001
														TM (O)	CS	RCS-VCS-2	OST-703-3
														FC	CS	RCS-VCS-2	OST-703-3
RC-569	5379-1971 (1)	C-3	B	Act	1	GL	SO	Y	C	O	C	N	Y	FS	CS	RCS-VCS-2	OST-703-3
														PI	Bi		GP-001
														TM (O)	CS	RCS-VCS-2	OST-703-3
														FC	CS	RCS-VCS-2	OST-703-3
RC-570	5379-1971 (1)	C-3	B	Act	1	GL	SO	Y	C	O	C	N	Y	FS	CS	RCS-VCS-2	OST-703-3
														PI	Bi		GP-001
														TM (O)	CS	RCS-VCS-2	OST-703-3
														FC	CS	RCS-VCS-2	OST-703-3

Attachment 10.6
Page 57 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
RC-571	5379-1971 (1)	D-2	B	Act	1	GL	SO	Y	C	O	C	N	Y	FS	CS	RCS-VCS-2	OST-703-3
														PI	Bi		GP-001
														TM (O)	CS		OST-703-3
														FC	CS		OST-703-3
RC-572	5379-1971 (1)	D-1	B	Act	1	GL	SO	Y	C	O	C	N	Y	FS	CS	RCS-VCS-2	OST-703-3
														PI	Bi		GP-001
														TM (O)	CS		OST-703-3
														FC	CS		OST-703-3
RHR-706	5379-1484 (1)	B-8	C	Act	2	RV	SA	N	C	O/C	N/A	N	N	RL	App. I		EST-112
RHR-743	5379-1484 (1)	C-7	B	Act	2	GL	M	N	LC	C	N/A	N	N	FS	Bi		OST-253
RHR-744A	5379-1484 (1) GL 89-10, GL 96-05	B-8	B	Act	10	GA	MO	N	C	O	AI	N	Y	FS	Q		OST-252-1
														TM (O)	Q		OST-252-1
														PI	Bi		OST-258-1
RHR-744B	5379-1484 (1) GL 89-10, GL 96-05	B-8	B	Act	10	GA	MO	N	C	O	AI	N	Y	FS	Q		OST-252-2
														TM (O)	Q		OST-252-2
														PI	Bi		OST-258-2

Attachment 10.6
Page 58 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
RHR-750	5379-1484 (1) GL 89-10, GL 96-05	B-2	B	Act	14	GA	MO	N	C	O/C	AI	N	Y	FS	R	RHR-VRS-1	OST-257
														TM (O)	R	RHR-VRS-1	OST-257
														TM (C)	R	RHR-VRS-1	OST-257
														PI	Bi		OST-257
RHR-751	5379-1484 (1) GL 89-10, GL 96-05	B-2	B	Act	14	GA	MO	N	C	O/C	AI	N	Y	FS	R	RHR-VRS-1	OST-257
														TM (O)	R	RHR-VRS-1	OST-257
														TM (C)	R	RHR-VRS-1	OST-257
														PI	Bi		OST-257
RHR-752A	5379-1484 (1) GL 89-10, GL 96-05	D-3	B	Act	14	GA	MO	N	O	O/C	AI	N	Y	FS	Q		OST-252-1
														TM (C)	Q		OST-252-1
														PI	Bi		OST-258-1
RHR-752B	5379-1484 (1) GL 89-10, GL 96-05	F-3	B	Act	14	GA	MO	N	O	O/C	AI	N	Y	FS	Q		OST-252-2
														TM (C)	Q		OST-252-2
														PI	Bi		OST-258-2
RHR-753A	5379-1484 (1)	D-5	C	Act	10	CK	SA	N	C	O/C	N/A	N	N	FF	App. II		CM-130 OST-253 PM-300
														RF	App. II		CM-130 OST-253 PM-300
RHR-753B	5379-1484 (1)	F-5	C	Act	10	CK	SA	N	C	O/C	N/A	N	N	FF	App. II		CM-130 OST-253 PM-300
														RF	App. II		CM-130 OST-253 PM-300

Attachment 10.6
Page 59 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
RHR-757C	5379-1484 (1)	E-5	B	Act	10	GA	M	N	LC	C	N/A	N	N	FS	Bi		OST-253
RHR-757D	5379-1484 (1)	E-5	B	Act	10	GA	M	N	LC	C	N/A	N	N	FS	Bi		OST-253
RHR-759A	5379-1484 (1)	D-7	B	Act	10	GA	MO	N	O	O/C	AI	N	Y	FS	Q		OST-252-1
	GL 89-10, GL 96-05													TM (O)	Q		OST-252-1
														TM (C)	Q		OST-252-1
														PI	Bi		OST-258-1
RHR-759B	5379-1484 (1)	F-7	B	Act	10	GA	MO	N	O	O/C	AI	N	Y	FS	Q		OST-252-2
	GL 89-10, GL 96-05													TM (O)	Q		OST-252-2
														TM (C)	Q		OST-252-2
														PI	Bi		OST-258-2
RHR-760	5379-1484 (1)	E-7	B	Act	2	GL	M	N	LC	C	N/A	N	N	FS	Bi		OST-253
RHR-782	5379-1484 (1)	D-7	C	Act	10	CK	SA	N	C	O/C	N/A	N	N	FF	App. II		OST-253 PM-129
														RF	App. II		OST-251-2 OST-253 PM-129

Attachment 10.6
Page 60 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
RHR-783	5379-1484 (1)	F-7	C	Act	10	CK	SA	N	C	O/C	N/A	N	N	FF	App. II		OST-253 PM-129
														RF	App. II		OST-251-1 OST-253 PM-129
RMS-1	G-190304 (1)	C-2	A	Act	1	GL	AO	N	O	C	C	Y	Y	FS	Q		OST-701-11
														FC	Q		OST-701-11
														TM (C)	Q		OST-701-11
														PI	Bi		OST-707-11
														LJ	App. J		EST-137-3
RMS-2	G-190304 (1)	C-2	A	Act	1	GL	AO	N	O	C	C	Y	Y	FS	Q		OST-701-11
														FC	Q		OST-701-11
														TM (C)	Q		OST-701-11
														PI	Bi		OST-707-11
														LJ	App. J		EST-137-3
RMS-3	G-190304 (1)	C-2	A	Act	1	GL	AO	N	O	C	C	Y	Y	FS	Q		OST-701-11
														FC	Q		OST-701-11
														TM (C)	Q		OST-701-11
														PI	Bi		OST-707-11
														LJ	App. J		EST-137-2
RMS-4	G-190304 (1)	C-2	A	Act	1	GL	AO	N	O	C	C	Y	Y	FS	Q		OST-701-11
														FC	Q		OST-701-11
														TM (C)	Q		OST-701-11
														PI	Bi		OST-707-11
														LJ	App. J		EST-137-2

Attachment 10.6
Page 61 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
RV1-1	G-190196 (1)	C-6	B	Pass	8	GL	AO	N	C	C	C	N	Y	FS AUG	CS		OST-702-5
														FC AUG	CS		OST-702-5
														PI	Bi		OST-702-5
RV1-2	G-190196 (1)	E-6	B	Pass	8	GL	AO	N	C	C	C	N	Y	FS AUG	CS		OST-702-5
														FC AUG	CS		OST-702-5
														PI	Bi		OST-702-5
RV1-3	G-190196 (1)	G-6	B	Pass	8	GL	AO	N	C	C	C	N	Y	FS AUG	CS		OST-702-5
														FC AUG	CS		OST-702-5
														PI	Bi		OST-702-5
SA-42	G-190200 (3) AUG	D-5	B	Act	2	DA	M	N	LC	O	N/A	N	N	FS	Bi		OST-703-7
SA-43	G-190200 (3)	D-5	A	Act	2	DA	M	N	LC	O/C	N/A	Y	N	FS	Bi		OST-703-7
														LJ	App. J		EST-137-4
SA-44	G-190200 (3)	D-5	A	Act	2	DA	M	N	LC	O/C	N/A	Y	N	FS	Bi		OST-703-7
														LJ	App. J		EST-137-4
SA-80	G-190200 (3) AUG	D-5	C	Act	2	CK	SA	N	C	O	N/A	N	N	OV	Bi		OST-703-7

Attachment 10.6
Page 62 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
SDN-13	HBR2-8606 (2) AUG	F-3	B	Act	0.5	GL	M	N	C	O	N/A	Y	N	FS	AUG	BI	OST-906
SDN-28	HBR2-8606 (2) AUG	F-4	B	Act	1	GL	M	N	LC	O	N/A	N	N	FS	AUG	BI	OST-906
SDN-29	HBR2-8606 (2) AUG	F-4	B	Pass	.75	GL	M	N	LO	C	N/A	N	N	FS	AUG	BI	OST-906
SI-844A	5379-1082 (3)	C-2	B	Pass	8	GA	MO	N	O	O	AI	N	Y	PI	BI		OST-352-3
SI-844B	5379-1082 (3)	E-2	B	Pass	8	GA	MO	N	O	O	AI	N	Y	PI	BI		OST-352-4
SI-845A	5379-1082 (3) GL 89-10, GL 96-05	F-6	B	Act	2	GL	MO	N	C	O	AI	N	Y	FS	CS	SI-VCS-1	OST-703-1
														TM (O)	CS	SI-VCS-1	OST-703-1
														PI	BI		OST-703-1
SI-845B	5379-1082 (3) GL 89-10, GL 96-05	E-6	B	Act	2	GL	MO	N	C	O	AI	N	Y	FS	CS	SI-VCS-1	OST-703-1
														TM (O)	CS	SI-VCS-1	OST-703-1
														PI	BI		OST-703-1

Attachment 10.6
Page 63 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
SI-845C	5379-1082 (3) AUG GL 89-10, GL 96-05	F-6	B	Pass	2	GL	MO	N	O	O	AI	N	Y	PI	Bi		OST-703-1
SI-851A	5379-1082 (5)	E-5	B	Act	1	GL	AO	N	C	C	C	N	Y	FS	CS	SI-VCS-6	OST-703-1
														FC	CS	SI-VCS-6	OST-703-1
														TM (C)	CS	SI-VCS-6	OST-703-1
														PI	Bi		OST-703-1
SI-851B	5379-1082 (5)	D-5	B	Act	1	GL	AO	Y	C	C	C	N	Y	FS	CS	SI-VCS-6	OST-703-1
														FC	CS	SI-VCS-6	OST-703-1
														TM (C)	CS	SI-VCS-6	OST-703-1
														PI	Bi		OST-703-1
SI-851C	5379-1082 (5)	B-5	B	Act	1	GL	AO	Y	C	C	C	N	Y	FS	CS	SI-VCS-6	OST-703-1
														FC	CS	SI-VCS-6	OST-703-1
														TM (C)	CS	SI-VCS-6	OST-703-1
														PI	Bi		OST-703-1
SI-853A	5379-1082 (5)	G-6	B	Pass	1	GL	AO	N	C	C	C	N	Y	PI	Bi		OST-703-1
SI-853B	5379-1082 (5)	E-6	B	Pass	1	GL	AO	N	C	C	C	N	Y	PI	Bi		OST-703-1

Attachment 10.6
Page 64 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
SI-853C	5379-1082 (5)	C-6	B	Pass	1	GL	AO	N	C	C	C	N	Y	PI	Bi		OST-703-1
SI-855	5379-1082 (5)	F-3	A	Act	1	GL	AO	N	O	C	C	Y	Y	FS	Q		OST-151-1 OST-151-2 OST-151-4 OST-151-5
														FC	Q		OST-151-1 OST-151-2 OST-151-4 OST-151-5
														TM (C)	Q		OST-151-1 OST-151-2 OST-151-4 OST-151-5
														PI	Bi		OST-151-4 OST-151-5
														LJ	App. J		EST-059
SI-856A	5379-1082 (2) IN 91-056	E-3	A	Act	2	GL	AO	N	O	O/C	O	N	Y	FS	CS	SI-VCS-5	OST-703-1
														FO	CS	SI-VCS-5	OST-703-1
														TM (O)	CS	SI-VCS-5	OST-703-1
														TM (C)	CS	SI-VCS-5	OST-703-1
														PI	Bi		OST-703-1
														LK	Bi		EST-140
SI-856B	5379-1082 (2) IN 91-056	E-3	A	Act	2	GL	AO	N	O	O/C	O	N	Y	FS	CS	SI-VCS-5	OST-703-1
														FO	CS	SI-VCS-5	OST-703-1
														TM (O)	CS	SI-VCS-5	OST-703-1
														TM (C)	CS	SI-VCS-5	OST-703-1
														PI	Bi		OST-703-1
														LK	Bi		EST-140
SI-857A	5379-1082 (1)	F-7	C	Act	0.75	RV	SA	N	C	O	N/A	N	N	RL	App. I		EST-112

Attachment 10.6
Page 65 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
SI-857B	5379-1082 (4)	E-6	C	Act	0.75	RV	SA	N	C	O	N/A	N	N	RL	App. I		EST-112
SI-858A	5379-1082 (5)	F-6	C	Act	1	RV	SA	N	C	O	N/A	N	N	RL	App. I		EST-112
SI-858B	5379-1082 (5)	E-6	C	Act	1	RV	SA	N	C	O	N/A	N	N	RL	App. I		EST-112
SI-858C	5379-1082 (5)	C-6	C	Act	1	RV	SA	N	C	O	N/A	N	N	RL	App. I		EST-112
SI-859	5379-1082 (4)	F-8	C	Act	0.75	RV	SA	N	C	O	N/A	N	N	RL	App. I		EST-112
SI-860A	5379-1082 (5)	C-2	B	Act	14	GA	MO	N	C	O	AI	N	Y	FS	Q		OST-252-1
	GL 89-10, GL 96-05													TM (O)	Q		OST-252-1
														TM (C)	Q		OST-252-1
														PI	Bi		OST-258-1
SI-860B	5379-1082 (5)	B-2	B	Act	14	GA	MO	N	C	O	AI	N	Y	FS	Q		OST-252-2
	GL 89-10, GL 96-05													TM (O)	Q		OST-252-2
														TM (C)	Q		OST-252-2
														PI	Bi		OST-258-2

Attachment 10.6
Page 66 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
SI-861A	5379-1082 (5) GL 89-10, GL 96-05	C-2	B	Act	14	GA	MO	N	C	O	AI	N	Y	FS	CS	SI-VCS-7	OST-703-2
														TM (O)	CS	SI-VCS-7	OST-703-2
														TM (C)	CS	SI-VCS-7	OST-703-2
														PI	Bi		OST-703-2
SI-861B	5379-1082 (5) GL 89-10, GL 96-05	B-2	B	Act	14	GA	MO	N	C	O	AI	N	Y	FS	CS	SI-VCS-7	OST-703-2
														TM (O)	CS	SI-VCS-7	OST-703-2
														TM (C)	CS	SI-VCS-7	OST-703-2
														PI	Bi		OST-703-2
SI-862A	5379-1082 (2) GL 89-10, GL 96-05	C-3	B	Act	14	GA	MO	N	O	O/C	AI	N	Y	FS	CS	SI-VCS-2	OST-703-2
														TM (O)	CS	SI-VCS-2	OST-703-2
														TM (C)	CS	SI-VCS-2	OST-703-2
														PI	Bi		OST-703-2
SI-862B	5379-1082 (2) GL 89-10, GL 96-05	C-3	B	Act	14	GA	MO	N	O	O/C	AI	N	Y	FS	CS	SI-VCS-2	OST-703-2
														TM (O)	CS	SI-VCS-2	OST-703-2
														TM (C)	CS	SI-VCS-2	OST-703-2
														PI	Bi		OST-703-2
SI-863A	5379-1082 (2) GL 89-10, GL 96-05	C-3	B	Act	8	GA	MO	N	LC	O/C	AI	N	Y	FS	CS	SI-VCS-3	OST-703-2
														TM (O)	CS	SI-VCS-3	OST-703-2
														TM (C)	CS	SI-VCS-3	OST-703-2
														PI	Bi		OST-703-2
SI-863B	5379-1082 (2) GL 89-10, GL 96-05	C-3	B	Act	8	GA	MO	N	LC	O/C	AI	N	Y	FS	CS	SI-VCS-3	OST-703-2
														TM (O)	CS	SI-VCS-3	OST-703-2
														TM (C)	CS	SI-VCS-3	OST-703-2
														PI	Bi		OST-703-2

Attachment 10.6
Page 67 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type	Pos C Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
SI-864A	5379-1082 (2) IN 91-56 GL 89-10, GL 96-05	E-4	A	Act	16	GA	MO	N	O	O/C	AI	N	Y	FS	CS	SI-VCS-2	OST-703-1
														TM (O)	CS	SI-VCS-2	OST-703-1
														TM (C)	CS	SI-VCS-2	OST-703-1
														PI	Bi		OST-703-1
														LK	Bi		EST-140
SI-864B	5379-1082 (2) IN 91-56 GL 89-10, GL 96-05	E-4	A	Act	16	GA	MO	N	O	O/C	AI	N	Y	FS	CS	SI-VCS-2	OST-703-1
														TM (O)	CS	SI-VCS-2	OST-703-1
														TM (C)	CS	SI-VCS-2	OST-703-1
														PI	Bi		OST-703-1
														LK	Bi		EST-140
SI-865A	5379-1082 (4) Full stroke exercise and stroke time measurement are augmented tests	F-2	B	Act	10	GA	MO	N	O	O/C	AI	N	Y	FS	CS	SI-VCS-3	OST-161
														TM (O)	CS	SI-VCS-3	OST-161
														TM (C)	CS	SI-VCS-3	OST-161
														PI	Bi		OST-161
SI-865B	5379-1082 (4) Full stroke exercise and stroke time measurement are augmented tests	D-2	B	Act	10	GA	MO	N	O	O/C	AI	N	Y	FS	CS	SI-VCS-3	OST-161
														TM (O)	CS	SI-VCS-3	OST-161
														TM (C)	CS	SI-VCS-3	OST-161
														PI	Bi		OST-161
SI-865C	5379-1082 (4) Full stroke exercise and stroke time measurement are augmented tests	C-2	B	Act	10	GA	MO	N	O	O/C	AI	N	Y	FS	CS	SI-VCS-3	OST-161
														TM (O)	CS	SI-VCS-3	OST-161
														TM (C)	CS	SI-VCS-3	OST-161
														PI	Bi		OST-161

Attachment 10.6
Page 68 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
SI-866A	5379-1082 (4) GL 89-10, GL 96-05	D-7	B	Act	2	GL	MO	N	C	O/C	AI	N	Y	FS	CS	SI-VCS-3	OST-703-1
														TM (O)	CS	SI-VCS-3	OST-703-1
														TM (C)	CS	SI-VCS-3	OST-703-1
														PI	Bi		OST-703-1
SI-866B	5379-1082 (4) GL 89-10, GL 96-05	D-7	B	Act	2	GL	MO	N	C	O/C	AI	N	Y	FS	CS	SI-VCS-3	OST-703-1
														TM (O)	CS	SI-VCS-3	OST-703-1
														TM (C)	CS	SI-VCS-3	OST-703-1
														PI	Bi		OST-703-1
SI-867A	5379-1082 (1)	D-3	B	Pass	4	GA	MO	N	O	O	AI	N	Y	PI	Bi		OST-151-4 OST-151-5
SI-867B	5379-1082 (1)	C-3	B	Pass	4	GA	MO	N	O	O	AI	N	Y	PI	Bi		OST-151-5 OST-151-6
SI-868A	5379-1082 (1) AUG	B-7	B	Pass	2	GA	M	N	O	O	AI	N	N	FS	Bi		OST-160
SI-868B	5379-1082 (1) AUG	B-7	B	Pass	2	GA	M	N	O	O	AI	N	N	FS	Bi		OST-160
SI-868C	5379-1082 (1) AUG	B-7	B	Pass	2	GA	M	N	O	O	AI	N	N	FS	Bi		OST-160

Attachment 10.6
Page 69 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
SI-869	5379-1082 (1)	F-8	B	Act	3	GA	MO	N	C	O/C	AI	N	Y	FS	Q		OST-151-1 OST-151-2 OST-151-4 OST-151-5
	GL 89-10, GL 96-05													TM (O)	Q		OST-151-1 OST-151-2 OST-151-4 OST-151-5
														TM (C)	Q		OST-151-1 OST-151-2 OST-151-4 OST-151-5
														PI	Bi		OST-151-4 OST-151-5
SI-870A	5379-1082 (1)	D-8	B	Act	3	GA	MO	N	C	O/C	AI	N	Y	FS	Q		OST-151-1 OST-151-2 OST-151-4 OST-151-5
	GL 89-10, GL 96-05													TM (O)	Q		OST-151-1 OST-151-2 OST-151-4 OST-151-5
														TM (C)	Q		OST-151-1 OST-151-2 OST-151-4 OST-151-5
														PI	Bi		OST-151-4 OST-151-5
SI-870B	5379-1082 (1)	D-7	B	Act	3	GA	MO	N	C	O/C	AI	N	Y	FS	Q		OST-151-2 OST-151-3 OST-151-5 OST-151-6
	GL 89-10, GL 96-05													TM (O)	Q		OST-151-2 OST-151-3 OST-151-5 OST-151-6
														TM (C)	Q		OST-151-2 OST-151-3 OST-151-5 OST-151-6
														PI	Bi		OST-151-5 OST-151-6

Attachment 10.6
Page 70 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
SI-871	5379-1082 (3)	E-2	C	Act	0.75	RV	SA	N	C	O	N/A	N	N	RL	App. I		EST-112
SI-872	5379-1082 (3)	G-6	C	Act	0.75	RV	SA	N	C	O	N/A	N	N	RL	App. I		EST-112
SI-873A	5379-1082 (4) SI-873A and SI-873D are tested as a unit (ISTC 4.5.7)	C-6	A/C	Act	2	CK	SA	N	C	O/C	N/A	N	N	FF	R	SI-VRS-3	OST-154
														LK	Bi		OST-160
														RF	R	SI-VRS-3	OST-160
SI-873B	5379-1082 (4)	C-6	C	Act	2	CK	SA	N	C	O	N/A	N	N	FF	App. II		CM-143 OST-154 PM-312
														CV	App. II		CM-143 OST-167-1 PM-312
SI-873C	5379-1082 (4)	C-5	C	Act	2	CK	SA	N	C	O	N/A	N	N	FF	App. II		CM-143 OST-154 PM-312
														CV	App. II		CM-143 OST-167-2 PM-312
SI-873D	5379-1082 (4) SI-873A and SI-873D are tested as a unit (ISTC 4.5.7)	B-6	A/C	Act	2	CK	SA	N	C	O/C	N/A	N	N	FF	R	SI-VRS-3	OST-154
														LK	Bi		OST-160
														RF	R	SI-VRS-3	OST-160

Attachment 10.6
Page 71 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
SI-873E	5379-1082 (4)	B-6	A/C	Act	2	CK	SA	N	C	O/C	N/A	N	N	FF	R	SI-VRS-3	OST-154
														LK	Bi		OST-160
														RF	R	SI-VRS-3	OST-160
SI-873F	5379-1082 (4)	C-5	A/C	Act	2	CK	SA	N	C	O/C	N/A	N	N	FF	R	SI-VRS-3	OST-154
														LK	Bi		OST-160
														RF	R	SI-VRS-3	OST-160
SI-874A	5379-1082 (4)	C-7	A/C	Act	2	CK	SA	N	C	O/C	N/A	N	N	FF	App. II		CM-143 OST-154 PM-312
														LK	Bi		OST-160
														RF	App. II		CM-143 OST-160 PM-312
SI-874B	5379-1082 (4)	C-7	A/C	Act	2	CK	SA	N	C	O/C	N/A	N	N	FF	App. II		CM-143 OST-154 PM-312
														LK	Bi		OST-160
														RF	App. II		CM-143 OST-160 PM-312
SI-875A	5379-1082 (4)	B-6	A/C	Act	10	CK	SA	N	C	O/C	N/A	N	N	FF	App. II		EST-096 OST-253 PM-306
														LK	Bi		OST-160
														RF	App. II		OST-160

Attachment 10.6
Page 72 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
SI-875B	5379-1082 (4)	B-7	A/C	Act	10	CK	SA	N	C	O/C	N/A	N	N	FF	App. II		EST-096 OST-253 PM-306 LK Bi RF App. II OST-160 OST-160
SI-875C	5379-1082 (4)	A-7	A/C	Act	10	CK	SA	N	C	O/C	N/A	N	N	FF	App. II		EST-096 OST-253 PM-306 LK Bi RF App. II OST-160 OST-160
SI-875D	5379-1082 (4)	F-3	A/C	Act	10	CK	SA	N	C	O/C	N/A	N	N	FF	App. II		EST-096 OST-161 PM-306 LK App. II RF App. II OST-160 OST-160
SI-875E	5379-1082 (4)	D-3	A/C	Act	10	CK	SA	N	C	O/C	N/A	N	N	FF	App. II		EST-096 OST-161 PM-306 LK App. II RF App. II OST-160 OST-160
SI-875F	5379-1082 (4)	C-3	A/C	Act	10	CK	SA	N	C	O/C	N/A	N	N	FF	App. II		EST-096 OST-161 PM-306 LK App. II RF App. II OST-160 OST-160

Attachment 10.6
Page 73 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
SI-876A	5379-1082 (4)	F-3	A/C	Act	8	CK	SA	N	C	O/C	N/A	N	N	FF	App. II		OST-253 PM-306
														LK	Bi		OST-160
														RF	App. II		OST-160
SI-876B	5379-1082 (4)	D-4	A/C	Act	8	CK	SA	N	C	O/C	N/A	N	N	FF	App. II		OST-253 PM-306
														LK	Bi		OST-160
														RF	App. II		OST-160
SI-876C	5379-1082 (4)	C-3	A/C	Act	8	CK	SA	N	C	O/C	N/A	N	N	FF	App. II		OST-253 PM-306
														LK	Bi		OST-160
														RF	App. II		OST-160
SI-878A	5379-1082 (2) Full stroke exercise and stroke time measurement are augmented tests	D-7	B	Act	4	GA	MO	N	O	C	AI	N	Y	FS	CS	SI-VCS-3	OST-703-1
														TM (C)	CS	SI-VCS-3	OST-703-1
														PI	Bi		OST-703-1
SI-878B	5379-1082 (2) Full stroke exercise and stroke time measurement are augmented tests	E-7	B	Act	4	GA	MO	N	O	C	AI	N	Y	FS	CS	SI-VCS-3	OST-703-1
														TM (C)	CS	SI-VCS-3	OST-703-1
														PI	Bi		OST-703-1
SI-879A	5379-1082 (2)	D-7	C	Act	3	CK	SA	N	C	O/C	N/A	N	N	FF	R	SI-VRS-2	OST-151-4
														RF	R	SI-VRS-2	OST-151-2 OST-151-3 OST-151-5 OST-151-6

Attachment 10.6
Page 74 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type	Pos C	Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
SI-879B	5379-1082 (2)	E-7	C	Act	3	CK	SA	N	C	O/C	N/A	N	N		FF	R	SI-VRS-2	OST-151-5
															RF	R	SI-VRS-2	OST-151-1 OST-151-3 OST-151-4 OST-151-6
SI-879C	5379-1082 (2)	F-7	C	Act	3	CK	SA	N	C	O/C	N/A	N	N		FF	R	SI-VRS-2	OST-151-6
															RF	R	SI-VRS-2	OST-151-1 OST-151-2 OST-151-4 OST-151-5
SI-880A	5379-1082 (3) GL 89-10, GL 96-05	C-5	B	Act	6	GA	MO	N	C	O	AI	N	Y		FS	Q		OST-352-1 OST-352-3
															TM (O)	Q		OST-352-1 OST-352-3
															PI	Bi		OST-352-3
SI-880B	5379-1082 (3) GL 89-10, GL 96-05	C-5	B	Act	6	GA	MO	N	C	O	AI	N	Y		FS	Q		OST-352-1 OST-352-3
															TM (O)	Q		OST-352-1 OST-352-3
															PI	Bi		OST-352-3
SI-880C	5379-1082 (3) GL 89-10, GL 96-05	E-5	B	Act	6	GA	MO	N	C	O	AI	N	Y		FS	Q		OST-352-2 OST-352-4
															TM (O)	Q		OST-352-2 OST-352-4
															PI	Bi		OST-352-4

Attachment 10.6
Page 75 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
SI-880D	5379-1082 (3)	E-5	B	Act	6	GA	MO	N	C	O	AI	N	Y	FS	Q		OST-352-2 OST-352-4
	GL 89-10, GL 96-05													TM (O)	Q		OST-352-2 OST-352-4
														PI	Bi		OST-352-4
SI-889A	5379-1082 (3)	D-3	C	Act	2	CK	SA	N	C	O/C	N/A	N	N	FF	CS	SI-VCS-4	OST-357
														RF	CS	SI-VCS-4	OST-357
SI-889B	5379-1082 (3)	D-3	C	Act	2	CK	SA	N	C	O/C	N/A	N	N	FF	CS	SI-VCS-4	OST-357
														RF	CS	SI-VCS-4	OST-357
SI-890A	5379-1082 (3)	C-5	A/C	Act	6	CK	SA	N	C	O/C	N/A	N	N	FF	App. II		CM-130 OST-357 PM-300
														LK	Bi		OST-357
														RF	App. II		OST-357
SI-890B	5379-1082 (3)	E-6	A/C	Act	6	CK	SA	N	C	O/C	N/A	N	N	FF	App. II		CM-130 OST-357 PM-300
														LK	Bi		OST-357
														RF	App. II		OST-357
SI-891A	5379-1082 (3)	C-8	A	Act	6	GA	M	N	LO	O/C	N/A	Y	N	FS	Bi		OST-357
														LJ	App. J		OST-933-5

Attachment 10.6
Page 76 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
SI-891B	5379-1082 (3)	E-8	A	Act	6	GA	M	N	LO	O/C	N/A	Y	N	FS	Bi		OST-357 OST-933-6
														LJ	App. J		
SI-893A	5379-1082 (2)	D-6	C	Act	0.75	CK	SA	N	C	O	N/A	N	N	FF	App. II		CM-143 OST-151-1 OST-151-4 PM-312 OST-151-2 OST-151-3 OST-151-5 OST-151-6
														CV	App. II		
SI-893B	5379-1082 (2)	E-6	C	Act	0.75	CK	SA	N	C	O	N/A	N	N	FF	App. II		CM-143 OST-151-2 OST-151-5 PM-312 OST-151-1 OST-151-3 OST-151-4 OST-151-6
														CV	App. II		
SI-893C	5379-1082 (2)	G-6	C	Act	0.75	CK	SA	N	C	O	N/A	N	N	FF	App. II		CM-143 OST-151-3 OST-151-6 PM-312 OST-151-1 OST-151-2 OST-151-4 OST-151-5
														CV	App. II		
SI-895V	5379-1082 (1)	G-7	A	Pass	0.75	GL	M	N	LC	C	N/A	Y	N	FS AUG	Bi		OST-933-28 OST-933-28
														LJ	App. J		

Attachment 10.6
Page 77 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
SI-898F	5379-1082 (1)	G-7	A	Pass	0.75	GL	M	N	LC	C	N/A	Y	N	FS AUG	BI		OST-933-28 OST-933-28
														LJ	App. J		
SI-899D	5379-1082 (3)	G-7	C	Act	0.75	VB	SA	N	C	O	N/A	N	N	RL	App. I		EST-068
SI-899E	5379-1082 (3)	G-7	C	Act	0.75	VB	SA	N	C	O	N/A	N	N	RL	App. I		EST-068
SI-909	5379-1082 (5)	F-3	A/C	Act	1	CK	SA	N	C	C	N/A	Y	N	LJ	App. J		EST-059
														OV	R	SI-VRS-1	EST-152
														RF	R	SI-VRS-1	EST-059
SI-915	5379-1082 (2) AUG	D-1	B	Pass	4	GL	M	N	LO	O	N/A	N	N	FS AUG	BI		OST-253
SI-916	5379-1082 (2) AUG	C-1	B	Pass	4	GL	M	N	LO	O	N/A	N	N	FS AUG	BI		OST-253
SI-925	5379-1082 (3)	B-3	A	Pass	4	GA	M	N	LC	C	N/A	N	N	LK	BI		EST-140

Attachment 10.6
Page 78 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
SI-928	5379-1082 (3)	F-3	A	Pass	4	GA	M	N	LC	C	N/A	N	N	LK	Bi		EST-140
SI-932	5379-1082 (2)	C-7	A	Pass	2	GA	M	N	LC	C	N/A	N	N	LK	Bi		EST-140
SI-935	5379-1082 (2)	D-7	A	Pass	2	GA	M	N	LC	C	N/A	N	N	LK	Bi		EST-140
SI-938	5379-1082 (2)	F-7	A	Pass	2	GA	M	N	LC	C	N/A	N	N	LK	Bi		EST-140
SV1-1A	G-190196 (1)	C-6	C	Act	6	RV	SA	N	C	O/C	N/A	N	N	RL	App. I		EST-028
SV1-1B	G-190196 (1)	E-6	C	Act	6	RV	SA	N	C	O/C	N/A	N	N	RL	App. I		EST-028
SV1-1C	G-190196 (1)	G-6	C	Act	6	RV	SA	N	C	O/C	N/A	N	N	RL	App. I		EST-028

Attachment 10.6
Page 79 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
SV1-2A	G-190196 (1)	C-6	C	Act	6	RV	SA	N	C	O/C	N/A	N	N	RL	App. I		EST-028
SV1-2B	G-190196 (1)	E-6	C	Act	6	RV	SA	N	C	O/C	N/A	N	N	RL	App. I		EST-028
SV1-2C	G-190196 (1)	G-6	C	Act	6	RV	SA	N	C	O/C	N/A	N	N	RL	App. I		EST-028
SV1-3A	G-190196 (1)	C-5	C	Act	6	RV	SA	N	C	O/C	N/A	N	N	RL	App. I		EST-028
SV1-3B	G-190196 (1)	E-5	C	Act	6	RV	SA	N	C	O/C	N/A	N	N	RL	App. I		EST-028
SV1-3C	G-190196 (1)	G-5	C	Act	6	RV	SA	N	C	O/C	N/A	N	N	RL	App. I		EST-028
SV1-4A	G-190196 (1)	C-5	C	Act	6	RV	SA	N	C	O/C	N/A	N	N	RL	App. I		EST-028

Attachment 10.6
Page 80 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
SV1-4B	G-190196 (1)	E-5	C	Act	6	RV	SA	N	C	O/C	N/A	N	N	RL	App. I		EST-028
SV1-4C	G-190196 (1)	G-5	C	Act	6	RV	SA	N	C	O/C	N/A	N	N	RL	App. I		EST-028
SW-118	G-190199 (10)	C-4	B	Act	6	GA	M	N	LC	O	N/A	N	N	FS	Bi		OST-701-6
SW-18	G-190199 (9)	D-7	B	Act	24	BF	M	N	O	O/C	N/A	N	N	FS	Bi		OST-701-6
SW-19	G-190199 (9)	E-7	B	Act	24	BF	M	N	O	O/C	N/A	N	N	FS	Bi		OST-701-6
SW-200	G-190199 (7) AUG	D-3	B	Act	1	GL	M	N	LC	O	N/A	N	N	FS	Bi		OST-701-6
SW-202	G-190199 (7) AUG.	D-3	B	Act	1	GL	M	N	C	O	N/A	N	N	FS	Bi		OST-701-6

Attachment 10.6
Page 81 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
SW-261	G-190199 (10)	F-2	C	Act	1	CK	SA	N	C	O	N/A	N	N	FF	App. II		CM-146 OST-202 PM-317 CM-146 PM-317
														CV	App. II		
SW-272	G-190199 (10)	E-1	C	Act	1	CK	SA	N	C	O	N/A	N	N	FF	App. II		CM-131 OST-202 PM-322 CM-131 PM-322
														CV	App. II		
SW-374	G-190199 (2)	C-8	C	Act	18	CK	SA	N	O/C	O/C	N/A	N	N	FF	Q		OST-302-1 OST-302-3
														RF	Q		OST-302-1 OST-302-3
SW-375	G-190199 (2)	C-6	C	Act	18	CK	SA	N	O/C	O/C	N/A	N	N	FF	Q		OST-302-2 OST-302-4
														RF	Q		OST-302-2 OST-302-4
SW-376	G-190199 (2)	C-7	C	Act	18	CK	SA	N	O/C	O/C	N/A	N	N	FF	Q		OST-302-1 OST-302-3
														RF	Q		OST-302-1 OST-302-3
SW-377	G-190199 (2)	C-6	C	Act	18	CK	SA	N	O/C	O/C	N/A	N	N	FF	Q		OST-302-2 OST-302-4
														RF	Q		OST-302-2 OST-302-4

Attachment 10.6

Page 82 of 97

Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
SW-541	G-190199 (9)	G-5	C	Act	30	CK	SA	N	O	O/C	N/A	N	N	FF	Q		OST-302-2 OST-302-4 OST-302-2 OST-302-4
														RF	Q		
SW-545	G-190199 (10)	B-3	C	Act	30	CK	SA	N	O	O/C	N/A	N	N	FF	Q		OST-302-1 OST-302-3 OST-302-1 OST-302-3
														RF	Q		
SW-546	G-190199 (4)	F-3	C	Act	0.75	RV	SA	N	C	O	N/A	N	N	RL	App. I		EST-112
SW-547	G-190199 (5)	E-6	C	Act	0.75	RV	SA	N	C	O	N/A	N	N	RL	App. I		EST-112
SW-548	G-190199 (5)	D-6	C	Act	0.75	RV	SA	N	C	O	N/A	N	N	RL	App. I		EST-112
SW-549	G-190199 (5)	C-6	C	Act	0.75	RV	SA	N	C	O	N/A	N	N	RL	App. I		EST-112
SW-559	G-190199 (7)	D-3	C	Act	1	CK	SA	N	C	O	N/A	N	N	FF	App. II		CM-131 PM-322
	AUG													CV	App. II		CM-131 PM-322

Attachment 10.6
Page 83 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type	Pos C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
SW-560	G-190199 (7)	F-5	C	Act	12	CK	SA	N	O/C	O/C	N/A	N	N	N	FF	Q		OST-303-2 OST-303-4 OST-303-1 OST-303-3
															RF	Q		
SW-561	G-190199 (7)	E-5	C	Act	12	CK	SA	N	O/C	O/C	N/A	N	N	N	FF	Q		OST-303-1 OST-303-3 OST-303-2 OST-303-4
															RF	Q		
SW-562	G-190199 (9) AUG	D-6	C	Act	1	CK	SA	N	O/C	O	N/A	N	N	N	FF	Q		OST-201-1 OST-207
SW-563	G-190199 (9) AUG	E-6	C	Act	1	CK	SA	N	O/C	O	N/A	N	N	N	FF	Q		OST-201-2 OST-207
SW-83	G-190199 (6) AUG	G-6	B	Pass	6	GA	M	N	C	C	N/A	N	N	N	FS	Bi		OST-410
SW-837	G-190199 (2)	F-6	C	Act	0.5	CK	SA	N	C	C	N/A	N	N	N	RF	App. II		OST-305
															OV	App. II		PMID 16360
SW-843	G-190199 (2)	F-6	C	Act	0.5	CK	SA	N	C	C	N/A	N	N	N	RF	App. II		OST-305
															OV	App. II		PMID 16361

Attachment 10.6
Page 84 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
SW-849	G-190199 (2)	F-7	C	Act	0.5	CK	SA	N	C	C	N/A	N	N	RF	App. II		OST-305
														OV	App. II		PMID 16362
SW-855	G-190199 (2)	F-7	C	Act	0.5	CK	SA	N	C	C	N/A	N	N	RF	App. II		OST-305
														OV	App. II		PMID 16363
SW-906	G-190199 (5)	B-2	B	Act	3	GA	M	N	O	O/C	N/A	N	N	FS	BI		OST-927-2
SW-907	G-190199 (5)	B-4	B	Act	2	GA	M	N	O	O/C	N/A	N	N	FS	BI		OST-927-1
SW-911	G-190199 (10)	F-6	C	Act	2	CK	SA	N	O	C	N/A	N	N	RF	App. II		CM-143 OST-927-2 PM-312
														OV	App. II		CM-143 EST-153 PM-312
SW-924	G-190199 (10)	F-7	C	Act	2	CK	SA	N	O	C	N/A	N	N	RF	App. II		CM-143 OST-927-1 PM-312
														OV	App. II		CM-143 EST-153 PM-312

Attachment 10.6
Page 85 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
SW-931	G-190199 (7)	E-5	C	Act	0.5	CK	SA	N	O	C	N/A	N	N	RF	App. II		CM-131 OST-303-2 OST-303-4 PM-322
	AUG													OV	App. II		CM-131 PM-322
SW-932	G-190199 (7)	F-5	C	Act	0.5	CK	SA	N	O	C	N/A	N	N	RF	App. II		CM-131 OST-303-1 OST-303-3 PM-322
	AUG													OV	App. II		CM-131 PM-322
SW-933	G-190199 (7)	D-4	C	Act	1	CK	SA	N	C	C	N/A	N	N	RF	App. II		CM-131 PM-322
	AUG													OV	App. II		CM-131 PM-322
SW-949	G-190199 (7)	E-4	C	Act	6	CK	SA	N	O/C	C	N/A	N	N	RF	Q		SPP-038
	System normally out of service													OV	Q		SPP-038
SW-950	G-190199 (7)	E-4	C	Act	6	CK	SA	N	O/C	C	N/A	N	N	RF	Q		SPP-038
	System normally out of service													OV	Q		SPP-038
SW-969	G-190199 (12)	A-5	B	Act	16	BF	M	N	LO	C	N/A	N	N	FS	AUG	BI	OST-702-4
	AUG																

Attachment 10.6
Page 86 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
TCV-1660	G-190199 (6)	C-1	B	Act	4	GL	AO	N	C	O	O	N	N	FS	Q		OST-401-1 OST-409-1 OST-410
														FO	Q		OST-401-1 OST-409-1 OST-410
														TM (O)	Q		OST-401-1 OST-409-1 OST-410
TCV-1661	G-190199 (6)	C-5	B	Act	4	GL	AO	N	C	O	O	N	N	FS	Q		OST-401-2 OST-409-2 OST-411
														FO	Q		OST-401-2 OST-409-2 OST-411
														TM (O)	Q		OST-401-2 OST-409-2 OST-411
TCV-1903A	G-190199 (9)	C-5	B	Act	1	GL	AO	Y	C	O	O	N	Y	FS	Q		OST-201-1 OST-207
														FO	Q		OST-201-1 OST-207
														TM (O)	Q		OST-201-1 OST-207
														PI	Bi		OST-207
TCV-1903B	G-190199 (9)	F-5	B	Act	1	GL	AO	Y	C	O	O	N	Y	FS	Q		OST-201-2 OST-207
														FO	Q		OST-201-2 OST-207
														TM (O)	Q		OST-201-2 OST-207
														PI	Bi		OST-207

Attachment 10.6
Page 87 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
V12-10	G-190304 (1)	D-2	A	Act	6	BF	AO	Y	O/C	C	C	Y	Y	FS	Q		OST-701-8
														FC	Q		OST-701-8
														TM (C)	Q		OST-701-8
														PI	Bi		OST-707-8
														LJ	App. J		EST-137-6
V12-11	G-190304 (1)	D-3	A	Act	6	BF	AO	Y	O/C	C	C	Y	Y	FS	Q		OST-701-8
														FC	Q		OST-701-8
														TM (C)	Q		OST-701-8
														PI	Bi		OST-707-8
														LJ	App. J		EST-137-6
V12-12	G-190304 (1)	C-6	A	Act	6	BF	AO	Y	O/C	C	C	Y	Y	FS	CS	HVA-VCS-1	OST-703-9
														FC	CS	HVA-VCS-1	OST-703-9
														TM (C)	CS	HVA-VCS-1	OST-703-9
														PI	Bi		OST-703-9
														LJ	App. J		EST-135-2
V12-13	G-190304 (1)	C-6	A	Act	6	BF	AO	Y	O/C	C	C	Y	Y	FS	CS	HVA-VCS-1	OST-703-9
														FC	CS	HVA-VCS-1	OST-703-9
														TM (C)	CS	HVA-VCS-1	OST-703-9
														PI	Bi		OST-703-9
														LJ	App. J		EST-135-2
V12-14	HBR2-6933 (1)	F-8	A	Act	3	DA	AO	N	C	O/C	C	Y	Y	FS	CS	PAV-VCS-1	OST-703-7
														FC	CS	PAV-VCS-1	OST-703-7
														TM (O)	CS	PAV-VCS-1	OST-703-7
														TM (C)	CS	PAV-VCS-1	OST-703-7
														PI	Bi		OST-703-7
														LJ	App. J		EST-137-6

Attachment 10.6
Page 88 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type	Pos C	Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
V12-15	HBR2-6933 (1)	G-6	A	Act	3	DA	AO	N	C	O/C	C	Y	Y		FS	CS	PAV-VCS-1	OST-703-7
															FC	CS	PAV-VCS-1	OST-703-7
															TM (O)	CS	PAV-VCS-1	OST-703-7
															TM (C)	CS	PAV-VCS-1	OST-703-7
															PI	Bi		OST-703-7
															LJ	App. J		EST-137-6
V12-16	HBR2-6933 (1) AUG	G-5	B	Act	3	DA	M	N	C	O	N/A	N	N		FS	Bi		OST-907
V12-17	HBR2-6933 (1) AUG	G-4	B	Act	3	DA	M	N	C	O	N/A	N	N		FS	Bi		OST-907
V12-18	HBR2-6933 (1)	E-8	A	Act	3	DA	AO	N	C	O/C	C	Y	Y		FS	CS	PAV-VCS-1	OST-703-7
															FC	CS	PAV-VCS-1	OST-703-7
															TM (O)	CS	PAV-VCS-1	OST-703-7
															TM (C)	CS	PAV-VCS-1	OST-703-7
															PI	Bi		OST-703-7
															LJ	App. J		EST-137-7
V12-19	HBR2-6933 (1)	E-7	A	Act	3	DA	AO	N	C	O/C	C	Y	Y		FS	CS	PAV-VCS-1	OST-703-7
															FC	CS	PAV-VCS-1	OST-703-7
															TM (O)	CS	PAV-VCS-1	OST-703-7
															TM (C)	CS	PAV-VCS-1	OST-703-7
															PI	Bi		OST-703-7
															LJ	App. J		EST-137-7
V12-20	HBR2-6933 (1) AUG	E-6	B	Act	3	DA	M	N	C	O	N/A	N	N		FS	Bi		OST-907

Attachment 10.6
Page 89 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
V12-21	HBR2-6933 (1) AUG	E-5	B	Act	3	DA	M	N	C	O	N/A	N	N	FS	Bi		OST-907
V12-24A	G-190200 (9) AUG	F-4	B	Act	2	DA	AO	N	C	O	C	N	Y	FS	Bi		OST-703-7
														FC	Bi		OST-703-7
														TM (O)	Bi		OST-703-7
														PI	Bi		OST-703-7
V12-24B	G-190200 (3) AUG	E-5	B	Act	2	DA	AO	N	C	O	C	N	Y	FS	Bi		OST-703-7
														FC	Bi		OST-703-7
														TM (O)	Bi		OST-703-7
														PI	Bi		OST-703-7
V12-25	G-190200 (3) AUG	C-5	B	Act	2	DA	AO	N	C	O	O	N	Y	FS	Bi		OST-703-7
														FO	Bi		OST-703-7
														TM (O)	Bi		OST-703-7
														PI	Bi		OST-703-7
V12-6	G-190304 (1)	C-6	A	Act	42	BF	AO	Y	O/C	C	C	Y	Y	FS	CS	HVA-VCS-2	OST-704
														FC	CS	HVA-VCS-2	OST-704
														TM (C)	CS	HVA-VCS-2	OST-704
														PI	Bi		OST-704
														LJ	App. J		EST-135-1
V12-61	HBR2-6933 (1) AUG	G-5	B	Act	2	GA	M	N	C	O	N/A	N	N	FS	Bi		OST-907

Attachment 10.6
Page 90 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
V12-63	HBR2-6933 (1) AUG	E-6	B	Act	2	GA	M	N	C	O	N/A	N	N	FS	Bi		OST-907
V12-7	G-190304 (1)	C-6	A	Act	42	BF	AO	Y	O/C	C	C	Y	Y	FS	CS	HVA-VCS-2	OST-704
														FC	CS	HVA-VCS-2	OST-704
														TM (C)	CS	HVA-VCS-2	OST-704
														PI	Bi		OST-704
														LJ	App. J		EST-135-1
V12-8	G-190304 (1)	E-2	A	Act	42	BF	AO	Y	O/C	C	C	Y	Y	FS	CS	HVA-VCS-2	OST-704
														FC	CS	HVA-VCS-2	OST-704
														TM (C)	CS	HVA-VCS-2	OST-704
														PI	Bi		OST-704
														LJ	App. J		EST-137-5
V12-9	G-190304 (1)	D-3	A	Act	42	BF	AO	Y	O/C	C	C	Y	Y	FS	CS	HVA-VCS-2	OST-704
														FC	CS	HVA-VCS-2	OST-704
														TM (C)	CS	HVA-VCS-2	OST-704
														PI	Bi		OST-704
														LJ	App. J		EST-137-5
V6-12A	G-190199 (2) Full stroke exercise and stroke time measurement are augmented tests	D-7	B	Act	30	BF	MO	N	O	C	AI	N	Y	FS	Q		OST-302-1 OST-302-3
														TM (C)	Q		OST-302-1 OST-302-3
														PI	Bi		OST-302-3

Attachment 10.6
Page 91 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type	Pos C Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
V6-12B	G-190199 (2) Full stroke exercise and stroke time measurement are augmented tests	C-7	B	Act	30	BF	MO	N	O	C	AI	N	Y	FS	Q		OST-302-1 OST-302-3 OST-302-1 OST-302-3 OST-302-3
														TM (C)	Q		
														PI	Bi		
V6-12C	G-190199 (2) Full stroke exercise and stroke time measurement are augmented tests	C-6	B	Act	30	BF	MO	N	O	C	AI	N	Y	FS	Q		OST-302-2 OST-302-4 OST-302-2 OST-302-4 OST-302-4
														TM (C)	Q		
														PI	Bi		
V6-12D	G-190199 (2) Full stroke exercise and stroke time measurement are augmented tests	D-6	B	Act	30	BF	MO	N	O	C	AI	N	Y	FS	Q		OST-302-2 OST-302-4 OST-302-2 OST-302-4 OST-302-4
														TM (C)	Q		
														PI	Bi		
V6-16A	G-190199 (10) GL 89-10, GL 96-05	B-3	B	Act	16	BF	MO	N	O	C	AI	N	Y	FS	Q		OST-302-2 OST-302-4 OST-302-2 OST-302-4 OST-302-4
														TM (C)	Q		
														PI	Bi		
V6-16B	G-190199 (10) GL 89-10, GL 96-05	C-3	B	Act	16	BF	MO	N	O	C	AI	N	Y	FS	Q		OST-302-1 OST-302-3 OST-302-1 OST-302-3 OST-302-3
														TM (C)	Q		
														PI	Bi		
V6-16C	G-190199 (10) GL 89-10, GL 96-05	B-2	B	Act	16	BF	MO	N	O	C	AI	N	Y	FS	CS	SW-VCS-1	OST-702-4
														TM (C)	CS	SW-VCS-1	OST-702-4
														PI	Bi		OST-702-4

Attachment 10.6
Page 92 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
V6-33A	G-190199 (7) Full stroke exercise and stroke time measurement are augmented tests	E-3	B	Act	6	BF	MO	N	O	C	AI	N	Y	FS	Q		OST-902-1 OST-902-1 OST-925
														TM (C)	Q		
														PI	Bi		
V6-33B	G-190199 (7) Full stroke exercise and stroke time measurement are augmented tests	E-3	B	Act	6	BF	MO	N	O	C	AI	N	Y	FS	Q		OST-902-1 OST-902-1 OST-925
														TM (C)	Q		
														PI	Bi		
V6-33C	G-190199 (7) Full stroke exercise and stroke time measurement are augmented tests	G-3	B	Act	6	BF	MO	N	O	C	AI	N	Y	FS	Q		OST-902-2 OST-902-2 OST-925
														TM (C)	Q		
														PI	Bi		
V6-33D	G-190199 (7) Full stroke exercise and stroke time measurement are augmented tests	F-3	B	Act	6	BF	MO	N	O	C	AI	N	Y	FS	Q		OST-902-2 OST-902-2 OST-925
														TM (C)	Q		
														PI	Bi		
V6-33E	G-190199 (7) Full stroke exercise and stroke time measurement are augmented tests	E-4	B	Act	6	BF	MO	N	O	C	AI	N	Y	FS	Q		OST-902-2 OST-902-2 OST-925
														TM (C)	Q		
														PI	Bi		
V6-33F	G-190199 (7) Full stroke exercise and stroke time measurement are augmented tests	F-4	B	Act	6	BF	MO	N	O	C	AI	N	Y	FS	Q		OST-902-1 OST-902-1 OST-925
														TM (C)	Q		
														PI	Bi		

Attachment 10.6
Page 93 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
V6-34A	G-190199 (5)	C-6	B	Act	6	BF	MO	N	O	C	AI	N	Y	FS	Q		OST-902-1
	Full stroke exercise and stroke time measurement are augmented tests													TM (C)	Q		OST-902-1
														PI	Bi		OST-925
V6-34B	G-190199 (5)	D-6	B	Act	6	BF	MO	N	O	C	AI	N	Y	FS	Q		OST-902-1
	Full stroke exercise and stroke time measurement are augmented tests													TM (C)	Q		OST-902-1
														PI	Bi		OST-925
V6-34C	G-190199 (5)	E-6	B	Act	6	BF	MO	N	O	C	AI	N	Y	FS	Q		OST-902-2
	Full stroke exercise and stroke time measurement are augmented tests													TM (C)	Q		OST-902-2
														PI	Bi		OST-925
V6-34D	G-190199 (5)	F-6	B	Act	6	BF	MO	N	O	C	AI	N	Y	FS	Q		OST-902-2
	Full stroke exercise and stroke time measurement are augmented tests													TM (C)	Q		OST-902-2
														PI	Bi		OST-925
V6-35A	G-190199 (4)	G-3	B	Act	1	GL	MO	N	O	C	AI	N	Y	FS	Q		OST-902-1
	Full stroke exercise and stroke time measurement are augmented tests													TM (C)	Q		OST-902-1
														PI	Bi		OST-925
V6-35B	G-190199 (4)	G-4	B	Act	1	GL	MO	N	O	C	AI	N	Y	FS	Q		OST-902-1
	Full stroke exercise and stroke time measurement are augmented tests													TM (C)	Q		OST-902-1
														PI	Bi		OST-925

Attachment 10.6
Page 94 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
V6-35C	G-190199 (4)	G-3	B	Act	1	GL	MO	N	O	C	AI	N	Y	FS	Q		OST-902-2
	Full stroke exercise and stroke time measurement are augmented tests													TM (C)	Q		OST-902-2
														PI	Bi		OST-925
V6-35D	G-190199 (4)	G-3	B	Act	1	GL	MO	N	O	C	AI	N	Y	FS	Q		OST-902-2
	Full stroke exercise and stroke time measurement are augmented tests													TM (C)	Q		OST-902-2
														PI	Bi		OST-925
VCT-13	HBR2-6490 (1)	C-8	A	Pass	2	GA	M	N	LC	C	N/A	Y	N	LJ	App. J		EST-009
VCT-18	HBR2-6490 (1)	C-7	A	Pass	0.375	GL	M	N	LC	C	N/A	Y	N	LJ	App. J		EST-046
VCT-19	HBR2-6490 (1)	D-7	A	Pass	0.375	GL	M	N	LC	C	N/A	Y	N	LJ	App. J		EST-046
VCT-20	HBR2-6490 (1)	E-8	A	Pass	0.375	GL	M	N	LC	C	N/A	Y	N	LJ	App. J		EST-046
WD-1621	5379-921 (2) AUG	F-3	C	Act	1	RV	SA	N	C	O	N/A	N	N	RL	App. I		EST-112

Attachment 10.6
Page 95 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
WD-1622	5379-921 (2) AUG	G-3	C	Act	1	RV	SA	N	C	O	N/A	N	N	RL	App. I		EST-112
WD-1623	5379-921 (2) AUG	D-3	C	Act	1	RV	SA	N	C	O	N/A	N	N	RL	App. I		EST-112
WD-1624	5379-921 (2) AUG	E-3	C	Act	1	RV	SA	N	C	O	N/A	N	N	RL	App. I		EST-112
WD-1713	5379-920 (3)	E-7	A/C	Pass	1	CK	SA	N	C	C	N/A	Y	N	LJ	App. J		EST-061
WD-1721	5379-920 (3)	C-6	A	Act	3	DA	AO	N	O/C	C	C	Y	Y	FS	Q		OST-701-2
														FC	Q		OST-701-2
														TM (C)	Q		OST-701-2
														PI	Bi		OST-707-2
														LJ	App. J		OST-933-8
WD-1722	5379-920 (3)	C-7	A	Act	3	DA	AO	N	O/C	C	C	Y	Y	FS	Q		OST-701-2
														FC	Q		OST-701-2
														TM (C)	Q		OST-701-2
														PI	Bi		OST-707-2
														LJ	App. J		OST-933-8

Attachment 10.6
Page 96 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
WD-1723	5379-920 (3)	B-7	A	Act	2	DA	AO	Y	O/C	C	C	Y	Y	FS	Q		OST-701-2
														FC	Q		OST-701-2
														TM (C)	Q		OST-701-2
														PI	Bi		OST-707-2
														LJ	App. J		OST-933-24
WD-1728	5379-920 (3)	B-7	A	Act	2	DA	AO	N	O/C	C	C	Y	Y	FS	Q		OST-701-2
														FC	Q		OST-701-2
														TM (C)	Q		OST-701-2
														PI	Bi		OST-707-2
														LJ	App. J		OST-933-24
WD-1786	5379-920 (3)	D-6	A	Act	1	DA	AO	Y	O/C	C	C	Y	Y	FS	Q		OST-701-2
														FC	Q		OST-701-2
														TM (C)	Q		OST-701-2
														PI	Bi		OST-707-2
														LJ	App. J		OST-933-16
WD-1787	5379-920 (3)	D-7	A	Act	1	DA	AO	Y	O/C	C	C	Y	Y	FS	Q		OST-701-2
														FC	Q		OST-701-2
														TM (C)	Q		OST-701-2
														PI	Bi		OST-707-2
														LJ	App. J		OST-933-16
WD-1789	5379-920 (3)	D-7	A	Act	0.75	DA	AO	N	O/C	C	C	Y	Y	FS	Q		OST-701-2
														FC	Q		OST-701-2
														TM (C)	Q		OST-701-2
														PI	Bi		OST-707-2
														LJ	App. J		OST-933-25

Attachment 10.6
Page 97 of 97
Valve Table

Valve Number	P&ID (SHT) Remarks	Coord	Cat	Act Pass	Size	Valve Type	Act Type	Rap Act	Norm Pos	Safe Pos	Fail Pos	App J Type C	Pos Ind	Test Type	Test Freq	Test Deferral	Surveillance Test
WD-1793	5379-920 (3)	E-6	A	Pass	1	DA	M	N	LC	C	N/A	Y	N	LJ	App. J		EST-061
WD-1794	5379-920 (3)	D-6	A	Act	0.75	DA	AO	N	O/C	C	C	Y	Y	FS	Q		OST-701-2
														FC	Q		OST-701-2
														TM (C)	Q		OST-701-2
														PI	Bi		OST-707-2
														LJ	App. J		OST-933-25

Attachment 10.7

Page 1 of 40

Excluded Valve Table

P&ID	Valve No.	Reason For Exclusion
5379-1082 (1)	SI-841A	No safety function
	SI-841B	No safety function
	SI-877D	Exempt - test valve
	SI-883L	Category B passive manual valve
	SI-883W	Category B passive manual valve
	SI-894	Line blocked by MOD-888
	SI-895K	Category B passive manual valve
	SI-895N	Exempt - drain valve
	SI-895P	Category B passive manual valve
	SI-895T	No safety function
	SI-895U	Category B passive manual valve
	SI-899B	Category B passive manual valve
	SI-977	Exempt - vent valve
5379-1082 (2)	SI-878C	Exempt - vent valve
	SI-889C	Exempt - test valve
	SI-891C	Category B passive manual valve
	SI-891D	Category B passive manual valve
	SI-897G	Category B passive manual valve
	SI-898D	Category B passive manual valve
	SI-898G	Category B passive manual valve
	SI-898H	Category B passive manual valve
	SI-898J	Category B passive manual valve
	SI-968	Exempt - vent valve
	SI-969	Exempt - vent valve
	SI-970	Exempt - vent valve
	SI-971	Exempt - vent valve
	SI-972	Exempt - vent valve
	SI-973	Exempt - vent valve
	SI-974	Exempt - vent valve

Attachment 10.7
Page 2 of 40
Excluded Valve Table

P&ID	Valve No.	Reason For Exclusion
5379-1082 (3)	SI-975	Exempt - vent valve
	SI-883M	Category B passive manual valve
	SI-883N	Category B passive manual valve
	SI-889F	No safety function
	SI-892A	Category B passive manual valve
	SI-892C	Category B passive manual valve
	SI-892D	Category B passive manual valve
	SI-892E	Category B passive manual valve
	SI-892F	Category B passive manual valve
	SI-892G	Category B passive manual valve
	SI-892H	Category B passive manual valve
	SI-896E	Category B passive manual valve
5379-1082 (4)	SI-897H	Category B passive manual valve
	SI-897J	Category B passive manual valve
	SI-850A	Exempt - test valve
	SI-850B	Exempt - test valve
	SI-850C	Exempt - test valve
	SI-850D	Exempt - test valve
	SI-850E	Exempt - test valve
	SI-850F	Exempt - test valve
	SI-877A	Exempt - test valve
	SI-877B	Exempt - test valve
	SI-877C	Exempt - test valve
	SI-883R	Exempt - maintenance valve
	SI-884A	Exempt - test valve
	SI-884B	Exempt - test valve
	SI-884C	Exempt - test valve
	SI-884D	Exempt - test valve
	SI-884E	Exempt - test valve

Attachment 10.7

Page 3 of 40

Excluded Valve Table

P&ID	Valve No.	Reason For Exclusion
5379-1082 (5)	SI-976	Category B passive manual valve
	HCV-936	Exempt - control valve
	SI-852A	Exempt - drain valve
	SI-852B	Exempt - drain valve
	SI-852C	Exempt - drain valve
	SI-882A	Exempt - drain valve
	SI-882B	Exempt - drain valve
	SI-882C	Exempt - drain valve
	SI-883B	Exempt - maintenance valve
	SI-883C	Exempt - maintenance valve
	SI-883E	Exempt - maintenance valve
	SI-883F	Exempt - maintenance valve
	SI-883H	Exempt - maintenance valve
	SI-883J	Exempt - maintenance valve
	SI-912	No safety function
5379-1484 (1)	RHR-754A	Category B passive manual valve
	RHR-754B	Category B passive manual valve
	RHR-755A	No safety function
	RHR-755B	No safety function
	RHR-757A	Category B passive manual valve
	RHR-757B	Category B passive manual valve
	RHR-762A	Exempt - maintenance valve
	RHR-762B	Exempt - maintenance valve
	RHR-764	Category B passive manual valve
	RHR-774	No safety function
	RHR-775	No safety function
	RHR-784	Exempt - vent valve
	RHR-785	Exempt - vent valve
	RHR-789	Exempt - vent valve

Attachment 10.7
Page 4 of 40
Excluded Valve Table

P&ID	Valve No.	Reason For Exclusion
	RHR-790	Exempt - vent valve
	RHR-791	Exempt - vent valve
	RHR-792	Exempt - vent valve
	RHR-793	Exempt - vent valve
5379-1485	SFPC-836A	No safety function
	SFPC-836B	No safety function
	SFPC-837	No safety function
5379-1485 (1)	SFPC-742	No safety function
	SFPC-783	No safety function
	SFPC-793	No safety function
	SFPC-796	No safety function
	SFPC-797	No safety function
	SFPC-798A	No safety function
	SFPC-798B	No safety function
	SFPC-799A	No safety function
	SFPC-799B	No safety function
	SFPC-799C	No safety function
	SFPC-799D	No safety function
	SFPC-800A	No safety function
	SFPC-800B	No safety function
	SFPC-801	No safety function
	SFPC-802A	No safety function
	SFPC-802B	No safety function
	SFPC-802C	Category B Passive manual valve
	SFPC-803	No safety function
	SFPC-804	Category B Passive manual valve
	SFPC-805A	No safety function
	SFPC-805B	No safety function
	SFPC-806	No safety function

Attachment 10.7

Page 5 of 40

Excluded Valve Table

P&ID	Valve No.	Reason For Exclusion
	SFPC-808	No safety function
	SFPC-809	No safety function
	SFPC-810	No safety function
	SFPC-811	No safety function
	SFPC-812	No safety function
	SFPC-813A	No safety function
	SFPC-813B	No safety function
	SFPC-813C	No safety function
	SFPC-813D	No safety function
	SFPC-814A	No safety function
	SFPC-814B	No safety function
	SFPC-815	No safety function
	SFPC-816A	No safety function
	SFPC-816B	No safety function
	SFPC-817	No safety function
	SFPC-818	No safety function
	SFPC-819	No safety function
	SFPC-820	No safety function
	SFPC-821A	No safety function
	SFPC-821B	No safety function
	SFPC-821C	No safety function
	SFPC-824J	No safety function
	SFPC-838A	No safety function
	SFPC-838B	No safety function
	SFPC-843	No safety function
	SFPC-843	No safety function
5379-1971 (1)	RC-501	Category B passive manual valve
	RC-502	Category B passive manual valve
	RC-505A	Exempt - drain valve

Attachment 10.7
Page 6 of 40
Excluded Valve Table

P&ID	Valve No.	Reason For Exclusion
5379-1971 (2)	RC-505B	Exempt - drain valve
	RC-508A	Exempt - drain valve
	RC-508B	Exempt - drain valve
	RC-515A	Exempt - drain valve
	RC-515B	Exempt - drain valve
	RC-542	Category B passive manual valve
	RC-586	Category B passive manual valve
	RC-601	Category B passive manual valve
	PCV-455A	Exempt - control valve
	PCV-455B	Exempt - control valve
	RC-524	No safety function
	RC-525	No safety function
	RC-582	No safety function
5379-353 (1)	PS-951	Exempt - maintenance valve
	PS-953	Exempt - maintenance valve
	PS-955A	Exempt - maintenance valve
	PS-955B	Exempt - maintenance valve
	PS-955C	Exempt - maintenance valve
	PS-955D	Exempt - maintenance valve
	PS-955E	Exempt - maintenance valve
	PS-969B	No safety function
	PS-974A	No safety function
	PS-974B	No safety function
	PS-975	No safety function
	PS-976	No safety function
	PS-977	No safety function
5379-376 (1)	PS-988	No safety function
	PS-989D	No safety function
5379-376 (1)	CC-701A	Category B passive manual valve

Attachment 10.7
Page 7 of 40
Excluded Valve Table

P&ID	Valve No.	Reason For Exclusion
	CC-701B	Category B passive manual valve
	CC-701C	Category B passive manual valve
	CC-703A	Category B passive manual valve
	CC-703B	Category B passive manual valve
	CC-703C	Category B passive manual valve
	CC-705A	Category B passive manual valve
	CC-705B	Category B passive manual valve
	CC-705C	Category B passive manual valve
	CC-710	Category B passive manual valve
	CC-711	Category B passive manual valve
	CC-712A	Category B passive manual valve
	CC-712B	Category B passive manual valve
	CC-713A	Category B passive manual valve
	CC-713B	Category B passive manual valve
	CC-733A	Category B passive manual valve
	CC-733B	Category B passive manual valve
	CC-737C	Category B passive manual valve
	CC-737D	Category B passive manual valve
	CC-786A	Category B passive manual valve
	CC-786B	Category B passive manual valve
	CC-788A	Category B passive manual valve
	CC-788AA	Category B passive manual valve
	CC-788B	Category B passive manual valve
	CC-788BB	Category B passive manual valve
	CC-788C	Category B passive manual valve
	CC-788CC	Category B passive manual valve
	CC-788D	Category B passive manual valve
	CC-788DD	Category B passive manual valve
	CC-788E	Category B passive manual valve

Attachment 10.7
Page 8 of 40
Excluded Valve Table

P&ID	Valve No.	Reason For Exclusion
	CC-788EE	Category B passive manual valve
	CC-788F	Category B passive manual valve
	CC-788FF	Category B passive manual valve
	CC-788G	Category B passive manual valve
	CC-788GG	Category B passive manual valve
	CC-825A	Category B passive manual valve
	CC-825B	Category B passive manual valve
	CC-825C	Category B passive manual valve
	CC-825D	Category B passive manual valve
	CC-825E	Category B passive manual valve
	CC-825F	Category B passive manual valve
	CC-861	Exempt - vent valve
	CC-940	Exempt - instrument valve
	CC-941	Exempt - instrument valve
	CC-942	Exempt - vent valve
	CC-943	Exempt - vent valve
	CC-944	Exempt - vent valve
	CC-945	Exempt - vent valve
	CC-946	Exempt - vent valve
	CC-947	Exempt - vent valve
	RCV-609	Exempt - vent valve
	TCV-659A	Exempt - control valve
	TCV-659B	Exempt - control valve
	TCV-659C	Exempt - control valve
5379-376(2)	CC-732	Category B passive manual valve
	CC-737B	Category B passive manual valve
	CC-746A	Category B passive manual valve
	CC-746B	Category B passive manual valve
	CC-748A	Category B passive manual valve

Attachment 10.7

Page 9 of 40

Excluded Valve Table

P&ID	Valve No.	Reason For Exclusion
	CC-748B	Category B passive manual valve
	CC-777	Category B passive manual valve
	CC-780	Category B passive manual valve
	CC-781	Category B passive manual valve
	CC-784	Category B passive manual valve
	CC-785	Category B passive manual valve
	CC-792A	Category B passive manual valve
	CC-792B	Category B passive manual valve
	CC-830A	Category B passive manual valve
	CC-833	Category B passive manual valve
	CC-834	Category B passive manual valve
	TCV-144	Exempt - control valve
5379-376 (3)	CC-717	No safety function
	CC-718A	Category B passive manual valve
	CC-718B	Category B passive manual valve
	CC-718C	Category B passive manual valve
	CC-719A	Category B passive manual valve
	CC-719B	Category B passive manual valve
	CC-719C	Category B passive manual valve
	CC-719D	Category B passive manual valve
	CC-719D1	Category B passive manual valve
	CC-719D2	Category B passive manual valve
	CC-719D3	Category B passive manual valve
	CC-719E	Category B passive manual valve
	CC-720A	Category B passive manual valve
	CC-720B	Category B passive manual valve
	CC-720C	Category B passive manual valve
	CC-723A	Category B passive manual valve
	CC-723B	Category B passive manual valve

Attachment 10.7
Page 10 of 40
Excluded Valve Table

P&ID	Valve No.	Reason For Exclusion
	CC-723C	Category B passive manual valve
	CC-724A	Category B passive manual valve
	CC-724B	Category B passive manual valve
	CC-724C	Category B passive manual valve
	CC-724D	Category B passive manual valve
	CC-727A	Category B passive manual valve
	CC-727B	Category B passive manual valve
	CC-727C	Category B passive manual valve
	CC-728A	Category B passive manual valve
	CC-728B	Category B passive manual valve
	CC-728C	Category B passive manual valve
5379-376 (4)	CC-728D	Category B passive manual valve
	CC-769A	Category B passive manual valve
	CC-769B	Category B passive manual valve
	CC-772	Category B passive manual valve
	CC-775	Category B passive manual valve
	CC-776	Category B passive manual valve
	CC-791A	Abandoned per EC 84732
	CC-792C	Category B passive manual valve
	CC-792D	Category B passive manual valve
	CC-794A	Category B passive manual valve
	CC-794B	Category B passive manual valve
	CC-795A	Category B passive manual valve
	CC-795B	Category B passive manual valve
	CC-795C	Category B passive manual valve
	CC-795D	Category B passive manual valve
	CC-795E	Category B passive manual valve
	CC-795F	Category B passive manual valve
	CC-795G	Category B passive manual valve

Attachment 10.7
Page 11 of 40
Excluded Valve Table

P&ID	Valve No.	Reason For Exclusion
	CC-795H	Category B passive manual valve
	CC-795J	Category B passive manual valve
	CC-795K	Category B passive manual valve
	CC-826A	Category B passive manual valve
	CC-826B	Category B passive manual valve
	CC-826C	Category B passive manual valve
	CC-826D	Category B passive manual valve
	CC-826E	Category B passive manual valve
	CC-826F	Category B passive manual valve
	CC-827A	Category B passive manual valve
	CC-827B	Category B passive manual valve
	CC-830B	Category B passive manual valve
5379-684 (1)	CVC-1102	No safety function
	CVC-1161	No safety function
5379-685 (1)	CVC-202B	Category B passive manual valve
	CVC-205A	Category B passive manual valve
	CVC-205B	Category B passive manual valve
	CVC-293B	No safety function
	CVC-293D	No safety function
	CVC-302A	No safety function
	CVC-302B	No safety function
	CVC-302C	No safety function
	CVC-303A	No safety function
	CVC-303B	No safety function
	CVC-303C	No safety function
	CVC-304A	Category B passive manual valve
	CVC-304B	Category B passive manual valve
	CVC-304C	Category B passive manual valve
	CVC-304D	Category B passive manual valve

Attachment 10.7
Page 12 of 40
Excluded Valve Table

P&ID	Valve No.	Reason For Exclusion
	CVC-304E	Category B passive manual valve
	CVC-304F	Category B passive manual valve
	CVC-304G	Category B passive manual valve
	CVC-304H	Category B passive manual valve
	CVC-304J	Category B passive manual valve
	CVC-304K	Category B passive manual valve
	CVC-304L	Category B passive manual valve
	CVC-304M	Category B passive manual valve
	CVC-306A	Category B passive manual valve
	CVC-306B	Category B passive manual valve
	CVC-306C	Category B passive manual valve
	CVC-308	Category B passive manual valve
	CVC-309D	No safety function
	CVC-312	Category B passive manual valve
	CVC-318	No safety function
	CVC-320	No safety function
	CVC-380	No safety function
	CVC-389	No safety function
	CVC-474	Category B passive manual valve
	HCV-121	Exempt - control valve
	HCV-137	Exempt - control valve
	HCV-142	Exempt - control valve
	LCV-460A	No safety function
	LCV-460B	No safety function
5379-685 (2)	CVC-249	No safety function
	CVC-250	No safety function
	CVC-253	No safety function
	CVC-254	No safety function

Attachment 10.7
Page 13 of 40
Excluded Valve Table

P&ID	Valve No.	Reason For Exclusion
	CVC-256	Category B passive with no remote position indication
	CVC-259A	No safety function
	CVC-259C	No safety function
	CVC-264	Category B passive manual valve
	CVC-267	Category B passive manual valve
	CVC-268	Category B passive manual valve
	CVC-269	Category B passive manual valve
	CVC-270	Category B passive manual valve
	CVC-271	No safety function
	CVC-272	Category B passive manual valve
	CVC-275A	No safety function
	CVC-275B	No safety function
	CVC-275C	No safety function
	CVC-277A	Category B passive manual valve
	CVC-277B	Category B passive manual valve
	CVC-277C	Category B passive manual valve
	CVC-286	Category B passive manual valve
	CVC-287	Category B passive manual valve
	CVC-288	Category B passive manual valve
	CVC-289	Category B passive manual valve
	CVC-290	Category B passive manual valve
	CVC-291	Category B passive manual valve
	CVC-309B	No safety function
	CVC-309C	No safety function
	CVC-309E	No safety function
	CVC-321	No safety function
	CVC-352	No safety function
	CVC-353	Category B passive manual valve

Attachment 10.7
Page 14 of 40
Excluded Valve Table

P&ID	Valve No.	Reason For Exclusion
	CVC-354	No safety function
	CVC-355	No safety function
	CVC-356	Category B passive manual valve
	CVC-361	No safety function
	CVC-362	No safety function
	CVC-364	No safety function
	CVC-366	No safety function
	CVC-368	No safety function
	CVC-600	Category B passive manual valve
	FCV-113A	No safety function
	FCV-114A	No safety function
	FCV-114B	No safety function
	LCV-115A	Exempt - control valve
	PCV-117	Exempt - control valve
	PCV-118	Exempt - control valve
	PCV-119	Exempt - control valve
	PCV-145	Exempt - control valve
	TCV-143	No safety function
5379-685(3)	CVC-1237	No safety function
	CVC-226B	Category B passive manual valve
	CVC-227A	Category B passive manual valve
	CVC-239B	No safety function
	CVC-244	No safety function
	CVC-245	No safety function
	CVC-247A	No safety function
	CVC-247B	No safety function
	CVC-284A	Category B passive manual valve
	CVC-284B	Category B passive manual valve

Attachment 10.7
Page 15 of 40
Excluded Valve Table:

P&ID	Valve No.	Reason For Exclusion
	CVC-328	No safety function
	CVC-329	Category B passive manual valve
	CVC-331	Category B passive manual valve
	CVC-332	Category B passive manual valve
	CVC-334	Category B passive manual valve
	CVC-335	Category B passive manual valve
	CVC-336	Category B passive manual valve
	CVC-337	Category B passive manual valve
	CVC-338	Category B passive manual valve
	CVC-340	Category B passive manual valve
	CVC-343A	No safety function
	CVC-344	Category B passive manual valve
	CVC-345	Category B passive manual valve
	CVC-347	Category B passive manual valve
	CVC-348	Category B passive manual valve
	CVC-375	Category B passive manual valve
	CVC-379	Category B passive manual valve
	CVC-398A	No safety function
	CVC-398B	No safety function
5379-686 (1)	CVC-1100	No safety function
	CVC-1101	No safety function
	CVC-1103	No safety function
	CVC-1104	No safety function
	CVC-1105	No safety function
	CVC-1106	No safety function
	CVC-1107	No safety function
	CVC-1108	No safety function
	CVC-1109	No safety function
	CVC-1111	No safety function

Attachment 10.7
Page 16 of 40
Excluded Valve Table

P&ID	Valve No.	Reason For Exclusion
	CVC-1114A	No safety function
	CVC-1114B	No safety function
	CVC-1114C	No safety function
	CVC-1115	No safety function
	CVC-1116A	No safety function
	CVC-1116B	No safety function
	CVC-1116C	No safety function
	CVC-1122	No safety function
	CVC-1123	No safety function
	CVC-1124	No safety function
	CVC-1125	No safety function
	CVC-1129	No safety function
	CVC-1130	No safety function
	CVC-1131	No safety function
	CVC-1241A	No safety function
	CVC-1241B	No safety function
	CVC-1241C	No safety function
5379-920 (1)	WD-3316	No safety function
5379-921 (2)	WD-1676	No safety function
	WD-1677	No safety function
	WD-1679	No safety function
	WD-3332	No safety function
	WD-3335	No safety function
G-190196 (1)	MS-10A	Category B passive manual valve
	MS-11A	Category B passive manual valve
	MS-12A	Category B passive manual valve
	MS-13	Exempt - instrument valve
	MS-14	Exempt - instrument valve
	MS-15A	Category B passive manual valve

Attachment 10.7
Page 17 of 40
Excluded Valve Table

P&ID	Valve No.	Reason For Exclusion
	MS-155	Category B passive manual valve
	MS-156	Category B passive manual valve
	MS-158	Category B passive manual valve
	MS-159	No safety function
	MS-16	Exempt - instrument valve
	MS-160	Category B passive manual valve
	MS-161	Category B passive manual valve
	MS-17	Exempt - instrument valve
	MS-19	Category B passive manual valve
	MS-20	Category B passive manual valve
	MS-21	Category B passive manual valve
	MS-22	Exempt - instrument valve
	MS-23	Exempt - instrument valve
	MS-25	Exempt - instrument valve
	MS-26	Exempt - instrument valve
	MS-28	Category B passive manual valve
	MS-29	Category B passive manual valve
	MS-30	Category B passive manual valve
	MS-31	Exempt - instrument valve
	MS-32	Exempt - instrument valve
	MS-34	Exempt - instrument valve
	MS-35	Exempt - instrument valve
	MS-37	Category B passive manual valve
	MS-38	Category B passive manual valve
	MS-39	Category B passive manual valve
G-190197 (4)	AFW-120	No safety function
	AFW-121	No safety function
	AFW-15	Exempt - instrument valve
	AFW-20	Category B passive manual valve

Attachment 10.7
Page 18 of 40
Excluded Valve Table

P&ID	Valve No.	Reason For Exclusion
	AFW-22	Category B passive manual valve
	AFW-28	Category B passive manual valve
	AFW-29	Category B passive manual valve
	AFW-4	Category B passive manual valve
	AFW-42	Category B passive manual valve
	AFW-43	Category B passive manual valve
	AFW-51	Exempt - drain valve
	AFW-53	Category B passive manual valve
	AFW-54	Category B passive manual valve
	AFW-55	Category B passive manual valve
	AFW-62	Category B passive manual valve
	AFW-63	Category B passive manual valve
	AFW-64	Category B passive manual valve
	FW-201	Category B passive manual valve
	FW-203	Category B passive manual valve
	FW-205	Category B passive manual valve
	FW-5A	Category B passive manual valve
	FW-5B	Category B passive manual valve
	FW-5C	Category B passive manual valve
	FW-6A	Category B passive manual valve
	FW-6B	Category B passive manual valve
	FW-6C	Category B passive manual valve
	FW-7A	Exempt - maintenance valve
	FW-7B	Exempt - maintenance valve
	FW-7C	Exempt - maintenance valve
G-190199 (1)	SW-197	Exempt - maintenance valve
	SW-198	Exempt - maintenance valve
	SW-199	Exempt - maintenance valve
G-190199 (10)	SW-106	Exempt - maintenance valve

Attachment 10.7
Page 19 of 40
Excluded Valve Table

P&ID	Valve No.	Reason For Exclusion
	SW-243	Exempt - maintenance valve
	SW-246	Category B passive manual valve
	SW-252	Category B passive manual valve
	SW-253	Category B passive manual valve
	SW-259	Category B passive manual valve
	SW-542	No safety function
	SW-543	No safety function
	SW-75	Category B passive manual valve
	SW-76	Category B passive manual valve
	SW-77	Category B passive manual valve
	SW-78	Category B passive manual valve
	SW-900	Exempt - maintenance valve
	SW-914	Exempt - maintenance valve
	SW-922	Category B passive manual valve
	SW-927	Category B passive manual valve
	TCV-1902A	No safety function
	V6-146A	Exempt - vent valve
	V6-146B	Exempt - vent valve
G-190199 (2)	SW-187	Category B passive manual valve
	SW-188	Category B passive manual valve
	SW-190	Category B passive manual valve
	SW-203	Category B passive manual valve
	SW-204	Category B passive manual valve
	SW-205	Category B passive manual valve
	SW-206	Category B passive manual valve
	SW-5	Category B passive manual valve
	SW-6	Category B passive manual valve
	SW-7	Category B passive manual valve
	SW-8	Category B passive manual valve

Attachment 10.7
Page 20 of 40
Excluded Valve Table

P&ID	Valve No.	Reason For Exclusion
	SW-839	Category B passive manual valve
	SW-845	Category B passive manual valve
	SW-851	Category B passive manual valve
	SW-857	Category B passive manual valve
	SW-963	Exempt - instrument valve
	SW-964	Exempt - instrument valve
G-190199 (4)	SW-630	Category B passive manual valve
	SW-632	Category B passive manual valve
	SW-634	Category B passive manual valve
	SW-636	Category B passive manual valve
G-190199 (5)	SW-79A	Category B passive manual valve
	SW-81	Category B passive manual valve
G-190199 (6)	SW-85	Category B passive manual valve
	SW-86	Category B passive manual valve
	SW-87	Category B passive manual valve
	SW-88	Category B passive manual valve
	SW-89	Category B passive manual valve
	SW-90	Category B passive manual valve
	SW-91	Category B passive manual valve
	SW-92	Category B passive manual valve
	SW-93	Category B passive manual valve
	SW-965	Category B passive manual valve
	SW-966	Category B passive manual valve
	SW-967	Category B passive manual valve
	SW-968	Category B passive manual valve
G-190199 (7)	SW-24	Category B passive manual valve
	SW-25	Category B passive manual valve
	SW-26	Category B passive manual valve
	SW-27	Category B passive manual valve

Attachment 10.7
Page 21 of 40
Excluded Valve Table

P&ID	Valve No.	Reason For Exclusion
	SW-28	Category B passive manual valve
	SW-284	Category B passive manual valve
	SW-29	Category B passive manual valve
	SW-307	Category B passive manual valve
	SW-311	Category B passive manual valve
	SW-32	Category B passive manual valve
	SW-33	Category B passive manual valve
	SW-503	Category B passive manual valve
	SW-948	Exempt - maintenance valve
	SW-958	Exempt - maintenance valve
	SW-959	Exempt - maintenance valve
	SW-960	Exempt - drain valve
G-190199 (8)	SW-54	No safety function
	SW-61	No safety function
	SW-68	Category B passive manual valve
G-190199 (9)	FCV-4701	Exempt - control valve
	FCV-4702	Exempt - control valve
	SW-100	Category B passive manual valve
	SW-102	Category B passive manual valve
	SW-109	Category B passive manual valve
	SW-110	Category B passive manual valve
	SW-112	Category B passive manual valve
	SW-113	Category B passive manual valve
	SW-20	Category B passive manual valve
	SW-21	Category B passive manual valve
	SW-260	Exempt - instrument valve
	SW-270	Category B passive manual valve
	SW-52	Category B passive manual valve
	SW-53	Category B passive manual valve

Attachment 10.7
Page 22 of 40
Excluded Valve Table

P&ID	Valve No.	Reason For Exclusion
	SW-739	Category B passive manual valve
	SW-740	Category B passive manual valve
	SW-866	Category B passive manual valve
	SW-869	Category B passive manual valve
	SW-871	Category B passive manual valve
	SW-873	Category B passive manual valve
	SW-875	Category B passive manual valve
	SW-877	Category B passive manual valve
G-190204A (1)	DA-28	Category B passive manual valve
	DA-3A	No safety function
	DA-3B	No safety function
	DA-40	Category B passive manual valve
	DA-45	Category B passive manual valve
G-190204D (2)	FO-13	Category B passive manual valve
	FO-14	Category B passive manual valve
	FO-176A	Category B passive manual valve
	FO-176B	Category B passive manual valve
	FO-177A	Category B passive manual valve
	FO-177B	Category B passive manual valve
	FO-178A	Category B passive manual valve
	FO-178B	Category B passive manual valve
	FO-179A	Category B passive manual valve
	FO-179B	Category B passive manual valve
	FO-191A	Category B passive manual valve
	FO-191B	Category B passive manual valve
	FO-192A	Category B passive manual valve
	FO-192B	Category B passive manual valve
	FO-193A	Exempt - maintenance valve
	FO-193B	Exempt - maintenance valve

Attachment 10.7
Page 23 of 40
Excluded Valve Table

P&ID	Valve No.	Reason For Exclusion
	FO-194A	Exempt - test valve
	FO-194B	Exempt - test valve
	FO-195A	Exempt - maintenance valve
	FO-195B	Exempt - maintenance valve
	FO-196A	Category B passive manual valve
	FO-196B	Category B passive manual valve
	FO-197A	Category B passive manual valve
	FO-197B	Category B passive manual valve
	FO-19A	Category B passive manual valve
	FO-19B	Category B passive manual valve
	FO-20A	Exempt - instrument valve
	FO-20B	Exempt - instrument valve
	FO-23A	Category B passive manual valve
	FO-23B	Category B passive manual valve
	FO-24	Category B passive manual valve
	FO-25A	Category B passive manual valve
	FO-25B	Category B passive manual valve
	FO-26A	No safety function
	FO-26B	No safety function
	FO-28A	Category B manual passive valve
	FO-28B	Category B manual passive valve
G-190234 (1)	SGB-30	No safety function
	SGB-31	No safety function
	SGB-32	No safety function
G-190261 (1)	PP-100B	Category B passive manual valve
	PP-101B	Category B passive manual valve
	PP-102B	Category B passive manual valve
	PP-103B	Category B passive manual valve
	PP-104B	Category B passive manual valve

Attachment 10.7
Page 24 of 40
Excluded Valve Table

P&ID	Valve No.	Reason For Exclusion
	PP-105B	Category B passive manual valve
	PP-106B	Category B passive manual valve
	PP-107B	Category B passive manual valve
	PP-108B	Category B passive manual valve
	PP-109B	Category B passive manual valve
	PP-110B	Category B passive manual valve
	PP-111B	Category B passive manual valve
	PP-112B	Category B passive manual valve
	PP-113B	Category B passive manual valve
	PP-14B	Category B passive manual valve
	PP-15B	Category B passive manual valve
	PP-16A	Category B passive manual valve
	PP-16B	Category B passive manual valve
	PP-17A	Category B passive manual valve
	PP-17B	Category B passive manual valve
	PP-18A	Category B passive manual valve
	PP-18B	Category B passive manual valve
	PP-19A	Category B passive manual valve
	PP-19B	Category B passive manual valve
	PP-20A	Category B passive manual valve
	PP-20B	Category B passive manual valve
	PP-21A	Category B passive manual valve
	PP-21B	Category B passive manual valve
	PP-22B	Category B passive manual valve
	PP-23B	Category B passive manual valve
	PP-24B	Category B passive manual valve
	PP-25B	Category B passive manual valve
	PP-26B	Category B passive manual valve
	PP-27B	Category B passive manual valve

Attachment 10.7
Page 25 of 40
Excluded Valve Table

P&ID	Valve No.	Reason For Exclusion
	PP-28B	Category B passive manual valve
	PP-29B	Category B passive manual valve
	PP-300B	Category B passive manual valve
	PP-301B	Category B passive manual valve
	PP-302B	Category B passive manual valve
	PP-303B	Category B passive manual valve
	PP-304B	Category B passive manual valve
	PP-305B	Category B passive manual valve
	PP-306B	Category B passive manual valve
	PP-307B	Category B passive manual valve
	PP-30B	Category B passive manual valve
	PP-31A	Category B passive manual valve
	PP-31B	Category B passive manual valve
	PP-32A	Category B passive manual valve
	PP-32B	Category B passive manual valve
	PP-33A	Category B passive manual valve
	PP-33B	Category B passive manual valve
	PP-34A	Category B passive manual valve
	PP-34B	Category B passive manual valve
	PP-35A	Category B passive manual valve
	PP-35B	Category B passive manual valve
	PP-36A	Category B passive manual valve
	PP-36B	Category B passive manual valve
	PP-37B	Category B passive manual valve
	PP-38B	Category B passive manual valve
	PP-39B	Category B passive manual valve
	PP-40B	Category B passive manual valve
	PP-41B	Category B passive manual valve
	PP-42B	Category B passive manual valve

Excluded Valve Table

P&ID	Valve No.	Reason For Exclusion
	PP-43B	Category B passive manual valve
	PP-44B	Category B passive manual valve
	PP-45B	Category B passive manual valve
	PP-46B	Category B passive manual valve
	PP-47B	Category B passive manual valve
	PP-48B	Category B passive manual valve
	PP-49B	Category B passive manual valve
	PP-50B	Category B passive manual valve
	PP-51B	Category B passive manual valve
	PP-52B	Category B passive manual valve
	PP-53B	Category B passive manual valve
	PP-54B	Category B passive manual valve
	PP-55B	Category B passive manual valve
	PP-56B	Category B passive manual valve
	PP-57B	Category B passive manual valve
	PP-58B	Category B passive manual valve
	PP-59B	Category B passive manual valve
	PP-60B	Category B passive manual valve
	PP-61B	Category B passive manual valve
	PP-62B	Category B passive manual valve
	PP-63B	Category B passive manual valve
	PP-64B	Category B passive manual valve
	PP-65B	Category B passive manual valve
	PP-66B	Category B passive manual valve
	PP-67B	Category B passive manual valve
	PP-68B	Category B passive manual valve
	PP-69B	Category B passive manual valve
	PP-70B	Category B passive manual valve
	PP-71B	Category B passive manual valve

Excluded Valve Table

P&ID	Valve No.	Reason For Exclusion
	PP-72B	Category B passive manual valve
	PP-73B	Category B passive manual valve
	PP-74B	Category B passive manual valve
	PP-75B	Category B passive manual valve
	PP-76B	Category B passive manual valve
	PP-77B	Category B passive manual valve
	PP-78B	Category B passive manual valve
	PP-79B	Category B passive manual valve
	PP-80B	Category B passive manual valve
	PP-81B	Category B passive manual valve
	PP-82B	Category B passive manual valve
	PP-83B	Category B passive manual valve
	PP-84B	Category B passive manual valve
	PP-85B	Category B passive manual valve
	PP-86B	Category B passive manual valve
	PP-87B	Category B passive manual valve
	PP-88B	Category B passive manual valve
	PP-89B	Category B passive manual valve
	PP-90B	Category B passive manual valve
	PP-91B	Category B passive manual valve
	PP-92B	Category B passive manual valve
	PP-93B	Category B passive manual valve
	PP-94B	Category B passive manual valve
	PP-95B	Category B passive manual valve
	PP-96B	Category B passive manual valve
	PP-97B	Category B passive manual valve
	PP-98B	Category B passive manual valve
	PP-99B	Category B passive manual valve
G-190261 (2)	PP-14C	Category B passive manual valve

Attachment 10.7
Page 28 of 40
Excluded Valve Table

P&ID	Valve No.	Reason For Exclusion
	PP-15C	Category B passive manual valve
	PP-16C	Category B passive manual valve
	PP-17C	Category B passive manual valve
	PP-18C	Category B passive manual valve
	PP-19C	Category B passive manual valve
	PP-20C	Category B passive manual valve
	PP-21C	Category B passive manual valve
	PP-22C	Category B passive manual valve
	PP-23C	Category B passive manual valve
	PP-24C	Category B passive manual valve
	PP-254C	Category B passive manual valve
	PP-255C	Category B passive manual valve
	PP-256C	Category B passive manual valve
	PP-257C	Category B passive manual valve
	PP-25C	Category B passive manual valve
	PP-26C	Category B passive manual valve
	PP-276D	Category B passive manual valve
	PP-27C	Category B passive manual valve
	PP-284D	No safety function
	PP-285D	No safety function
	PP-286D	No safety function
	PP-28C	Category B passive manual valve
	PP-29C	Category B passive manual valve
	PP-30C	Category B passive manual valve
	PP-31C	Category B passive manual valve
	PP-32C	Category B passive manual valve
	PP-33C	Category B passive manual valve
	PP-34C	Category B passive manual valve
	PP-35C	Category B passive manual valve

Attachment 10.7
Page 29 of 40
Excluded Valve Table

P&ID	Valve No.	Reason For Exclusion
	PP-38C	Category B passive manual valve
	PP-40C	Category B passive manual valve
	PP-41C	Category B passive manual valve
	PP-42C	Category B passive manual valve
	PP-44C	Category B passive manual valve
	PP-45C	Category B passive manual valve
	PP-46C	Category B passive manual valve
	PP-47C	Category B passive manual valve
	PP-48C	Category B passive manual valve
	PP-54C	Category B passive manual valve
	PP-55C	Category B passive manual valve
	PP-56C	Category B passive manual valve
	PP-57C	Category B passive manual valve
	PP-58C	Category B passive manual valve
	PP-59C	Category B passive manual valve
	PP-60C	Category B passive manual valve
	PP-61C	Category B passive manual valve
	PP-62C	Category B passive manual valve
	PP-63C	Category B passive manual valve
	PP-64C	Category B passive manual valve
	PP-65C	Category B passive manual valve
	PP-66C	Category B passive manual valve
	PP-67C	Category B passive manual valve
	PP-68C	Category B passive manual valve
	PP-69C	Category B passive manual valve
	PP-70C	Category B passive manual valve
	PP-71C	Category B passive manual valve
	PP-72C	Category B passive manual valve
	PP-73C	Category B passive manual valve

Attachment 10.7
Page 30 of 40
Excluded Valve Table

P&ID	Valve No.	Reason For Exclusion
	PP-74C	Category B passive manual valve
	PP-75C	Category B passive manual valve
	PP-78C	Category B passive manual valve
	PP-80C	Category B passive manual valve
	PP-81C	Category B passive manual valve
	PP-82C	Category B passive manual valve
	PP-84C	Category B passive manual valve
	PP-85C	Category B passive manual valve
	PP-86C	Category B passive manual valve
	PP-87C	Category B passive manual valve
	PP-88C	Category B passive manual valve
G-190261(3)	PP-100D	Category B passive manual valve
	PP-101D	Category B passive manual valve
	PP-102D	Category B passive manual valve
	PP-103D	Category B passive manual valve
	PP-104D	Category B passive manual valve
	PP-105D	Category B passive manual valve
	PP-106D	Category B passive manual valve
	PP-107D	Category B passive manual valve
	PP-114D	Category B passive manual valve
	PP-115D	Category B passive manual valve
	PP-116D	Category B passive manual valve
	PP-117D	Category B passive manual valve
	PP-118D	Category B passive manual valve
	PP-119D	Category B passive manual valve
	PP-120D	Category B passive manual valve
	PP-121D	Category B passive manual valve
	PP-122D	Category B passive manual valve
	PP-123D	Category B passive manual valve

Attachment 10.7

Page 31 of 40

Excluded Valve Table

P&ID	Valve No.	Reason For Exclusion
PP-124D	Category B passive manual valve	
PP-125D	Category B passive manual valve	
PP-126D	Category B passive manual valve	
PP-127D	Category B passive manual valve	
PP-128D	Category B passive manual valve	
PP-129D	Category B passive manual valve	
PP-130D	Category B passive manual valve	
PP-131D	Category B passive manual valve	
PP-132D	Category B passive manual valve	
PP-133D	Category B passive manual valve	
PP-134D	Category B passive manual valve	
PP-135D	Category B passive manual valve	
PP-136D	Category B passive manual valve	
PP-137D	Category B passive manual valve	
PP-138D	Category B passive manual valve	
PP-139D	Category B passive manual valve	
PP-140D	Category B passive manual valve	
PP-141D	Category B passive manual valve	
PP-142D	Category B passive manual valve	
PP-143D	Category B passive manual valve	
PP-144D	Category B passive manual valve	
PP-145D	Category B passive manual valve	
PP-146D	Category B passive manual valve	
PP-147D	Category B passive manual valve	
PP-148D	Category B passive manual valve	
PP-149D	Category B passive manual valve	
PP-150D	Category B passive manual valve	
PP-151D	Category B passive manual valve	

Attachment 10.7
Page 32 of 40
Excluded Valve Table

P&ID	Valve No.	Reason For Exclusion
	PP-152D	Category B passive manual valve
	PP-153D	Category B passive manual valve
	PP-154D	Category B passive manual valve
	PP-155D	Category B passive manual valve
	PP-156D	Category B passive manual valve
	PP-157D	Category B passive manual valve
	PP-158D	Category B passive manual valve
	PP-159D	Category B passive manual valve
	PP-160D	Category B passive manual valve
	PP-161D	Category B passive manual valve
	PP-162D	Category B passive manual valve
	PP-163D	Category B passive manual valve
	PP-164D	Category B passive manual valve
	PP-165D	Category B passive manual valve
	PP-166D	Category B passive manual valve
	PP-167D	Category B passive manual valve
	PP-168D	Category B passive manual valve
	PP-169D	Category B passive manual valve
	PP-170D	Category B passive manual valve
	PP-171D	Category B passive manual valve
	PP-172D	Category B passive manual valve
	PP-173D	Category B passive manual valve
	PP-174D	Category B passive manual valve
	PP-175D	Category B passive manual valve
	PP-176D	Category B passive manual valve
	PP-177D	Category B passive manual valve
	PP-178D	Category B passive manual valve

Excluded Valve Table

P&ID	Valve No.	Reason For Exclusion
	PP-179D	Category B passive manual valve
	PP-17D	Category B passive manual valve
	PP-180D	Category B passive manual valve
	PP-181D	Category B passive manual valve
	PP-182D	Category B passive manual valve
	PP-183D	Category B passive manual valve
	PP-184D	Category B passive manual valve
	PP-185D	Category B passive manual valve
	PP-186D	Category B passive manual valve
	PP-187D	Category B passive manual valve
	PP-188D	Category B passive manual valve
	PP-189D	Category B passive manual valve
	PP-18D	Category B passive manual valve
	PP-190D	Category B passive manual valve
	PP-191D	Category B passive manual valve
	PP-192D	Category B passive manual valve
	PP-193D	Category B passive manual valve
	PP-194D	Category B passive manual valve
	PP-195D	Category B passive manual valve
	PP-196D	Category B passive manual valve
	PP-197D	Category B passive manual valve
	PP-198D	Category B passive manual valve
	PP-199D	Category B passive manual valve
	PP-19D	Category B passive manual valve
	PP-200D	Category B passive manual valve
	PP-201D	Category B passive manual valve
	PP-202D	Category B passive manual valve
	PP-203D	Category B passive manual valve
	PP-204D	Category B passive manual valve

Attachment 10.7
Page 34 of 40
Excluded Valve Table

P&ID	Valve No.	Reason For Exclusion
	PP-205D	Category B passive manual valve
	PP-206D	Category B passive manual valve
	PP-207D	Category B passive manual valve
	PP-208D	Category B passive manual valve
	PP-20D	Category B passive manual valve
	PP-214D	Category B passive manual valve
	PP-219D	Category B passive manual valve
	PP-21D	Category B passive manual valve
	PP-221D	Category B passive manual valve
	PP-222D	Category B passive manual valve
	PP-22D	Category B passive manual valve
	PP-23D	Category B passive manual valve
	PP-24D	Category B passive manual valve
	PP-258D	Category B passive manual valve
	PP-259D	Category B passive manual valve
	PP-25D	Category B passive manual valve
	PP-26D	Category B passive manual valve
	PP-27D	Category B passive manual valve
	PP-28D	Category B passive manual valve
	PP-292	Category B passive manual valve
	PP-293	Category B passive manual valve
	PP-29D	Category B passive manual valve
	PP-30D	Category B passive manual valve
	PP-31D	Category B passive manual valve
	PP-32D	Category B passive manual valve
	PP-33D	Category B passive manual valve
	PP-34D	Category B passive manual valve
	PP-35D	Category B passive manual valve
	PP-36D	Category B passive manual valve

Excluded Valve Table

P&ID	Valve No.	Reason For Exclusion
	PP-37D	Category B passive manual valve
	PP-38D	Category B passive manual valve
	PP-39D	Category B passive manual valve
	PP-40D	Category B passive manual valve
	PP-41D	Category B passive manual valve
	PP-42D	Category B passive manual valve
	PP-43D	Category B passive manual valve
	PP-44D	Category B passive manual valve
	PP-45D	Category B passive manual valve
	PP-46D	Category B passive manual valve
	PP-47D	Category B passive manual valve
	PP-48D	Category B passive manual valve
	PP-49D	Category B passive manual valve
	PP-50D	Category B passive manual valve
	PP-51D	Category B passive manual valve
	PP-52D	Category B passive manual valve
	PP-53D	Category B passive manual valve
	PP-54D	Category B passive manual valve
	PP-55D	Category B passive manual valve
	PP-56D	Category B passive manual valve
	PP-57D	Category B passive manual valve
	PP-58D	Category B passive manual valve
	PP-59D	Category B passive manual valve
	PP-60D	Category B passive manual valve
	PP-61D	Category B passive manual valve
	PP-62D	Category B passive manual valve
	PP-63D	Category B passive manual valve
	PP-64D	Category B passive manual valve
	PP-65D	Category B passive manual valve

Excluded Valve Table:

P&ID	Valve No.	Reason For Exclusion
Water Injection	PP-66D	Category B passive manual valve
Water Injection	PP-67D	Category B passive manual valve
Water Injection	PP-68D	Category B passive manual valve
Water Injection	PP-69D	Category B passive manual valve
Water Injection	PP-70D	Category B passive manual valve
Water Injection	PP-71D	Category B passive manual valve
Water Injection	PP-72D	Category B passive manual valve
Water Injection	PP-73D	Category B passive manual valve
Water Injection	PP-74D	Category B passive manual valve
Water Injection	PP-75D	Category B passive manual valve
Water Injection	PP-76D	Category B passive manual valve
Water Injection	PP-77D	Category B passive manual valve
Water Injection	PP-78D	Category B passive manual valve
Water Injection	PP-79D	Category B passive manual valve
Water Injection	PP-80D	Category B passive manual valve
Water Injection	PP-81D	Category B passive manual valve
Water Injection	PP-82D	Category B passive manual valve
Water Injection	PP-83D	Category B passive manual valve
Water Injection	PP-84D	Category B passive manual valve
Water Injection	PP-85D	Category B passive manual valve
Water Injection	PP-86D	Category B passive manual valve
Water Injection	PP-87D	Category B passive manual valve
Water Injection	PP-88D	Category B passive manual valve
Water Injection	PP-89D	Category B passive manual valve
Water Injection	PP-90D	Category B passive manual valve
Water Injection	PP-91D	Category B passive manual valve
Water Injection	PP-92D	Category B passive manual valve
Water Injection	PP-93D	Category B passive manual valve
Water Injection	PP-94D	Category B passive manual valve

Excluded Valve Table

P&ID	Valve No.	Reason For Exclusion
	PP-95D	Category B passive manual valve
	PP-96D	Category B passive manual valve
	PP-97D	Category B passive manual valve
	PP-98D	Category B passive manual valve
	PP-99D	Category B passive manual valve
G-190261 (4)	PP-108D	Category B passive manual valve
	PP-109C	Category B passive manual valve
	PP-110D	Category B passive manual valve
	PP-14A	Category B passive manual valve
	PP-15A	Category B passive manual valve
	PP-209D	Category B passive manual valve
	PP-210C	Category B passive manual valve
	PP-211D	Category B passive manual valve
	PP-222C	Category B passive manual valve
	PP-223C	Category B passive manual valve
	PP-224C	Category B passive manual valve
	PP-225C	Category B passive manual valve
	PP-226C	Category B passive manual valve
	PP-22A	Category B passive manual valve
	PP-231C	Category B passive manual valve
	PP-232C	Category B passive manual valve
	PP-234C	Category B passive manual valve
	PP-235C	Category B passive manual valve
	PP-236C	Category B passive manual valve
	PP-237C	Category B passive manual valve
	PP-238C	Category B passive manual valve
	PP-23A	Category B passive manual valve
	PP-240C	Category B passive manual valve
	PP-241C	Category B passive manual valve

Attachment 10.7
Page 38 of 40
Excluded Valve Table

P&ID	Valve No.	Reason For Exclusion
	PP-242C	Category B passive manual valve
	PP-244A	Category B passive manual valve
	PP-244C	Category B passive manual valve
	PP-245A	Category B passive manual valve
	PP-246A	Category B passive manual valve
	PP-247A	Category B passive manual valve
	PP-248A	Category B passive manual valve
	PP-249A	Category B passive manual valve
	PP-249C	Category B passive manual valve
	PP-24A	Category B passive manual valve
	PP-250C	Category B passive manual valve
	PP-251C	Category B passive manual valve
	PP-252C	Category B passive manual valve
	PP-261D	Category B passive manual valve
	PP-262A	Category B passive manual valve
	PP-262D	Category B passive manual valve
	PP-263D	Category B passive manual valve
	PP-264D	Category B passive manual valve
	PP-265D	Category B passive manual valve
	PP-266D	Category B passive manual valve
	PP-274C	Category B passive manual valve
	PP-291A	Category B passive manual valve
	PP-291B	Category B passive manual valve
	PP-291C	Category B passive manual valve
	PP-295	Category B passive manual valve
	PP-29A	Category B passive manual valve
	PP-308	Category B passive manual valve
	PP-309	Category B passive manual valve
	PP-30A	Category B passive manual valve

Attachment 10.7
Page 39 of 40
Excluded Valve Table

P&ID	Valve No.	Reason For Exclusion
G-190262 (1)	PP-310	Category B passive manual valve
	PP-36C	Category B passive manual valve
	PP-38A	Category B passive manual valve
	PP-40A	Category B passive manual valve
	PP-41A	Category B passive manual valve
	PP-42A	Category B passive manual valve
	PP-43A	Category B passive manual valve
	PP-49C	Category B passive manual valve
	PP-89C	Category B passive manual valve
	PP-90C	Category B passive manual valve
	PP-91C	Category B passive manual valve
	PP-92C	Category B passive manual valve
	PP-93C	Category B passive manual valve
	IVSW-16D	Category B passive manual valve
	IVSW-16G	Category B passive manual valve
	IVSW-70	No safety function
	IVSW-98	No safety function
	PCV-26E	Exempt - control valve
	PCV-30A	Exempt - control valve
	PCV-30G	Exempt - control valve
HBR2-6490 (1)	PCV-30G1	Exempt - control valve
	PCV-30G2	Exempt - control valve
	VCT-15	Category B passive manual valve
HBR2-9067 (1)	VCT-16	Category B passive manual valve
	VCT-17	Category B passive manual valve
	RC-588A	Category B passive manual valve
	RC-588B	Category B passive manual valve
	RC-591	Category B passive manual valve
	RC-592	Category B passive manual valve

Attachment 10.7
Page 40 of 40
Excluded Valve Table

P&ID	Valve No.	Reason For Exclusion
100-100	RC-599	Category B passive manual valve
100-100	RC-600A	Category B passive manual valve
100-100	RC-600B	Category B passive manual valve
100-100	RC-600C	Category B passive manual valve
100-100	RC-600D	Category B passive manual valve
100-100	RC-600E	Category B passive manual valve
100-100	RC-600F	Category B passive manual valve
100-100	RC-600G	Category B passive manual valve
100-100	RC-600H	Category B passive manual valve
100-100	RC-600I	Category B passive manual valve
100-100	RC-600J	Category B passive manual valve
100-100	RC-600K	Category B passive manual valve
100-100	RC-600L	Category B passive manual valve
100-100	RC-600M	Category B passive manual valve
100-100	RC-600N	Category B passive manual valve
100-100	RC-600O	Category B passive manual valve
100-100	RC-600P	Category B passive manual valve
100-100	RC-600Q	Category B passive manual valve
100-100	RC-600R	Category B passive manual valve
100-100	RC-600S	Category B passive manual valve
100-100	RC-600T	Category B passive manual valve
100-100	RC-600U	Category B passive manual valve
100-100	RC-600V	Category B passive manual valve
100-100	RC-600W	Category B passive manual valve
100-100	RC-600X	Category B passive manual valve
100-100	RC-600Y	Category B passive manual valve
100-100	RC-600Z	Category B passive manual valve