



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

June 22, 2012

APPLICANT: NextEra Energy Seabrook, LLC

FACILITY: Seabrook Station

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON MAY 16, 2012, BETWEEN THE U.S. NUCLEAR REGULATORY COMMISSION AND NEXTERA ENERGY SEABROOK, LLC, CONCERNING THE RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION PERTAINING TO THE SEABROOK STATION LICENSE RENEWAL APPLICATION (TAC NO. ME4028)

The U.S. Nuclear Regulatory Commission (NRC or the staff) and representatives of NextEra Energy Seabrook, LLC (NextEra or the applicant), held a telephone conference call on May 16, 2012, to discuss the response to the request for additional information (RAI) concerning the Seabrook Station license renewal application (LRA).

Enclosure 1 provides a listing of the participants and Enclosure 2 contains a listing of the RAIs that were discussed with the applicant, including a brief description on the status of the item.

The applicant had an opportunity to comment on this summary.

A handwritten signature in black ink, reading "Arthur Cunanan", is positioned above the typed name and title.

Arthur Cunanan, Project Manager
Projects Branch 1
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket No. 50-443

Enclosures:
As stated

cc w/encls: Listserv

**TELEPHONE CONFERENCE CALL
SEABROOK STATION LICENSE RENEWAL APPLICATION**

LIST OF PARTICIPANTS
May 16, 2012

PARTICIPANTS

Arthur Cunanan
Michael Marshall
Abdul Sheikh
Richard Cliche
Ted Vassallo
Ed Carley

AFFILIATIONS

U.S. Nuclear Regulatory Commission (NRC)
NRC
NRC
NextEra Energy Seabrook, LLC. (NextEra)
NextEra
NextEra

**TELEPHONE CONFERENCE CALL
SEABROOK STATION
LICENSE RENEWAL APPLICATION**

The U.S. Nuclear Regulatory Commission (NRC or the staff) and representatives of NextEra Energy Seabrook, LLC (the applicant), held telephone conference calls on May 16, 2012, to discuss the response to the request for additional information (RAI) concerning the Seabrook Station license renewal application (LRA).

RAI B.2.1.28-3 and RAI B.2.1.31-1: Related to the ASME Section XI, Subsection IWL and Structures Monitoring Programs

The applicant discussed submitting a plant-specific aging management program related to alkali-silica reaction (ASR) on May 16, 2012.

The staff will review the applicant's submittal. The staff will not send an RAI. This item is tracked as Open Item OI 3.0.3.2.18-1 in the safety evaluation report with open items.

June 22, 2012

APPLICANT: NextEra Energy Seabrook, LLC

FACILITY: Seabrook Station

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON MAY 16, 2012, BETWEEN THE U.S. NUCLEAR REGULATORY COMMISSION AND NEXTERA ENERGY SEABROOK, LLC, CONCERNING THE RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION PERTAINING TO THE SEABROOK STATION LICENSE RENEWAL APPLICATION (TAC NO. ME4028)

The U.S. Nuclear Regulatory Commission (NRC or the staff) and representatives of NextEra Energy Seabrook, LLC (NextEra or the applicant), held a telephone conference call on May 16, 2012, to discuss the response to the request for additional information (RAI) concerning the Seabrook Station license renewal application (LRA).

Enclosure 1 provides a listing of the participants and Enclosure 2 contains a listing of the RAIs that were discussed with the applicant, including a brief description on the status of the item.

The applicant had an opportunity to comment on this summary.

/RA/

Arthur Cunanan, Project Manager
Projects Branch 1
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket No. 50-443

Enclosures:
As stated

cc w/encls: Listserv

DISTRIBUTION:

See next page

ADAMS Accession No.: ML12165A595

*by e-mail

OFFICE	PM:RPB1:DLR	LA:RPB2:DLR	BC:RPB1:DLR	PM:RPB1:DLR
NAME	ACunanan	IKing*	DMorey	ACunanan
DATE	6/19/12	6/18/2012	6/22/12	6/22/12

OFFICIAL RECORD COPY

Memorandum to NextEra Energy Seabrook, LLC from A. Cunanan dated June 22, 2012

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON MAY 16, 2012,
BETWEEN THE U.S. NUCLEAR REGULATORY COMMISSION AND NEXTERA
ENERGY SEABROOK, LLC, CONCERNING THE RESPONSE TO REQUEST
FOR ADDITIONAL INFORMATION PERTAINING TO THE SEABROOK
STATION LICENSE RENEWAL APPLICATION (TAC NO. ME4028)

DISTRIBUTION:

E-MAIL:

PUBLIC

RidsNrrDlr Resource
RidsNrrDlrRpb1 Resource
RidsNrrDlrRpb2 Resource
RidsNrrDlrRarb Resource
RidsNrrDlrRapb Resource
RidsNrrDlrRasb Resource
RidsNrrDlrRerb Resource
RidsNrrDlrRpob Resource

MWentzel
ACunanan
DMorey
JLamb
DMcIntyre, OPA
EDacus, OCA
MSpencer, OGC
WRaymond, RI
DTiftt, RI
NMcNamara, RI
NSheehan, RI
DScrenci, RI
JJohnson, RI
ABurritt, RI