



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

July 9, 2012

LICENSEE: STP Nuclear Operating Company

FACILITY: South Texas Project, Units 1 and 2

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON JUNE 6, 2012, BETWEEN THE U.S. NUCLEAR REGULATORY COMMISSION AND STP NUCLEAR OPERATING COMPANY, CONCERNING FUTURE USE OF OPERATING EXPERIENCE - FOLLOWUP, PERTAINING TO THE SOUTH TEXAS PROJECT, UNITS 1 AND 2, LICENSE RENEWAL APPLICATION (TAC NOS. ME4936 AND ME4937)

The U.S. Nuclear Regulatory Commission (NRC or the staff) and representatives of STP Nuclear Operating Company (STPNOC or the applicant) held a telephone conference call on June 6, 2012, to discuss staff concerns related to future use of operating experience for aging management, in the South Texas Project, Units 1 and 2, license renewal application (LRA). The telephone conference call was useful in clarifying staff concerns on the issue.

Enclosure 1 provides a listing of the participants and Enclosure 2 contains a summary of the discussion.

The applicant had an opportunity to comment on this summary.

A handwritten signature in black ink, reading "John Daily", is positioned above the typed name.

John Daily, Sr. Project Manager  
Projects Branch 1  
Division of License Renewal  
Office of Nuclear Reactor Regulation

Docket Nos. 50-498 and 50-499

Enclosures:  
As stated

cc w/encls: Listserv

TELEPHONE CONFERENCE CALL  
SOUTH TEXAS PROJECT  
LICENSE RENEWAL APPLICATION

LIST OF PARTICIPANTS  
June 6, 2012

PARTICIPANTS	AFFILIATIONS
John Daily	U.S. Nuclear Regulatory Commission (NRC)
Bo Pham	NRC
Don Brittner	NRC
Roger Kalikian	NRC
Ken Taplett	STP Nuclear Operating Company (STPNOC)
Martin Reta	STPNOC
Gary Warner	STARS Worley Parsons Center of Business

REQUEST FOR ADDITIONAL INFORMATION  
SOUTH TEXAS PROJECT, UNITS 1 AND 2  
LICENSE RENEWAL APPLICATION  
FUTURE USE OF OPERATING EXPERIENCE, FOLLOWUP  
RAI 1.4-3

June 6, 2012

The U.S. Nuclear Regulatory Commission (NRC or the staff) and representatives of STP Nuclear Operating Company (STPNOC or the applicant) held a telephone conference call on June 6, 2012, to discuss staff concerns related to future use of operating experience for aging management, in the South Texas Project, Units 1 and 2, license renewal application (LRA). The telephone conference call was useful in clarifying staff concerns on the issue.

**RAI 1.4-3 discussion**

The staff provided an overview of the history of this issue and outlined the primary areas of concern as expressed in LR-ISG-2011-05, "Ongoing Review of Operating Experience."

The staff also noted that, in its review of the applicant's request for additional information (RAI) response to RAI B1.4-2 dated February 27, 2012, while the applicant provided details of its programmatic framework for considering operating experience on an ongoing basis, some areas required further clarification in order for the staff to complete its review of the issue: (a) the applicant's discussion of using "event codes" in the applicant's Corrective Action Program did not explain how the codes capture age-related equipment failures or degradation; (b) the staff was not clear what implementing actions (if any) would result from performing a "training needs analysis," as proposed by the applicant, for personnel who implement, screen, assign, evaluate, and submit plant-specific and industry operating experience information; and (c) the summary description proposed for the Updated Final Safety Analysis Report (UFSAR) did not sufficiently capture key areas for consideration, when compared to the guidance in Table 3.0-1 "FSAR Supplement for Aging Management of Applicable Systems" of LR-ISG-2011-05.

The applicant agreed that it would take the staff's concerns into account as it prepares its response to the RAI. Both the staff and the applicant agreed that the discussion was useful in clarifying the RAI.

ENCLOSURE 2

July 9, 2012

LICENSEE: STP Nuclear Operating Company

FACILITY: South Texas Project, Units 1 and 2

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON JUNE 6, 2012, BETWEEN THE U.S. NUCLEAR REGULATORY COMMISSION AND STP NUCLEAR OPERATING COMPANY, CONCERNING FUTURE USE OF OPERATING EXPERIENCE - FOLLOWUP, PERTAINING TO THE SOUTH TEXAS PROJECT, UNITS 1 AND 2, LICENSE RENEWAL APPLICATION (TAC NOS. ME4936 AND ME4937)

The U.S. Nuclear Regulatory Commission (NRC or the staff) and representatives of STP Nuclear Operating Company (STPNOC or the applicant) held a telephone conference call on June 6, 2012, to discuss staff concerns related to future use of operating experience for aging management, in the South Texas Project, Units 1 and 2, license renewal application (LRA). The telephone conference call was useful in clarifying staff concerns on the issue.

Enclosure 1 provides a listing of the participants and Enclosure 2 contains a summary of the discussion.

The applicant had an opportunity to comment on this summary.

/RA/

John Daily, Sr. Project Manager  
Projects Branch 1  
Division of License Renewal  
Office of Nuclear Reactor Regulation

Docket Nos. 50-498 and 50-499

Enclosures:  
As stated

cc w/encls: Listserv

DISTRIBUTION: See next page

ADAMS Accession No.: ML12165A608

OFFICE	PM:RPB1:DLR	LA:RPB1:DLR	BC:RPB1:DLR	PM:RPB1:DLR
NAME	JDaily	YEdmonds	DMorey	JDaily
DATE	06/26/12	06/25/12	07/02/12	07/09/12

OFFICIAL RECORD COPY

Memorandum to STP Nuclear Operating Company from J. Daily dated July 9, 2012

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON JUNE 6, 2012, BETWEEN THE U.S. NUCLEAR REGULATORY COMMISSION AND STP NUCLEAR OPERATING COMPANY, CONCERNING FUTURE USE OF OPERATING EXPERIENCE - FOLLOWUP, PERTAINING TO THE SOUTH TEXAS PROJECT, UNITS 1 AND 2, LICENSE RENEWAL APPLICATION (TAC NOS. ME4936 AND ME4937)

**DISTRIBUTION:**

**E-MAIL:**

PUBLIC

RidsNrrDlr Resource

RidsNrrDlrRpb1 Resource

RidsNrrDlrRpb2 Resource

RidsNrrDlrRerb Resource

RidsNrrDlrRpob Resource

RidsNrrDraApla Resource

RidsOgcMailCenter Resource

-----  
JDaily

ABuford

TTran

DMcIntyre, OPA

BSingal, DORL

VWalker, RIV

JDixon, RIV

BTharakan, RIV

WMaier, RIV

VDricks, RIV

NOKeefe, RIV

AVegel, RIV

GPick, RIV