

BellBendCOLPEM Resource

From: Canova, Michael
Sent: Tuesday, June 05, 2012 1:51 PM
To: Sgarro, Rocco R; 'melanie.Frailer@unistarnuclear.com'; Woodring, Kathryn L; Kirkwood, Jon K
Cc: BellBendCOL Resource; Segala, John; Miernicki, Michael; Goldin, Laura; Jaffe, David; Karas, Rebecca; Robinson, Edward; Hernandez, Raul; Devlin, Stephanie; McKenna, Eileen; Williams, Kevin; Clark, Phyllis; Hearn, Peter
Subject: RE: Bell Bend COLA - Revised Draft Request for Information No. 118 (RAI No. 118) - 6496, 6503, 6514
Attachments: DRAFT RAI Letter 118 REVISED- RGS2-6514 BPFP-6503 NSIR EP-6496.doc

[The attachment has been revised to correct format and textual errors. Please delete the previous mailing.](#)

Attached is DRAFT RAI No. [118](#) for the Bell Bend COL Application. Please contact me at your earliest convenience to identify whether you need a clarifying conference call prior to issuance of this RAI. [A call on section 2.05.02 is highly recommended.](#)

During the call, a schedule for response submittal will also need to be established

If you have any questions, please contact me.

Michael A. Canova

Project Manager - Bell Bend COL Application
Docket 52-039
EPR Project Branch
Division of New Reactor Licensing
Office of New Reactors
301-415-0737

Hearing Identifier: BellBend_COL_Public
Email Number: 546

Mail Envelope Properties (77BCCD26C6050B42A72FE3939CF492EDB7A8D3FDD8)

Subject: RE: Bell Bend COLA - Revised Draft Request for Information No. 118 (RAI No. 118) - 6496, 6503, 6514
Sent Date: 6/5/2012 1:51:04 PM
Received Date: 6/5/2012 1:51:06 PM
From: Canova, Michael

Created By: Michael.Canova@nrc.gov

Recipients:

"BellBendCOL Resource" <BellBendCOL.Resource@nrc.gov>
Tracking Status: None
"Segala, John" <John.Segala@nrc.gov>
Tracking Status: None
"Miernicki, Michael" <Michael.Miernicki@nrc.gov>
Tracking Status: None
"Goldin, Laura" <Laura.Goldin@nrc.gov>
Tracking Status: None
"Jaffe, David" <David.Jaffe@nrc.gov>
Tracking Status: None
"Karas, Rebecca" <Rebecca.Karas@nrc.gov>
Tracking Status: None
"Robinson, Edward" <Edward.Robinson@nrc.gov>
Tracking Status: None
"Hernandez, Raul" <Raul.Hernandez@nrc.gov>
Tracking Status: None
"Devlin, Stephanie" <Stephanie.Devlin@nrc.gov>
Tracking Status: None
"McKenna, Eileen" <Eileen.McKenna@nrc.gov>
Tracking Status: None
"Williams, Kevin" <Kevin.Williams@nrc.gov>
Tracking Status: None
"Clark, Phyllis" <Phyllis.Clark@nrc.gov>
Tracking Status: None
"Hearn, Peter" <Peter.Hearn@nrc.gov>
Tracking Status: None
"Sgarro, Rocco R" <rrsgarro@pplweb.com>
Tracking Status: None
"melanie.Frailer@unistarnuclear.com" <melanie.Frailer@unistarnuclear.com>
Tracking Status: None
"Woodring, Kathryn L" <KFitzpatrick@pplweb.com>
Tracking Status: None
"Kirkwood, Jon K" <jon.kirkwood@unistarnuclear.com>
Tracking Status: None

Post Office: HQCLSTR01.nrc.gov

Files	Size	Date & Time
MESSAGE	709	6/5/2012 1:51:06 PM
DRAFT RAI Letter 118 REVISED- RGS2-6514 BPFP-6503 NSIR EP-6496.doc		

35322

Options**Priority:**

Standard

Return Notification:

No

Reply Requested:

No

Sensitivity:

Normal

Expiration Date:**Recipients Received:**

RAI Letter No. 118

Application Revision 3

DRAFT

6/5/2012

Bell Bend
PPL Bell Bend LLC.
Docket No. 52-039

QUESTION from Geosciences and Geotechnical Engineering Branch 2 (RGS2)
Request for Additional Information No. 6514

SRP Section: 02.05.02 - Vibratory Ground Motion
Application Section: 02.05.02

Question 02.05.02-1

This request for additional information (RAI) specifically addresses Recommendation 2.1, of the Fukushima Near-Term Task Force recommendations contained in SECY-12-0025 as it pertains to the seismic hazard evaluation. This recommendation specifies the use of NUREG-2115, "Central and Eastern United States Seismic Source Characterization for Nuclear Facilities," (CEUS-SSC) in a site probabilistic seismic hazard analysis (PSHA). Consistent with Recommendation 2.1, as well as the need to consider the latest available information in the (PSHA) for the Bell Bend Nuclear Power Plant planned reactor site, the NRC staff requests that PPL Bell Bend, LLC:

- a) Evaluate the potential impacts of the newly released CEUS-SSC model, with potential local and regional refinements as identified in the CEUS-SSC model, on the seismic hazard curves and the site-specific ground motion response spectra (GMRS)/foundation input response spectra (FIRS). For re-calculation of the PSHA, please follow either the cumulative absolute velocity (CAV) filter or minimum magnitude specifications outlined in Attachment 1 to Seismic Enclosure 1 of the March 12, 2012 letter "Request for information pursuant to Title 10 of the *Code of Federal Regulations* 50.54(f) regarding Recommendations 2.1, 2.3, and 9.3, of the near-term task force review of insights from the Fukushima Dai-Ichi accident." (ML12053A340).
- b) Modify the site-specific GMRS and FIRS if you determine changes are necessary given the evaluation performed in part a) above.

QUESTION from Balance of Plant & Fire Protection Branch (BPFP)
Request for Additional Information No. 6503

SRP Section: 09.01.03 - Spent Fuel Pool Cooling and Cleanup System
Application Section: 9.1.3

Question 09.01.03-1

Related to Fukushima Task Force Recommendation 7.1

Provide sufficient reliable instrumentation, able to withstand design-basis natural phenomena, to monitor spent fuel pool water level, as described in Attachment 3 to Order EA-12-051 (ML12054A679).

QUESTION from Licensing and Inspection Branch (NSIR/DPR/LIB) (EP)
Request for Additional Information No. 6496

SRP Section: 13.03 - Emergency Planning
Application Section: Part 5: Emergency Plan

Question 13.03-52

Related to Fukushima Task Force Recommendation 9.3

The NRC staff requests that you address provisions for enhancing emergency preparedness as it relates to staffing and communications associated with Recommendation 9.3 outlined in Enclosure 5 of the March 12, 2012 letter "Request for information pursuant to Title 10 of the *Code of Federal Regulations* 50.54(f) regarding Recommendations 2.1, 2.3, and 9.3, of the near-term task force review of insights from the Fukushima Dai-Ichi accident." (ML12053A340).