



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

July 11, 2012

Mr. Mark E. Reddemann
Chief Executive Officer
Energy Northwest
P.O. Box 968 (Mail Drop 1023)
Richland, WA 99352-0968

SUBJECT: COLUMBIA GENERATING STATION – CORRECTION TO PAGES ISSUED
WITH AMENDMENT NO. 210

Dear Mr. Reddemann:

By letter dated September 30, 2008 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML082610049), the U.S. Nuclear Regulatory Commission (NRC) issued Amendment No. 210 to Facility Operating License No. NPF-21 for the Columbia Generating Station (CGS). The amendment consisted of changes to the Technical Specifications (TSs) in response to your application dated July 26, 2007, as superseded by application dated August 8, 2007, and as supplemented by letters dated November 19, 2007, and June 5 and July 21, 2008.

An administrative error was discovered in the electronic version of the amended TS pages for CGS following issuance of Amendment No. 210. The error resulted in the omission of page 3.3.5.2-3 and the duplication of page 3.3.5.2-4 from the attachment to the amendment document. The administrative error does not change the NRC staff's conclusions in Amendment No. 210.

Enclosed are corrected TS pages for Amendment No. 210. If you have any questions, please contact me at 301-415-1056 or via e-mail at Lauren.Gibson@nrc.gov.

Sincerely,

A handwritten signature in black ink that reads "Lauren Kate Gibson".

Lauren Gibson, Project Manager
Plant Licensing Branch IV
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-397

Enclosure:
As stated

cc w/encl: Distribution via Listserv

ENCLOSURE

Replacement Pages 3.3.5.2-3 and 3.3.5.2-4
issued with License Amendment No. 210,
Issued September 30, 2008

SURVEILLANCE REQUIREMENTS

NOTES

1. Refer to Table 3.3.5.2-1 to determine which SRs apply for each RCIC Function.
2. When a channel is placed in an inoperable status solely for performance of required Surveillances, entry into associated Conditions and Required Actions may be delayed as follows: (a) for up to 6 hours for Functions 2 and 4; and (b) for up to 6 hours for Functions 1 and 3 provided the associated Function maintains RCIC initiation capability.

SURVEILLANCE		FREQUENCY
SR 3.3.5.2.1	Perform CHANNEL CHECK.	12 hours
SR 3.3.5.2.2	Perform CHANNEL FUNCTIONAL TEST.	92 days
SR 3.3.5.2.3	Perform CHANNEL CALIBRATION.	18 months
SR 3.3.5.2.4	Perform LOGIC SYSTEM FUNCTIONAL TEST.	24 months

Table 3.3.5.2-1 (page 1 of 1)
Reactor Core Isolation Cooling System Instrumentation

FUNCTION	REQUIRED CHANNELS PER FUNCTION	CONDITIONS REFERENCED FROM REQUIRED ACTION A.1	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
1. Reactor Vessel Water Level - Low Low, Level 2	4	B	SR 3.3.5.2.1 SR 3.3.5.2.2 SR 3.3.5.2.3 SR 3.3.5.2.4	≥ -58 inches
2. Reactor Vessel Water Level - High, Level 8	2	C	SR 3.3.5.2.1 SR 3.3.5.2.2 SR 3.3.5.2.3 SR 3.3.5.2.4	≤ 56 inches
3. Condensate Storage Tank Level - Low	2	D	SR 3.3.5.2.1 SR 3.3.5.2.2 SR 3.3.5.2.3 SR 3.3.5.2.4	≥ 447 ft 7 inches elevation
4. Manual Initiation	2	C	SR 3.3.5.2.4	NA

July 11, 2012

Mr. Mark E. Reddemann
Chief Executive Officer
Energy Northwest
P.O. Box 968 (Mail Drop 1023)
Richland, WA 99352-0968

SUBJECT: COLUMBIA GENERATING STATION – CORRECTION TO PAGES ISSUED
WITH AMENDMENT NO. 210

Dear Mr. Reddemann:

By letter dated September 30, 2008 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML082610049), the U.S. Nuclear Regulatory Commission (NRC) issued Amendment No. 210 to Facility Operating License No. NPF-21 for the Columbia Generating Station (CGS). The amendment consisted of changes to the Technical Specifications (TSs) in response to your application dated July 26, 2007, as superseded by application dated August 8, 2007, and as supplemented by letters dated November 19, 2007, and June 5 and July 21, 2008.

An administrative error was discovered in the electronic version of the amended TS pages for CGS following issuance of Amendment No. 210. The error resulted in the omission of page 3.3.5.2-3 and the duplication of page 3.3.5.2-4 from the attachment to the amendment document. The administrative error does not change the NRC staff's conclusions in Amendment No. 210.

Enclosed are corrected TS pages for Amendment No. 210. If you have any questions, please contact me at 301-415-1056 or via e-mail at Lauren.Gibson@nrc.gov.

Sincerely,

/RA/

Lauren Gibson, Project Manager
Plant Licensing Branch IV
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-397

Enclosure:
As stated

cc w/encl: Distribution via Listserv

DISTRIBUTION:

PUBLIC
LPLIV Reading
RidsAcrsAcnw_MailCTR Resource
RidsNrrDorLp4 Resource
RidsNrrPMColumbia Resource

RidsNrrLAJBurkhardt Resource
RidsOgcRp Resource
RidsRgn4MailCenter Resource
RecordsAmend Resource

ADAMS Accession No. ML12172A025

OFFICE	NRR/LPL4/PM	NRR/LPL4/PM	NRR/LPL4/LA	NRR/LPL4/BC	NRR/LPL4/PM
NAME	LWilkins	LGibson	JBurkhardt	MMarkley	LGibson
DATE	7/6/12	7/10/12	7/6/12	7/11/12	7/11/12

OFFICIAL RECORD COPY