



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

June 26, 2012

Mr. Kevin D. Richards
President and Chief Executive Officer/
STP Nuclear Operating Company
South Texas Project
P.O. Box 289
Wadsworth, TX 77483

SUBJECT: SOUTH TEXAS PROJECT, UNITS 1 AND 2 – CLOSEOUT OF NRC
BULLETIN 2011-01, "MITIGATING STRATEGIES" (TAC NOS. ME6486 AND
ME6487)

Dear Mr. Richards:

On May 11, 2011, the U.S. Nuclear Regulatory Commission (NRC) issued Bulletin 2011-01, "Mitigating Strategies" (Agencywide Documents Access and Management System (ADAMS) Accession No. ML111250360), to all holders of operating licenses for nuclear power reactors, except those that have permanently ceased operation and have certified that fuel has been removed from the reactor vessel. The purpose of the bulletin was to obtain a comprehensive verification that licensees' mitigating strategies to maintain or restore core cooling, spent fuel cooling, and containment following a large explosion or fire were compliant with Title 10 of the *Code of Federal Regulations* (10 CFR) Section 50.54(hh)(2).

The bulletin required two sets of responses pursuant to the provisions of 10 CFR 50.54(f). STP Nuclear Operating Company (the licensee) provided its responses to the bulletin by letters dated June 8 and July 7, 2011 (ADAMS Accession Nos. ML11165A095 and ML11195A209, respectively), for South Texas Project, Units 1 and 2. By letter dated November 28, 2011 (ADAMS Accession No. ML113110149), the NRC sent the licensee a request for additional information (RAI) on its July 7, 2011, response. The licensee responded to the RAI by letter dated December 20, 2011 (ADAMS Accession No. ML12003A240).


The NRC staff has reviewed the information submitted by the licensee and concludes that its response to the bulletin is acceptable. As summarized in the enclosure, the NRC staff verified that the licensee provided the information requested in the bulletin and no further information or actions under the bulletin are requested.

K. Richards

- 2 -

If you have any questions, please contact Balwant K. Singal at 301-415-3016 or by e-mail at Balwant.Singal@nrc.gov.

Sincerely,

A handwritten signature in black ink, appearing to read "Balwant K. Singal". The signature is fluid and cursive, with the first name "Balwant" and last name "Singal" clearly distinguishable.

Balwant K. Singal, Senior Project Manager
Plant Licensing Branch IV
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket Nos. 50-498 and 50-499

Enclosure:
As stated

cc w/encl: Distribution via Listserv

SUMMARY OF NRC REVIEW OF LICENSEE'S RESPONSES TO

NRC BULLETIN 2011-01, "MITIGATING STRATEGIES"

STP NUCLEAR OPERATING COMPANY

SOUTH TEXAS PROJECT, UNITS 1 AND 2

DOCKET NOS. 50-498 AND 50-499

1.0 INTRODUCTION

On May 11, 2011, the U.S. Nuclear Regulatory Commission (NRC) issued Bulletin 2011-01, "Mitigating Strategies" (Agencywide Documents Access and Management System (ADAMS) Accession No. ML111250360), to all holders of operating licenses for nuclear power reactors, except those that have permanently ceased operation and have certified that fuel has been removed from the reactor vessel. The bulletin required two sets of responses pursuant to the provisions of with Title 10 of the *Code of Federal Regulations* (10 CFR) Section 50.54(f). The first responses were due 30 days after issuance of the bulletin. By letter dated June 8, 2011 (ADAMS Accession No. ML11165A095), STP Nuclear Operating Company (the licensee), provided its response to this first set of questions (first response) for South Texas Project (STP), Units 1 and 2. The second responses were due 60 days after issuance of the bulletin. By letter dated July 7, 2011 (ADAMS Accession No. ML11195A209), the licensee provided its response to this second set of questions (second response). By letter dated November 28, 2011 (ADAMS Accession No. ML113110149), the NRC sent the licensee a request for additional information (RAI) on its July 7, 2011, response. The licensee responded to the RAI by letter dated December 20, 2011 (ADAMS Accession No. ML12003A240). As summarized below, the NRC staff has verified that the licensee provided the information requested in the bulletin.

2.0 BACKGROUND

On February 25, 2002, the NRC issued ICM Order EA-02-026, "Order for Interim Safeguards and Security Compensatory Measures" (ICM Order) (ADAMS Accession No. ML020510635). Section B.5.b of the ICM Order required licensees to develop specific guidance and strategies to maintain or restore core cooling, containment, and spent fuel pool cooling capabilities using readily available resources (equipment and personnel) that can be effectively implemented under the circumstances associated with the loss of large areas of the plant due to explosions or fire.

By letter dated July 11, 2007 (ADAMS Accession No. ML071910382), the NRC staff issued its safety evaluation (SE) to document the final disposition of information submitted by the licensee regarding Section B.5.b of the ICM Order. Along with the SE, the NRC staff issued a conforming license condition to incorporate the B.5.b mitigating strategies into the licensing basis.

On March 27, 2009, the NRC issued 10 CFR 50.54(hh)(2) as a new rule, in order to capture the B.5.b mitigating strategies and related license conditions as regulatory requirements for both

Enclosure

current and future licensees. At that time, licensee compliance with the conforming license conditions was sufficient to demonstrate compliance with 10 CFR 50.54(hh)(2) (74 FR 13926; March 27, 2009) so no further actions were required on the part of current licensees.

3.0 30-DAY REQUEST

In order to confirm continued compliance with 10 CFR 50.54(hh)(2), the bulletin requested that licensees address the following two questions within 30 days of issuing the bulletin:

1. Is the equipment necessary to execute the mitigating strategies, as described in your submittals to the NRC, available and capable of performing its intended function?
2. Are the guidance and strategies implemented capable of being executed considering the current configuration of your facility and current staffing and skill levels of the staff?

The NRC staff reviewed the licensee's first response to determine if it had adequately addressed these questions.

3.1 Question 1: Availability and Capability of Equipment

In its first response, the licensee confirmed that equipment it needs to execute the 10 CFR 50.54(hh)(2) mitigating strategies is available and capable of performing its intended function. The NRC staff verified that this confirmation covered equipment needed for each of the three phases of B.5.b mitigation strategies. Therefore, the NRC staff concludes that the licensee has adequately responded to Question 1.

3.2 Question 2: Guidance and Strategies Can Be Executed

In its first response, the licensee confirmed that the guidance and strategies it has implemented for 10 CFR 50.54(hh)(2) are capable of being executed considering the current facility configuration, staffing levels, and staff skills. Since the licensee has considered its current facility configuration, staffing levels, and staff skills, and confirmed that it can execute its implemented guidance and strategies, the NRC staff concludes that the licensee has adequately responded to Question 2.

4.0 60-DAY REQUEST

The bulletin required a response to the following five questions within 60 days of issuing the bulletin:

1. Describe in detail the maintenance of equipment procured to support the strategies and guidance required by 10 CFR 50.54(hh)(2) in order to ensure that it is functional when needed.

2. Describe in detail the testing of equipment procured to support the strategies and guidance required by 10 CFR 50.54(hh)(2) in order to ensure that it will function when needed.
3. Describe in detail the controls for assuring that the equipment is available when needed.
4. Describe in detail how configuration and guidance management is assured so that strategies remain feasible.
5. Describe in detail how you assure availability of offsite support.

The NRC staff reviewed licensee's second response to determine if it had adequately addressed these questions. This was accomplished by verifying that the submittals dated July 7, 2011, and December 20, 2011, listed equipment, training, and offsite sources which were relied upon for reaching conclusions in NRC staff's SE dated July 11, 2007, or are commonly needed to implement the mitigating strategies.

4.1 Questions 1 and 2: Maintenance and Testing of Equipment

Questions 1 and 2 of the 60-day request required licensees to describe in detail the maintenance and testing of equipment procured to support the strategies and guidance required by 10 CFR 50.54(hh)(2) in order to ensure that it is functional when needed. In its second response, the licensee listed the equipment used to support the 10 CFR 50.54(hh)(2) mitigating strategies which receives maintenance or testing. For each item, the licensee described the maintenance and testing performed, including the frequency and basis for the maintenance or testing activity.

The NRC staff verified that the licensee listed equipment that typically requires maintenance or testing which was relied upon to make conclusions in the SE or commonly needed to implement the mitigating strategies. In its second response, the licensee stated that the portable pump, hoses, and spray nozzles receive maintenance or testing. The NRC staff noted in the RAI that the licensee did not describe any maintenance, testing, or controls on communications equipment in its second response. In its RAI response dated December 20, 2011, the licensee described the testing and inventory requirements for communications equipment. The NRC staff noted that the fuel level for the portable pump is verified during inventory. The licensee also identified other items that support the mitigating strategies that receive maintenance or testing.

The NRC staff verified that the licensee described the process used for corrective actions and listed the testing performed to ensure that the strategies were initially feasible. The licensee stated in its second response that its 10 CFR Part 50, Appendix B, corrective action program is used to document equipment failure, establish priorities, and perform trending.

Based on the above, the NRC staff concludes that the licensee has provided the information requested by Questions 1 and 2.

4.2 Question 3: Controls on Equipment

Question 3 of the 60-day request required licensees to describe in detail the controls on equipment, such as inventory requirements, to ensure that the equipment is available when needed. A list of inventory deficiencies and associated corrective actions to prevent loss was also requested.

The NRC staff verified that the licensee described its process for ensuring that B.5.b equipment will be available when needed. In its second response, the licensee identified equipment included in its inventory, the inventory frequency, storage requirements, and items verified. Items verified include proper quantity, location, and accessibility of equipment; equipment shelf lives; and controls on storage locations. The licensee states that at the time of its second response there were no outstanding inventory deficiencies that would render the strategies not viable.

The NRC staff verified that the licensee inventoried equipment which was relied upon to make conclusions in the SE or commonly needed to implement the mitigating strategies. In its second response, the licensee stated that procured non-permanently installed B.5.b equipment is inventoried at least quarterly in accordance with station procedures. The second response specifically states that the following items are included in the inventory: portable pump; hoses; monitor nozzles; and connectors. In its RAI response dated December 20, 2011, the licensee described how it ensures a vehicle is available to move the portable pump. The licensee also identified other items that support the mitigating strategies that are inventoried.

Based on the above, the NRC staff concludes that the licensee has provided the information requested by Question 3.

4.3 Question 4: Configuration and Guidance Management

Question 4 of the 60-day request required licensees to describe in detail how configuration and guidance management is assured so that the strategies remain feasible.

The NRC staff verified that the licensee described its measures to evaluate plant configuration changes for their effects on the mitigating strategies and to ensure its procedures are current. In its second response, the licensee stated that plant configuration changes are procedurally evaluated against the licensing basis, which includes the B.5.b mitigating strategies. The licensee states that the design change process requires a review of affected procedures and that procedure changes are validated to ensure that the B.5.b mitigating strategies remain viable.

The NRC staff verified that the licensee described measures it has taken to validate the procedures or guidelines developed to support the mitigating strategies. In its second response, the licensee identified testing in response to Question 2 that demonstrated the ability to execute some strategies. The licensee also states that "initially, mitigating strategies were validated by walkdowns and engineering evaluations" and they were revalidated by walkdowns in 2011.

The NRC staff verified that the licensee described the training program implemented in support of the mitigating strategies and how its effectiveness is evaluated. In its second response, the

licensee identified the training provided to its operations personnel, emergency response organization, security personnel, fire brigade, and other personnel. The licensee also identified the frequency with which each type of training is provided and the methods for training evaluating.

Based on the above, the NRC staff concludes that the licensee has provided the information requested by Question 4.

4.4 Question 5: Offsite Support

Question 5 of the 60-day request required licensees to describe in detail how offsite support availability is assured.

The NRC staff verified that the licensee listed the offsite organizations it relies upon for emergency response, including a description of agreements and related training. The NRC staff compared the list of offsite organizations that the licensee provided in its second response with the information relied upon to make conclusions in the SE. The licensee stated that it maintains letters of agreement with these offsite organizations, which are reviewed annually, and that these agreements were current at the time of its second response. The licensee also described the training and site familiarization it provides to these offsite organizations. The licensee stated that it reviewed its corrective action program back to 2008 and found no issues involving lapsed agreements related to offsite support for B.5.b events.

Based on the above, the NRC staff concludes that the licensee has provided the information requested by Question 5.

5.0 CONCLUSION

As described above, the NRC staff has verified that the licensee has provided the information requested in Bulletin 2011-01 for STP, Units 1 and 2. Specifically, the licensee responded to each of the questions in the bulletin as requested. The NRC staff concludes that the licensee has completed all of the requirements of the bulletin for STP, Units 1 and 2, and no further information or actions under the bulletin are needed.

K. Richards

- 2 -

If you have any questions, please contact Balwant K. Singal at 301-415-3016 or by e-mail at Balwant.Singal@nrc.gov.

Sincerely,

/RA/

Balwant K. Singal, Senior Project Manager
Plant Licensing Branch IV
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket Nos. 50-498 and 50-499

Enclosure:
As stated

cc w/encl: Distribution via Listserv

DISTRIBUTION:

PUBLIC

LPLIV Reading

RidsAcrsAcnw_MailCTR Resource

RidsNrrDprPgcb Resource

RidsNrrDorlLpl4 Resource

RidsNrrPMSouthTexas Resource

RidsNrrLAJBurkhardt Resource

RidsOgcRp Resource

RidsRgn4MailCenter Resource

BPurnell, NRR/DPR/PGCB

MMcCoppin, EDO RIV

ADAMS Accession No. ML12173A321

***SE memo dated June 14, 2012**

OFFICE	NRR/LPL4/PM	NRR/LPL4/LA	NRR/DPR/PGCB/BC	NRR/LPL4/BC	NRR/LPL4/PM
NAME	BSingal	JBurkhardt	KMorganButler*	MMarkley	BSingal
DATE	6/25/12	6/25/12	6/14/12	6/26/12	6/26/12

OFFICIAL AGENCY RECORD